

**Facility Summary in Wheatland County in the City of Harlowton**

**Location:** ENGINEERS DEPOT  
102 2nd St NE  
Harlowton, MT 59036-2910 Wheatland

Legacy ID:54-04934

**Facility ID:** 29584  
**Last Inspected On:** 07/28/2021  
**Operating Permit Renewal Date:** 10/31/2024

**Owner Operator Contact:** Dennis Whitmore;S and W Station LLC

**4066515101;4062524661**

**Operator Contact:** Savannah Truesdale;Shawn Truesdale

**4063669701**

Savannah Truesdale, UST Class A Operator  
Savannah Truesdale, UST Class B Operator  
Shawn Truesdale, UST Class A Operator  
Shawn Truesdale, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	33	11/17/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>1045</b>	No			Double Walled	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		04/02/2018	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco/EMC Basic		No
06	33	11/17/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>1046</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/02/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000		04/29/2018	Gilbarco/EMC Basic		No
07	33	11/17/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm

<b>4342</b>	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/02/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000		06/01/2018	Gilbarco/EMC Basic		No
08	18	07/17/2003	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
<b>4850</b>	No			Double Walled	Yes
Currently in Use		08/17/2012	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		04/02/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000		04/29/2018	Gilbarco/EMC Basic		No

**Facility Summary in Wheatland County in the City of Harlowton**

**Location:** MALMSTROM AFB K 1  
US Hwy 191  
Harlowton, MT 59036 Wheatland

Legacy ID:54-09085

**Facility ID:** 29612  
**Last Inspected On:** 04/18/2019  
**Operating Permit Renewal Date:** 08/21/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator: 341 CES CEANQ**

Candace Ellsworth, UST Class A Operator  
Candace Ellsworth, UST Class B Global Operator  
Curtis Hester, UST Class A Operator  
Curtis Hester, UST Class B Global Operator  
William Smith, UST Class A Operator  
William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	59	05/02/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve;High Level Alarm
<b>341</b>	No	04/12/2016	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		03/31/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Wheatland County in the City of Harlowton**

**Location:** MALMSTROM AFB K 10  
US Hwy 12  
Harlowton, MT 59036 Wheatland

Legacy ID:54-09094

**Facility ID:** 29621  
**Last Inspected On:** 04/18/2019  
**Operating Permit Renewal Date:** 07/31/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator: 341 CES CEANQ**

Candace Ellsworth, UST Class A Operator

Candace Ellsworth, UST Class B Global Operator  
 Curtis Hester, UST Class A Operator  
 Curtis Hester, UST Class B Global Operator  
 William Smith, UST Class A Operator  
 William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
<b>350</b>	No	04/11/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Wheatland County in the City of Harlowton**

**Location:** MALMSTROM AFB K 11  
 US Hwy 12  
 Harlowton, MT 59036 Wheatland

Legacy ID:54-09095

**Facility ID:** 29622  
**Last Inspected On:** 04/18/2019  
**Operating Permit Renewal Date:** 07/31/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

Candace Ellsworth, UST Class A Operator  
 Candace Ellsworth, UST Class B Global Operator  
 Curtis Hester, UST Class A Operator  
 Curtis Hester, UST Class B Global Operator  
 William Smith, UST Class A Operator  
 William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	28	06/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>351</b>	No	04/11/2016	Double-Walled	Double Walled	Yes
Currently in Use		Auto Dialer	U.S. Suction	Non-corrodible	
Diesel		Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No	
4,000		Gilbarco-Veeder Root/TLS-350		No	

**Facility Summary in Wheatland County in the City of Harlowton**

**Location:** MALMSTROM AFB K 2  
US Hwy 191  
Harlowton, MT 59036 Wheatland

Legacy ID:54-09086

**Facility ID:** 29613  
**Last Inspected On:** 04/19/2019  
**Operating Permit Renewal Date:** 08/21/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
<b>342</b>	No	04/13/2016	Double-Walled	Double Walled	Yes
Currently in Use		Auto Dialer	U.S. Suction	Non-corrodible	
Diesel		Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No	

4,000

Gilbarco-Veeder Root/TLS-350

No

**Facility Summary in Wheatland County in the City of Harlowton**

**Location:** MALMSTROM AFB K 3  
US Hwy 191  
Harlowton, MT 59036 Wheatland

Legacy ID:54-09087

**Facility ID:** 29614  
**Last Inspected On:** 04/19/2019  
**Operating Permit Renewal Date:** 07/31/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

Candace Ellsworth, UST Class A Operator  
Candace Ellsworth, UST Class B Global Operator  
Curtis Hester, UST Class A Operator  
Curtis Hester, UST Class B Global Operator  
William Smith, UST Class A Operator  
William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
343	No	04/14/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Wheatland County in the City of Harlowton**

**Location:** MALMSTROM AFB K 4  
US Hwy 12  
Harlowton, MT 59036 Wheatland

Legacy ID:54-09088

**Facility ID:** 29615  
**Last Inspected On:** 04/19/2019  
**Operating Permit Renewal Date:** 07/31/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

Candace Ellsworth, UST Class A Operator  
 Candace Ellsworth, UST Class B Global Operator  
 Curtis Hester, UST Class A Operator  
 Curtis Hester, UST Class B Global Operator  
 William Smith, UST Class A Operator  
 William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
344	No	04/13/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Wheatland County in the City of Harlowton**

**Location:** MALMSTROM AFB K 6  
 US Hwy 12  
 Harlowton, MT 59036 Wheatland

Legacy ID:54-09090

**Facility ID:** 29617  
**Last Inspected On:** 04/19/2019  
**Operating Permit Renewal Date:** 07/31/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

Candace Ellsworth, UST Class A Operator  
 Candace Ellsworth, UST Class B Global Operator  
 Curtis Hester, UST Class A Operator  
 Curtis Hester, UST Class B Global Operator  
 William Smith, UST Class A Operator  
 William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
<b>346</b>	No	04/12/2016	Double-Walled	Double Walled	Yes
Currently in Use		Auto Dialer	U.S. Suction	Non-corrodible	
Diesel		Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No	
4,000		Gilbarco-Veeder Root/TLS-350		No	

**Facility Summary in Wheatland County in the City of Harlowton**

Location: MALMSTROM AFB K 8  
US Hwy 191  
Harlowton, MT 59036 Wheatland

Legacy ID:54-09092

Facility ID: 29619  
Last Inspected On: 04/18/2019  
Operating Permit Renewal Date: 07/31/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator: 341 CES CEANQ**

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
<b>348</b>	No	04/12/2016	Double-Walled	Double Walled	Yes
Currently in Use		Auto Dialer	U.S. Suction	Non-corrodible	



Diesel	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000	Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Wheatland County in the City of Harlowton**

**Location:** MALMSTROM AFB K 9  
US Hwy 12  
Harlowton, MT 59036 Wheatland

Legacy ID:54-09093

**Facility ID:** 29620  
**Last Inspected On:** 04/18/2019  
**Operating Permit Renewal Date:** 07/31/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
<b>Tag #</b>	<b>AST</b>	<b>Sump Tightness</b>	<b>Secondary Option</b>	<b>Secondary Option</b>	<b>Spill Protected</b>
<b>Status</b>		<b>Piping Installed Date</b>	<b>Catastrophic L.D. Type 3.0</b>	<b>Piping Type</b>	<b>CP Met Types</b>
<b>Product</b>		<b>Tank/Pipe CP</b>	<b>Tank Detection</b>	<b>Primary Pipe Detection</b>	<b>Vapor Recovery</b>
<b>Capacity</b>		<b>Line Tightness</b>	<b>ATG Type</b>	<b>Secondary Pipe Detection</b>	<b>Energy Act</b>
02	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
<b>349</b>	No	04/11/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Wheatland County in the City of Harlowton**

**Location:** RAYS SPORT and WESTERN WEAR  
1504 US Hwy 12 E  
Harlowton, MT 59036 Wheatland

Legacy ID:54-11975

**Facility ID:** 29636  
**Last Inspected On:** 02/24/2021  
**Operating Permit Renewal Date:** 02/24/2024

**Owner Operator Contact:** Ray and Alma Hinand Trust Rays Sports and Western      **4066324329**

Operator Contact: Anita Leach

**Owner/Operator:** Ray and Alma Hinand Trust Rays Sports and Western

Anita Leach, UST Class A Operator

Anita Leach, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	05/01/1984	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>2362</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/22/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		11/25/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	37	05/01/1984	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>2363</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/22/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		11/24/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	37	01/01/1984	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
<b>2364</b>	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/22/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		11/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Wheatland County in the City of Judith Gap**

**Location:** JUDITH GAP OIL  
 302 High St  
 Judith Gap, MT 59453-7703 Wheatland

Legacy ID:54-07616

**Facility ID:** 29605  
**Last Inspected On:** 02/01/2019  
**Operating Permit Renewal Date:** 05/08/2022

**Owner Operator Contact:** David Miller

**4066324891**

**Operator Contact:** Jeffery Miller

**Owner/Operator:** David Miller

David Miller, UST Class B Operator  
 Jeffery Miller, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	15	10/02/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5089</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		08/23/2006	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		11/18/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	15	10/02/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5090</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		08/23/2006	Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
5,000		11/16/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	15	10/02/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5091</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		08/23/2006	Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No

10,000		11/28/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	15	10/02/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5092</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		08/23/2006	Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
5,000		11/30/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
11	15	10/02/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5093</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		08/23/2006	Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		11/24/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
12	15	10/02/2006	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
<b>5094</b>	No		Double-Walled	Double Walled	Yes
Currently in Use		08/23/2006	Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
5,000		12/06/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Wheatland County in the City of Judith Gap**

**Location:** MALMSTROM AFB L 1  
US Hwy 191  
Judith Gap, MT 59453 Wheatland

Legacy ID:14-09096

**Facility ID:** 20331  
**Last Inspected On:** 04/25/2019  
**Operating Permit Renewal Date:** 07/31/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith

**4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

Candace Ellsworth, UST Class A Operator  
Candace Ellsworth, UST Class B Global Operator  
Curtis Hester, UST Class A Operator  
Curtis Hester, UST Class B Global Operator

William Smith, UST Class A Operator  
 William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	59	05/02/1962	Cathodically Protected Steel	Flexible Plastic	Flapper Valve;High Level Alarm
186	No	04/29/2016	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Impressed Current
Diesel		04/30/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Wheatland County in the City of Judith Gap**

**Location:** MALMSTROM AFB L 3  
 Road 297  
 Judith Gap, MT 59453 Wheatland

Legacy ID:54-09098

**Facility ID:** 29623  
**Last Inspected On:** 04/24/2019  
**Operating Permit Renewal Date:** 08/07/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator: 341 CES CEANQ**

Candace Ellsworth, UST Class A Operator  
 Candace Ellsworth, UST Class B Global Operator  
 Curtis Hester, UST Class A Operator  
 Curtis Hester, UST Class B Global Operator  
 William Smith, UST Class A Operator  
 William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

02	28	06/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>352</b>	No	06/28/2016	Double-Walled	Double Walled	Yes
Currently in Use		11/16/2016	Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Wheatland County in the City of Judith Gap**

**Location:** MALMSTROM AFB L 4  
Road 297  
Judith Gap, MT 59453 Wheatland

Legacy ID:54-09099

**Facility ID:** 29624  
**Last Inspected On:** 04/24/2019  
**Operating Permit Renewal Date:** 08/07/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	28	06/10/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
<b>353</b>	No	04/25/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Wheatland County in the City of Judith Gap**

**Location:** MALMSTROM AFB L 5  
Road 297  
Judith Gap, MT 59453 Wheatland

Legacy ID:54-09100

**Facility ID:** 29625  
**Last Inspected On:** 04/24/2019  
**Operating Permit Renewal Date:** 08/07/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

Candace Ellsworth, UST Class A Operator  
Candace Ellsworth, UST Class B Global Operator  
Curtis Hester, UST Class A Operator  
Curtis Hester, UST Class B Global Operator  
William Smith, UST Class A Operator  
William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
354	No	04/25/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Wheatland County in the City of Judith Gap**

**Location:** MALMSTROM AFB L 6  
Road 297  
Judith Gap, MT 59453 Wheatland

Legacy ID:54-09101

**Facility ID:** 29626  
**Last Inspected On:** 04/24/2019  
**Operating Permit Renewal Date:** 08/07/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

Candace Ellsworth, UST Class A Operator  
Candace Ellsworth, UST Class B Global Operator  
Curtis Hester, UST Class A Operator

Curtis Hester, UST Class B Global Operator  
 William Smith, UST Class A Operator  
 William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	31	03/26/1990	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
355	No	04/26/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Wheatland County in the City of Judith Gap**

**Location:** MALMSTROM AFB L 7  
 US Hwy 191  
 Judith Gap, MT 59453 Wheatland

Legacy ID:54-09102

**Facility ID:** 29627  
**Last Inspected On:** 04/24/2019  
**Operating Permit Renewal Date:** 08/07/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

Candace Ellsworth, UST Class A Operator  
 Candace Ellsworth, UST Class B Global Operator  
 Curtis Hester, UST Class A Operator  
 Curtis Hester, UST Class B Global Operator  
 William Smith, UST Class A Operator  
 William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery



Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	28	05/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
<b>356</b>	No	07/13/2016	Double-Walled	Double Walled	Yes
Currently in Use		11/16/2016	Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

**Facility Summary in Wheatland County in the City of Judith Gap**

**Location:** MALMSTROM AFB L 8  
US Hwy 191  
Judith Gap, MT 59453 Wheatland

Legacy ID:54-09103

**Facility ID:** 29628  
**Last Inspected On:** 04/25/2019  
**Operating Permit Renewal Date:** 08/07/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator: 341 CES CEANQ**

- Candace Ellsworth, UST Class A Operator
- Candace Ellsworth, UST Class B Global Operator
- Curtis Hester, UST Class A Operator
- Curtis Hester, UST Class B Global Operator
- William Smith, UST Class A Operator
- William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	28	05/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
<b>357</b>	No	04/26/2016	Double-Walled	Double Walled	Yes
Currently in Use		01/04/2016	Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Wheatland County in the City of Shawmut**

**Location:** MALMSTROM AFB K 5  
US Hwy 12  
Shawmut, MT 59078 Wheatland

Legacy ID:54-09089

**Facility ID:** 29616  
**Last Inspected On:** 04/19/2019  
**Operating Permit Renewal Date:** 07/31/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

Candace Ellsworth, UST Class A Operator  
Candace Ellsworth, UST Class B Global Operator  
Curtis Hester, UST Class A Operator  
Curtis Hester, UST Class B Global Operator  
William Smith, UST Class A Operator  
William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	28	06/09/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
345	No	04/14/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No

**Facility Summary in Wheatland County in the City of Shawmut**

**Location:** MALMSTROM AFB K 7  
US Hwy 12  
Shawmut, MT 59078 Wheatland

Legacy ID:54-09091

**Facility ID:** 29618  
**Last Inspected On:** 04/19/2019  
**Operating Permit Renewal Date:** 07/31/2022

**Owner Operator Contact:**

**Operator Contact:** Candace Ellsworth;Curtis Hester;William Smith      **4067316239;4067317128**

**Owner/Operator:** 341 CES CEANQ

Candace Ellsworth, UST Class A Operator

Candace Ellsworth, UST Class B Global Operator  
 Curtis Hester, UST Class A Operator  
 Curtis Hester, UST Class B Global Operator  
 William Smith, UST Class A Operator  
 William Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	28	06/01/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
<b>347</b>	No	04/13/2016	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350		No