

Facility Summary in Yellowstone County in the City of Ballantine

Location: TIGER TOWN  
2253 S 16th Rd  
Ballantine, MT 59006 Yellowstone

System Facility ID:56-06325

Facility Code: 30099  
Last Inspected On: 03/30/2023  
Operating Permit Renewal Date: 07/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Carol Hayes4069672753

Operator Contact: Carol Hayes4069672753

Owner/Operator: Carol Hayes

Carol Hayes, UST Class A Operator  
Patti Anderson, UST Class B Operator

Tank Code	10	Tank Age	32	Tank Installed Date	11/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3310	Spill Test Date	03/30/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	03/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date	03/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/30/2023			ATG Type	Incon/TS-1001				
Tank Code	11	Tank Age	32	Tank Installed Date	11/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3311	Spill Test Date	03/30/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	03/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/30/2023			ATG Type	Incon/TS-1001				
Tank Code	12	Tank Age	32	Tank Installed Date	11/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3312	Spill Test Date	03/30/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	03/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	5000	ATG Test Date	03/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/30/2023			ATG Type	Incon/TS-1001				

Facility Summary in Yellowstone County in the City of Billings

Location: 24TH STREET CENEX  
1031 N 24th St W  
Billings, MT 59102-3807 Yellowstone

System Facility ID:56-05750

Facility Code: 30057  
Last Inspected On: 11/19/2021  
Operating Permit Renewal Date: 02/05/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Quast Inc

Operator Contact: Teresa Bidleman 4066704290

Owner/Operator: Quast Inc

Teresa Bidleman, UST Class A Operator  
Teresa Bidleman, UST Class B Operator

Tank Code	01	Tank Age	40	Tank Installed Date	09/01/1984	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3720	Spill Test Date	04/14/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/14/2021	Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/14/2021	Line Tightness Test Date	03/01/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/14/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	40	Tank Installed Date	09/01/1984	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3721	Spill Test Date	04/14/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	04/14/2021	Tank/Piping CP Test Date	04/14/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	04/14/2021	Line Tightness Test Date	03/01/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/14/2021			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE CENTER 27TH ST  
702 S 27th St  
Billings, MT 59101-4510 Yellowstone

System Facility ID:56-10797

Facility Code: 30360  
Last Inspected On: 02/28/2022  
Operating Permit Renewal Date: 02/28/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Larry Grosulak;SNG Inc 34062450161

Operator Contact: Bergundi Grosulak;John Grosulak;Kelly Groslack;Larry Groslack4062450161;4062566246;4066702563;4066902993

Owner/Operator: Larry Grosulak

Owner/Operator: SNG Inc 3

- Bergundi Grosulak, UST Class A Operator
- Bergundi Grosulak, UST Class B Operator
- John Grosulak, UST Class A Operator
- John Grosulak, UST Class B Operator
- Kelly Groslack, UST Class A Operator
- Kelly Groslack, UST Class B Operator
- Larry Groslack, UST Class A Operator
- Larry Groslack, UST Class B Operator

Tank Code	04	Tank Age	26	Tank Installed Date	07/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4751	Spill Test Date	03/15/2021	Piping Installed Date	06/09/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	01/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/12/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	07/18/2008	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/15/2021			ATG Type	Veeder Root/TLS-300				
Tank Code	05	Tank Age	26	Tank Installed Date	07/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4752	Spill Test Date	03/15/2021	Piping Installed Date	06/09/2010	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date	01/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/12/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	07/18/2008	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/15/2021			ATG Type	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE CENTER 3  
730 Lake Elmo Dr  
Billings, MT 59105-3128 Yellowstone

Facility Code: 29689  
Last Inspected On: 08/04/2023  
System Facility ID:56-00063  
Operating Permit Renewal Date: 01/08/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: SNG Inc 34062450161

Operator Contact: Bergundi Grosulak;John Grosulak;Kelly Groslack;Larry Groslack4062450161;4062566246;4066702563;4066902993

Owner/Operator: SNG Inc 3

Bergundi Grosulak, UST Class A Operator  
Bergundi Grosulak, UST Class B Operator  
John Grosulak, UST Class A Operator  
John Grosulak, UST Class B Operator  
Kelly Groslack, UST Class A Operator  
Kelly Groslack, UST Class B Operator  
Larry Groslack, UST Class A Operator  
Larry Groslack, UST Class B Operator

Tank Code	01	Tank Age	40	Tank Installed Date	12/20/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1871	Spill Test Date	08/04/2023	Piping Installed Date	02/03/2000	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/04/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/04/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/04/2023	Line Tightness Test Date	08/04/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	40	Tank Installed Date	12/20/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1872	Spill Test Date	08/04/2023	Piping Installed Date	02/03/2000	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/04/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/04/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/04/2023	Line Tightness Test Date	08/04/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	40	Tank Installed Date	12/20/1984	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	1873	Spill Test Date	08/04/2023	Piping Installed Date	02/03/2000	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/04/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/04/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/04/2023	Line Tightness Test Date	08/04/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE CENTER E WICKS LANE  
1221 Wicks Ln  
Billings, MT 59105-4417 Yellowstone

System Facility ID:56-04957

Facility Code: 29954  
Last Inspected On: 04/19/2023  
Operating Permit Renewal Date: 09/12/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: SNG Inc 34062450161

Operator Contact: Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack4062450161;4062566246;4066702563;4066902993;4068508456

Owner/Operator: SNG Inc 3

- Bergundi Grosulak, UST Class A Operator
- Bergundi Grosulak, UST Class B Operator
- Daniel Grosulak, UST Class A Operator
- Daniel Grosulak, UST Class B Operator
- John Grosulak, UST Class A Operator
- John Grosulak, UST Class B Operator
- Kelly Groslack, UST Class A Operator
- Kelly Groslack, UST Class B Operator
- Larry Groslack, UST Class A Operator
- Larry Groslack, UST Class B Operator

Tank Code	03	Tank Age	10	Tank Installed Date	09/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5532	Spill Test Date		Piping Installed Date	12/17/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/17/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	12/17/2014	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-550 EVO				
Tank Code	04	Tank Age	10	Tank Installed Date	09/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5533	Spill Test Date		Piping Installed Date	12/17/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No



Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/17/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	12/17/2014	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-550 EVO				
Tank Code	05	Tank Age	10	Tank Installed Date	09/14/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5534	Spill Test Date		Piping Installed Date	12/17/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/17/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	12/17/2014	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Incon/TS-550 EVO				

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE CENTER STATE AVE  
4410 State Ave  
Billings, MT 59101-5060 Yellowstone

System Facility ID:56-04946

Facility Code: 29946  
Last Inspected On: 08/16/2022  
Operating Permit Renewal Date: 11/05/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: SNG Inc 34062450161

Operator Contact: Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack4062450161;4062566246;4066702563;4066902993;4068508456

Owner/Operator: SNG Inc 3

Bergundi Grosulak, UST Class A Operator  
Bergundi Grosulak, UST Class B Operator  
Daniel Grosulak, UST Class A Operator  
Daniel Grosulak, UST Class B Operator  
John Grosulak, UST Class A Operator  
John Grosulak, UST Class B Operator  
Kelly Groslack, UST Class A Operator  
Kelly Groslack, UST Class B Operator  
Larry Groslack, UST Class A Operator  
Larry Groslack, UST Class B Operator

Tank Code	03	Tank Age	11	Tank Installed Date	04/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5400	Spill Test Date	08/16/2022	Piping Installed Date	10/24/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/01/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	11	Tank Installed Date	04/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5401	Spill Test Date	08/16/2022	Piping Installed Date	10/24/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Report Created: 4/17/2024

Page [10] of [264]

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/01/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	11	Tank Installed Date	04/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5402	Spill Test Date	08/16/2022	Piping Installed Date	10/24/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/01/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/16/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Yellowstone County in the City of Billings

Location: 3 Gs CONVENIENCE STORE #5  
4106 State Ave  
Billings, MT 59101-3550 Yellowstone

Facility Code: 30055  
Last Inspected On: 08/03/2023  
System Facility ID:56-05748  
Operating Permit Renewal Date: 08/03/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: G & L Properties LLC4062450161

Operator Contact: Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack4062450161;4062566246;4066702563;4066902993;4068508456

Owner/Operator: G & L Properties LLC

- Bergundi Grosulak, UST Class A Operator
- Bergundi Grosulak, UST Class B Operator
- Daniel Grosulak, UST Class A Operator
- Daniel Grosulak, UST Class B Operator
- John Grosulak, UST Class A Operator
- John Grosulak, UST Class B Operator
- Kelly Groslack, UST Class A Operator
- Kelly Groslack, UST Class B Operator
- Larry Groslack, UST Class A Operator
- Larry Groslack, UST Class B Operator

Tank Code	03	Tank Age	22	Tank Installed Date	08/23/2002	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4714	Spill Test Date	08/03/2023	Piping Installed Date	05/13/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/03/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/03/2023	Tank/Piping CP Test Date	08/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	9000	ATG Test Date	08/03/2023	Line Tightness Test Date	11/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	22	Tank Installed Date	08/23/2002	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4715	Spill Test Date	08/03/2023	Piping Installed Date	05/13/2016	Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/03/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/03/2023	Tank/Piping CP Test Date	08/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	3000	ATG Test Date	08/03/2023	Line Tightness Test Date	11/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE STORE #6  
1425 US Hwy 87 E  
Billings, MT 59101-6657 Yellowstone

Facility Code: 30004  
Last Inspected On: 05/19/2023  
System Facility ID:56-05086  
Operating Permit Renewal Date: 11/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	G & L Properties LLC;Kelly Grosulak	4062450161
Operator Contact:	Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack	4062450161;4062566246;4066702563;4066902993;4068508456

Owner/Operator: G & L Properties LLC

Owner/Operator: Kelly Grosulak

- Bergundi Grosulak, UST Class A Operator
- Bergundi Grosulak, UST Class B Operator
- Daniel Grosulak, UST Class A Operator
- Daniel Grosulak, UST Class B Operator
- John Grosulak, UST Class A Operator
- John Grosulak, UST Class B Operator
- Kelly Groslack, UST Class A Operator
- Kelly Groslack, UST Class B Operator
- Larry Groslack, UST Class A Operator
- Larry Groslack, UST Class B Operator

Tank Code	04	Tank Age	7	Tank Installed Date	05/09/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5679	Spill Test Date	05/19/2023	Piping Installed Date	05/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/03/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/19/2023	Line Tightness Test Date	05/26/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1;ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/19/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	05	Tank Age	7	Tank Installed Date	05/09/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	5680	Spill Test Date	05/29/2023	Piping Installed Date	05/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/03/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/29/2023	Line Tightness Test Date	03/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/29/2023			ATG Type	Incon/TS-550 EVO				
Tank Code	06	Tank Age	7	Tank Installed Date	05/09/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5681	Spill Test Date	05/29/2023	Piping Installed Date	05/09/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/03/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/29/2023	Line Tightness Test Date	05/24/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/29/2023			ATG Type	Incon/TS-550 EVO				

Facility Summary in Yellowstone County in the City of Billings

Location: AIR TRAFFIC CONTROL TOWER  
1907 Terminal Cir  
Billings, MT 59105-1990 Yellowstone

System Facility ID:56-14127

Facility Code: 30768  
Last Inspected On: 07/28/2022  
Operating Permit Renewal Date: 10/21/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Federal Aviation Admin Billings

Operator Contact: Craig Fitzgerald;Evan Wolfe;Kevonte Daniels4065986855;4066576981;4066701577

Owner/Operator: Federal Aviation Admin Billings

- Craig Fitzgerald, UST Class A Operator
- Craig Fitzgerald, UST Class B Global Operator
- Evan Wolfe, UST Class A Operator
- Evan Wolfe, UST Class B Global Operator
- Kevonte Daniels, UST Class A Operator
- Kevonte Daniels, UST Class B Operator

Tank Code	01	Tank Age	20	Tank Installed Date	12/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4976	Spill Test Date	10/21/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/12/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/28/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



Facility Summary in Yellowstone County in the City of Billings

Location: ARCHIE COCHRANE MOTORS  
2133 King Ave W  
Billings, MT 59102-6420 Yellowstone

System Facility ID:56-00123

Facility Code: 29692  
Last Inspected On: 12/15/2023  
Operating Permit Renewal Date: 03/26/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Archie Cochrane Motors4066561100

Operator Contact: Chuck South

Owner/Operator: Archie Cochrane Motors

Chuck South, UST Class A Operator  
Chuck South, UST Class B Operator

Tank Code	04	Tank Age	31	Tank Installed Date	08/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	390	Spill Test Date	12/15/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/15/2023	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/15/2023			ATG Type					
Tank Code	05	Tank Age	31	Tank Installed Date	08/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	391	Spill Test Date	12/15/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/15/2023	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/15/2023			ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: AT AND T COMMUNICATIONS BILLINGS  
3011 2nd Ave N  
Billings, MT 59101-2028 Yellowstone

System Facility ID:56-05758

Facility Code: 30061  
Last Inspected On: 10/15/2021  
Operating Permit Renewal Date: 03/09/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: AT and T Communications Inc2144641469

Operator Contact: Daniel Donigian;David Klase;Gary Vantress;Gerald Eshbaugh;Philip Bunker;Richard Powell;Robert Pickens2147410476;4062085209;5094596211

Owner/Operator: AT and T Communications Inc

- Daniel Donigian, UST Class A Operator
- Daniel Donigian, UST Class B Global Operator
- David Klase, UST Class A Operator
- David Klase, UST Class B Operator
- Gary Vantress, UST Class A Operator
- Gary Vantress, UST Class B Operator
- Gerald Eshbaugh, UST Class A Operator
- Philip Bunker, UST Class A Operator
- Richard Powell, UST Class A Operator
- Robert Pickens, UST Class A Operator

Tank Code	03	Tank Age	30	Tank Installed Date	09/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	399	Spill Test Date	10/05/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/05/2021	Catastrophic L.D Type 3.0	Auto Dialer;Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	10/05/2021	Line Tightness Test Date	10/15/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	3-Year Line Tightness Test	Energy Act	No
		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: BEACON AIR GROUP  
1483 Aviation Place  
Billings, MT 59105 Yellowstone

System Facility ID:00-32567

Facility Code: 32567  
Last Inspected On: 04/05/2024  
Operating Permit Renewal Date: 07/29/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Beacon Air Group8007005107

Operator Contact:

Owner/Operator: Beacon Air Group

Tank Code	01	Tank Age	1	Tank Installed Date	10/11/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	6216	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/21/2023	Catastrophic L.D Type 3.0		Piping Type	U.S. Suction	CP Met Types	
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	30000	ATG Test Date	12/21/2023	Line Tightness Test Date	12/21/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/21/2023			ATG Type					
Tank Code	02	Tank Age	1	Tank Installed Date	10/11/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	6217	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/21/2023	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	12/21/2023	Line Tightness Test Date	12/21/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	12/21/2023			ATG Type					
Tank Code	03	Tank Age	1	Tank Installed Date	10/11/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	High Level Alarm

Tag Number	6218	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/21/2023	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	12/21/2023	Line Tightness Test Date	12/21/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	12/21/2023			ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS DIGITAL AIRPORT SURVEILLANCE RADAR  
1901 Terminal Cir  
Billings, MT 59105-1990 Yellowstone

System Facility ID:56-14077

Facility Code: 30729  
Last Inspected On: 12/18/2023  
Operating Permit Renewal Date: 03/26/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Federal Aviation Admin Billings

Operator Contact: Dennis Schuelka;Evan Wolfe;Paul Henley4062252711;4066701577;4068551891

Owner/Operator: Federal Aviation Admin Billings

Dennis Schuelka, UST Class A Operator  
Dennis Schuelka, UST Class B Operator  
Evan Wolfe, UST Class A Operator  
Evan Wolfe, UST Class B Global Operator  
Paul Henley, UST Class A Operator

Tank Code	01	Tank Age	22	Tank Installed Date	12/30/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4780	Spill Test Date	10/10/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/09/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1000	ATG Test Date	05/04/2023	Line Tightness Test Date	08/12/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/12/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 1  
2305 8th Ave N  
Billings, MT 59101-1018 Yellowstone

System Facility ID:56-09739

Facility Code: 30317  
Last Inspected On: 12/07/2023  
Operating Permit Renewal Date: 12/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Billings Fire Dept4066578423

Operator Contact: Froilan Valdez;Kevonte Daniels4065986855;4066578420

Owner/Operator: City of Billings Fire Dept

Froilan Valdez, UST Class A Operator  
Froilan Valdez, UST Class B Global Operator  
Kevonte Daniels, UST Class A Operator  
Kevonte Daniels, UST Class B Global Operator

Tank Code	03	Tank Age	31	Tank Installed Date	12/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	2728	Spill Test Date	12/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/07/2023	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1035	ATG Test Date	12/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	31	Tank Installed Date	12/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	High Level Alarm
Tag Number	2729	Spill Test Date	12/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	517	ATG Test Date	12/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	12/07/2023			ATG Type	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC				
--	--	--------------------	------------	--	--	----------	--	--	--	--	--

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 2  
501 S 28th St  
Billings, MT 59101-4143 Yellowstone

System Facility ID:56-09740

Facility Code: 30318  
Last Inspected On: 12/07/2023  
Operating Permit Renewal Date: 12/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Billings Fire Dept4066578423

Operator Contact: Froilan Valdez4066578420

Owner/Operator: City of Billings Fire Dept

Froilan Valdez, UST Class A Operator  
Froilan Valdez, UST Class B Global Operator

Tank Code	03	Tank Age	34	Tank Installed Date	06/12/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3699	Spill Test Date	12/07/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	12/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/07/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	04	Tank Age	34	Tank Installed Date	06/12/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3700	Spill Test Date	12/07/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date	12/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/07/2023			ATG Type	Gilbarco/EMC Basic				



Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 3  
1928 17th St W  
Billings, MT 59102-2907 Yellowstone

System Facility ID:56-09741

Facility Code: 30319  
Last Inspected On: 12/07/2023  
Operating Permit Renewal Date: 12/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Billings Fire Dept4066578423

Operator Contact: Froilan Valdez4066578420

Owner/Operator: City of Billings Fire Dept

Froilan Valdez, UST Class A Operator  
Froilan Valdez, UST Class B Global Operator

Tank Code	02	Tank Age	32	Tank Installed Date	03/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4297	Spill Test Date	12/07/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	500	ATG Test Date	12/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 5  
605 S 24th St W  
Billings, MT 59102-6246 Yellowstone

System Facility ID:56-09742

Facility Code: 30320  
Last Inspected On: 12/07/2023  
Operating Permit Renewal Date: 12/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Billings Fire Dept4066578423

Operator Contact: Froilan Valdez4066578420

Owner/Operator: City of Billings Fire Dept

Froilan Valdez, UST Class A Operator  
Froilan Valdez, UST Class B Global Operator

Tank Code	04	Tank Age	31	Tank Installed Date	01/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2731	Spill Test Date	12/07/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	517	ATG Test Date	12/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/07/2023			ATG Type	Gilbarco-Veeder Root/Other				
Tank Code	05	Tank Age	31	Tank Installed Date	01/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2732	Spill Test Date	12/07/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	517	ATG Test Date	12/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/07/2023			ATG Type	Gilbarco-Veeder Root/Other				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 6  
1601 St Andrews Dr  
Billings, MT 59105-3863 Yellowstone

System Facility ID:56-09743

Facility Code: 30321  
Last Inspected On: 12/07/2023  
Operating Permit Renewal Date: 12/07/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Billings Fire Dept4066578423

Operator Contact: Froilan Valdez4066578420

Owner/Operator: City of Billings Fire Dept

Froilan Valdez, UST Class A Operator  
Froilan Valdez, UST Class B Global Operator

Tank Code	01	Tank Age	37	Tank Installed Date	10/19/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2733	Spill Test Date	12/07/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/07/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	500	ATG Test Date	12/07/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS LOGAN INTERNATIONAL AIRPORT UST  
1901 Terminal Cir Ste 216  
Billings, MT 59105-1991 Yellowstone

System Facility ID:56-00909

Facility Code: 29743  
Last Inspected On: 06/27/2022  
Operating Permit Renewal Date: 09/04/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Billings Logan International Airport;Mick McCarthy	4066578483
Operator Contact:	Shawn Gaalswyk	4067945065

Owner/Operator: Billings Logan International Airport

Owner/Operator: Mick McCarthy

Colter Smith, UST Class B Operator  
Shawn Gaalswyk, UST Class A Operator  
Shawn Gaalswyk, UST Class B Operator

Tank Code	17	Tank Age	31	Tank Installed Date	10/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	4826	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	06/27/2022	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	500	ATG Test Date		Line Tightness Test Date	07/08/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	11	Tank Age	37	Tank Installed Date	01/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	623	Spill Test Date	06/27/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	06/27/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	06/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	31	Tank Installed Date	10/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	624	Spill Test Date	06/27/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/27/2022	Tank/Piping CP Test Date	06/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/27/2022	Line Tightness Test Date	06/27/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	13	Tank Age	31	Tank Installed Date	10/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	625	Spill Test Date	06/27/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/27/2022	Tank/Piping CP Test Date	06/27/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/27/2022	Line Tightness Test Date	06/01/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS METROPOLITAN TRANSIT  
1705 Monad Rd  
Billings, MT 59101-3234 Yellowstone

System Facility ID:56-09747

Facility Code: 30325  
Last Inspected On: 08/13/2021  
Operating Permit Renewal Date: 12/18/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Billings MET Transit

Operator Contact: John Bishop;Josh Smith;Billings Metropolitan Transit;Lindsay Gran;Rusty Logan 4066578218;4066578219

Owner/Operator: City of Billings MET Transit

John Bishop, UST Class A Operator  
Josh Smith, UST Class A Operator  
Josh Smith, UST Class B Operator  
Lindsay Gran, UST Class A Operator  
Rick Pirami, UST Class B Operator  
Rusty Logan, UST Class A Operator

Tank Code	04	Tank Age	21	Tank Installed Date	09/03/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4862	Spill Test Date	08/13/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/27/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/13/2021	Line Tightness Test Date	08/27/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/13/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	21	Tank Installed Date	09/03/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4863	Spill Test Date	08/13/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/27/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	8000	ATG Test Date	08/13/2021	Line Tightness Test Date	08/27/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/13/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	41	Tank Installed Date	10/15/1983	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	635	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Galvanic
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	08/13/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2000	ATG Test Date	08/13/2021	Line Tightness Test Date	08/13/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS REGIONAL LANDFILL  
5240 Jellison Rd  
Billings, MT 59101 Yellowstone

System Facility ID:56-09744

Facility Code: 30322  
Last Inspected On: 07/01/2021  
Operating Permit Renewal Date: 07/01/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Billings Solid Waste Division

Operator Contact: Margaret Pegues 4062478633

Owner/Operator: City of Billings Solid Waste Division

Margaret Pegues, UST Class A Operator  
Margaret Pegues, UST Class B Operator

Tank Code	01	Tank Age	38	Tank Installed Date	10/01/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	630	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	09/04/2018	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/01/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				



Facility Summary in Yellowstone County in the City of Billings

Location: BROADWATER QUICK STOP  
942 Broadwater Ave  
Billings, MT 59101 Yellowstone

System Facility ID:56-08671

Facility Code: 30281  
Last Inspected On: 11/10/2023  
Operating Permit Renewal Date: 11/10/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Bill Grinsell4067402686

Operator Contact: Shay Grinsell4067400978

Owner/Operator: Bill Grinsell

Bill Grinsell, UST Class B Operator  
Shay Grinsell, UST Class A Operator  
Shay Grinsell, UST Class B Operator

Tank Code	04	Tank Age	31	Tank Installed Date	12/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3169	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/28/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/27/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	10/25/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/27/2023			ATG Type					
Tank Code	05	Tank Age	31	Tank Installed Date	12/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3170	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/28/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/27/2023	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	10/25/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/27/2023			ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: CARDLOCK #2  
3520 1st Ave S  
Billings, MT 59101 Yellowstone

System Facility ID:56-08324

Facility Code: 30262  
Last Inspected On: 07/29/2022  
Operating Permit Renewal Date: 12/24/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: GM Petroleum Distributing Inc4066611112

Operator Contact: Bill Grunstead;Jay Brookie;Laura Geffre;Roger Schmechel4062083147;4062524661

Owner/Operator: GM Petroleum Distributing Inc

Bill Grunstead, UST Class A Operator  
Jay Brookie, UST Class A Operator  
Jay Brookie, UST Class B Global Operator  
Laura Geffre, UST Class A Operator  
Laura Geffre, UST Class B Operator  
Roger Schmechel, UST Class A Operator  
Roger Schmechel, UST Class B Operator

Tank Code	01	Tank Age	46	Tank Installed Date	05/06/1978	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1179	Spill Test Date	07/18/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/18/2022	Tank/Piping CP Test Date	07/18/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/18/2022	Line Tightness Test Date	03/21/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	46	Tank Installed Date	05/06/1978	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1180	Spill Test Date	07/18/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/18/2022	Tank/Piping CP Test Date	07/18/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	8000	ATG Test Date	07/18/2022	Line Tightness Test Date	03/24/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	46	Tank Installed Date	05/06/1978	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1181	Spill Test Date	07/18/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/18/2022	Tank/Piping CP Test Date	07/18/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/18/2022	Line Tightness Test Date	03/21/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: CASEY'S CORNER 10  
3443 Central Ave  
Billings, MT 59102 Yellowstone

System Facility ID:56-05085

Facility Code: 30003  
Last Inspected On: 03/10/2022  
Operating Permit Renewal Date: 06/14/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc7018521194

Operator Contact: Nancy Coen7204212140

Owner/Operator: Superpumper Inc

Nancy Coen, UST Class A Operator

Nancy Coen, UST Class B Operator

Tank Code	06	Tank Age	29	Tank Installed Date	05/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2007	Spill Test Date	01/17/2023	Piping Installed Date	05/06/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/31/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/11/2021	Tank/Piping CP Test Date	03/10/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/11/2021	Line Tightness Test Date	01/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/11/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	08	Tank Age	29	Tank Installed Date	05/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2009	Spill Test Date	08/11/2021	Piping Installed Date	05/06/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/31/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/11/2021	Tank/Piping CP Test Date	03/10/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/11/2021	Line Tightness Test Date	01/17/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/11/2021			ATG Type	Veeder Root/TLS-450				
Tank Code	07	Tank Age	29	Tank Installed Date	05/01/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	4473	Spill Test Date	08/11/2021	Piping Installed Date	05/06/2014	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/31/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/11/2021	Tank/Piping CP Test Date	03/10/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/11/2021	Line Tightness Test Date	02/14/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	08/11/2021			ATG Type	Veeder Root/TLS-450				

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS CORNER 11  
2347 Main St  
Billings, MT 59105-4023 Yellowstone

Facility Code: 30118  
Last Inspected On: 01/25/2023  
System Facility ID:56-06593  
Operating Permit Renewal Date: 04/25/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc7018521194

Operator Contact: Brit Miller;Calvin Wilson;Nancy Coen4062520166;7204212140

Owner/Operator: Superpumper Inc

- Bill Bonner, UST Class B Operator
- Brit Miller, UST Class A Operator
- Calvin Wilson, UST Class A Operator
- Calvin Wilson, UST Class B Global Operator
- Dawn Jones, UST Class B Global Operator
- Nancy Coen, UST Class A Operator
- Nancy Coen, UST Class B Operator
- Randy Lowe, UST Class B Operator

Tank Code	01	Tank Age	43	Tank Installed Date	10/01/1981	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	459	Spill Test Date	03/24/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	01/24/2020	Tank/Piping CP Test Date	01/24/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	10/14/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	43	Tank Installed Date	10/01/1981	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	460	Spill Test Date	03/24/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	01/24/2020	Tank/Piping CP Test Date	01/24/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date		Line Tightness Test Date	10/15/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	43	Tank Installed Date	10/01/1981	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	461	Spill Test Date	03/24/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	01/24/2020	Tank/Piping CP Test Date	01/24/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	10/14/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	2	Tank Installed Date	10/21/2022	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6138	Spill Test Date	10/21/2022	Piping Installed Date	10/21/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/21/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/21/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	10/21/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/21/2022			ATG Type					
Tank Code	05	Tank Age	2	Tank Installed Date	10/21/2022	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6139	Spill Test Date	10/21/2022	Piping Installed Date	10/21/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/21/2022	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/21/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	Yes
Capacity	10000	ATG Test Date	10/21/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	10/21/2022			ATG Type					
Tank Code	06	Tank Age	0	Tank Installed Date		Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6140	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type					



Facility Summary in Yellowstone County in the City of Billings

Location: CASEY'S CORNER 12  
5550 US Hwy 312  
Billings, MT 59105-4944 Yellowstone

System Facility ID:56-00062

Facility Code: 29688  
Last Inspected On: 08/12/2022  
Operating Permit Renewal Date: 11/28/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc7018521194

Operator Contact: Justin Franjevic;Nancy Coen4068551749;7204212140

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator  
Nancy Coen, UST Class A Operator  
Renee Beck, UST Class B Global Operator

Tank Code	04	Tank Age	8	Tank Installed Date	06/30/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5653	Spill Test Date	08/12/2022	Piping Installed Date	06/30/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/17/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/17/2021	Line Tightness Test Date	07/14/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	8	Tank Installed Date	06/30/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5654	Spill Test Date	08/12/2022	Piping Installed Date	06/30/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/17/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/17/2021	Line Tightness Test Date	07/10/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	08/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	8	Tank Installed Date	06/30/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5655	Spill Test Date	08/12/2022	Piping Installed Date	06/30/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/17/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/17/2021	Line Tightness Test Date	07/12/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	8	Tank Installed Date	06/30/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5656	Spill Test Date	08/12/2022	Piping Installed Date	06/30/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	12/17/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	12/17/2021	Line Tightness Test Date	07/10/2019	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS CORNER 7  
2007 Blue Creek Rd  
Billings, MT 59101 Yellowstone

System Facility ID:56-06595

Facility Code: 30120  
Last Inspected On: 06/16/2023  
Operating Permit Renewal Date: 06/16/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc7018521194

Operator Contact: Calvin Wilson;Jason Shanley;Nancy Coen7204212140

Owner/Operator: Superpumper Inc

- Amber Olson, UST Class B Operator
- Calvin Wilson, UST Class A Operator
- Calvin Wilson, UST Class B Global Operator
- Irene Matzen, UST Class B Operator
- Jason Shanley, UST Class A Operator
- Jason Shanley, UST Class B Operator
- Kelly Shutes, UST Class B Global Operator
- Melanie Sims, UST Class B Operator
- Nancy Coen, UST Class A Operator
- Nancy Coen, UST Class B Operator

Tank Code	03	Tank Age	32	Tank Installed Date	11/02/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	466	Spill Test Date	05/30/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/10/2023	Line Tightness Test Date	08/10/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/04/2023			ATG Type	Veeder Root/TLS-300				
Tank Code	04	Tank Age	32	Tank Installed Date	11/02/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	467	Spill Test Date	05/30/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/10/2023	Line Tightness Test Date	08/04/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/10/2022			ATG Type	Veeder Root/TLS-350				
Tank Code	05	Tank Age	32	Tank Installed Date	11/02/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	468	Spill Test Date	05/30/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/30/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/10/2023	Line Tightness Test Date	08/04/2023	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/04/2023			ATG Type	Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: CASEY'S CORNER 8  
2816 Old Hardin Rd  
Billings, MT 59101 Yellowstone

System Facility ID:56-06594

Facility Code: 30119  
Last Inspected On: 09/22/2023  
Operating Permit Renewal Date: 02/28/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc7018521194

Operator Contact: Calvin Wilson;Jason Shanley;Nancy Coen7204212140

Owner/Operator: Superpumper Inc

- Andrew McLellan, UST Class B Operator
- Ann LeVeque, UST Class B Operator
- Calvin Wilson, UST Class A Operator
- Calvin Wilson, UST Class B Global Operator
- Chuck Crane, UST Class B Operator
- Jason Shanley, UST Class A Operator
- Jason Shanley, UST Class B Operator
- Kelly Shutes, UST Class B Global Operator
- Nancy Coen, UST Class A Operator
- Nancy Coen, UST Class B Operator
- Steve Willden, UST Class B Operator

Tank Code	04	Tank Age	26	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	462	Spill Test Date	09/22/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/04/2023	Tank/Piping CP Test Date	08/25/2011	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	26	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm

Tag Number	463	Spill Test Date	09/22/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/04/2023	Tank/Piping CP Test Date	08/25/2011	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	26	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	464	Spill Test Date	09/22/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/04/2023	Tank/Piping CP Test Date	08/25/2011	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	26	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	465	Spill Test Date	09/22/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/04/2023	Tank/Piping CP Test Date	08/25/2011	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: CENTRAL TRANSPORT  
6200 S Frontage Road  
Billings, MT 59101 Yellowstone

System Facility ID:00-32500

Facility Code: 32500  
Last Inspected On: 01/05/2023  
Operating Permit Renewal Date: 04/01/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Crown Enterprises5864671711

Operator Contact: Arin Jensen

Owner/Operator: Crown Enterprises

Arin Jensen, UST Class A Operator  
Arin Jensen, UST Class B Operator

Tank Code	01	Tank Age	2	Tank Installed Date	09/01/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6097	Spill Test Date	08/16/2022	Piping Installed Date	09/01/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/15/2022	Sump Tightness Test Date	08/16/2022	Catastrophic L.D Type 3.0	Auto Dialer;Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	09/15/2022	Line Tightness Test Date	09/15/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/15/2022			ATG Type					
Tank Code	02	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6098	Spill Test Date	08/16/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/16/2022	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	09/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/15/2022			ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746087  
4041 Grand Ave  
Billings, MT 59106-1731 Yellowstone

Facility Code: 30457  
Last Inspected On: 02/22/2022  
System Facility ID:56-13723  
Operating Permit Renewal Date: 05/23/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Rocky Mountain Oil LLC	6027288000
Operator Contact:	Chuck Nyberg;Kegan Krueger;Patrick Patnaude;Stephen Reckinger;Valeria Jeffries;Veronica Rivera	4063210938;9528308028;9528308721;9528308722

Owner/Operator: Rocky Mountain Oil LLC

Brad Lee, UST Class B Global Operator  
Chuck Nyberg, UST Class A Operator  
Greg Hoffman, UST Class B Operator  
Jeff Reed, UST Class B Global Operator  
Kegan Krueger, UST Class A Operator  
Patrick Patnaude, UST Class A Operator  
Stephen Reckinger, UST Class A Operator  
Valeria Jeffries, UST Class A Operator  
Veronica Rivera, UST Class A Operator  
Veronica Rivera, UST Class B Global Operator

Tank Code	01	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3062	Spill Test Date	08/27/2021	Piping Installed Date	11/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/18/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/27/2021	Tank/Piping CP Test Date	07/11/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	08/27/2021	Line Tightness Test Date	11/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3063	Spill Test Date	08/27/2021	Piping Installed Date	11/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No



Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/18/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/27/2021	Tank/Piping CP Test Date	07/11/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	08/27/2021	Line Tightness Test Date	11/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3064	Spill Test Date	08/27/2021	Piping Installed Date	11/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/18/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/27/2021	Tank/Piping CP Test Date	07/11/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	08/27/2021	Line Tightness Test Date	11/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3065	Spill Test Date	08/27/2021	Piping Installed Date	11/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/18/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/27/2021	Tank/Piping CP Test Date	07/11/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	08/27/2021	Line Tightness Test Date	11/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	28	Tank Installed Date	06/01/1996	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3066	Spill Test Date	08/27/2021	Piping Installed Date	11/18/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/18/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/27/2021	Tank/Piping CP Test Date	07/11/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	8000	ATG Test Date	08/27/2021	Line Tightness Test Date	11/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746108  
790 S Billings Blvd  
Billings, MT 59101-4709 Yellowstone

System Facility ID:56-13994

Facility Code: 30655  
Last Inspected On: 09/29/2022  
Operating Permit Renewal Date: 02/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC	6027288000
Operator Contact: Veronica Rivera	

Owner/Operator: Rocky Mountain Oil LLC

Courtney Sheriff, UST Class B Global Operator  
Jeff Reed, UST Class B Global Operator  
Veronica Rivera, UST Class A Operator  
Veronica Rivera, UST Class B Global Operator

Tank Code	01	Tank Age	23	Tank Installed Date	05/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4285	Spill Test Date	10/25/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	12/03/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/03/2021	Line Tightness Test Date	08/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	23	Tank Installed Date	05/04/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4286	Spill Test Date	03/16/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/03/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	12/03/2021	Line Tightness Test Date	02/28/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	23	Tank Installed Date	05/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4287	Spill Test Date	11/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/03/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	12/03/2021	Line Tightness Test Date	08/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	23	Tank Installed Date	05/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4288	Spill Test Date	10/25/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	12/03/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	12/03/2021	Line Tightness Test Date	06/22/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	1	Tank Installed Date	11/09/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6226	Spill Test Date	04/03/2024	Piping Installed Date	11/09/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/03/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	04/03/2024	Line Tightness Test Date	04/03/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/03/2024			ATG Type					
Tank Code	07	Tank Age	1	Tank Installed Date	11/09/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6227	Spill Test Date		Piping Installed Date	11/09/2023	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No

Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746266  
745 Grand Ave  
Billings, MT 59101 Yellowstone

System Facility ID:56-08058

Facility Code: 30210  
Last Inspected On: 02/22/2022  
Operating Permit Renewal Date: 05/23/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC6027288000

Operator Contact: Veronica Rivera

Owner/Operator: Rocky Mountain Oil LLC

Beth Podkowa, UST Class B Global Operator  
Jeff Reed, UST Class B Global Operator  
Veronica Rivera, UST Class A Operator

Tank Code	05	Tank Age	29	Tank Installed Date	06/08/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3036	Spill Test Date	12/08/2021	Piping Installed Date	03/13/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/14/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	07/29/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	05/13/2021	Line Tightness Test Date	02/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	29	Tank Installed Date	06/08/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3037	Spill Test Date	05/13/2021	Piping Installed Date	03/13/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/14/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	07/29/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	05/13/2021	Line Tightness Test Date	12/02/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	12/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	29	Tank Installed Date	06/08/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3038	Spill Test Date	05/13/2021	Piping Installed Date	03/13/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/14/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	07/29/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	05/13/2021	Line Tightness Test Date	02/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	29	Tank Installed Date	06/08/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3039	Spill Test Date	05/13/2021	Piping Installed Date	03/13/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/14/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/13/2021	Tank/Piping CP Test Date	07/29/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/13/2021	Line Tightness Test Date	02/02/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	12/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746274  
2620 6th Ave N  
Billings, MT 59101 Yellowstone

System Facility ID:56-08062

Facility Code: 30211  
Last Inspected On: 06/02/2022  
Operating Permit Renewal Date: 04/15/2019

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC6027288000

Operator Contact: Veronica Rivera

Owner/Operator: Rocky Mountain Oil LLC

Jeff Reed, UST Class B Global Operator  
Jolene Edmisten, UST Class B Operator  
Veronica Rivera, UST Class A Operator  
Veronica Rivera, UST Class B Global Operator

Tank Code	01	Tank Age	58	Tank Installed Date	05/01/1966	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.1	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	28000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	04	Tank Age	29	Tank Installed Date	10/01/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3040	Spill Test Date	05/12/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date	05/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	05/16/2022	Line Tightness Test Date	12/06/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



Tank Code	06	Tank Age	29	Tank Installed Date	10/01/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3042	Spill Test Date	05/12/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date	05/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	05/16/2022	Line Tightness Test Date	01/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	29	Tank Installed Date	10/01/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4399	Spill Test Date	05/12/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date	05/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	05/16/2022	Line Tightness Test Date	12/22/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746275  
105 Broadwater Ave  
Billings, MT 59101 Yellowstone

System Facility ID:56-08063

Facility Code: 30212  
Last Inspected On: 06/14/2023  
Operating Permit Renewal Date: 11/06/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC6027288000

Operator Contact: Chuck Nyberg;Kegan Krueger;Lisa Pedersen;Patrick Patnaude;Valeria Jeffries;Veronica Rivera;Holiday Stationstore 2754063210938;6128308891;9528308721;9528308722

Owner/Operator: Rocky Mountain Oil LLC

- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Jeff Reed, UST Class B Global Operator
- Kegan Krueger, UST Class A Operator
- Lisa Pedersen, UST Class A Operator
- Lisa Pedersen, UST Class B Operator
- Patrick Patnaude, UST Class A Operator
- Valeria Jeffries, UST Class A Operator
- Veronica Rivera, UST Class A Operator
- Veronica Rivera, UST Class B Global Operator
- Veronica Rivera, UST Class B Operator

Tank Code	05	Tank Age	29	Tank Installed Date	07/13/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3043	Spill Test Date	01/30/2024	Piping Installed Date	03/12/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date	06/28/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	05/31/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	29	Tank Installed Date	07/13/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3044	Spill Test Date	01/30/2024	Piping Installed Date	03/12/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date	06/28/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	05/31/2023	Line Tightness Test Date	02/17/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	29	Tank Installed Date	07/13/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3045	Spill Test Date	02/16/2024	Piping Installed Date	03/12/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date	06/28/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	05/31/2023	Line Tightness Test Date	03/16/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	29	Tank Installed Date	07/13/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3046	Spill Test Date	02/16/2024	Piping Installed Date	03/12/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date	06/28/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	05/31/2023	Line Tightness Test Date	03/16/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	29	Tank Installed Date	07/13/1995	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3047	Spill Test Date	02/16/2024	Piping Installed Date	03/12/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/12/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/31/2023	Tank/Piping CP Test Date	06/28/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	8000	ATG Test Date	05/31/2023	Line Tightness Test Date	01/14/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	05/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746280  
1020 Main St  
Billings, MT 59105-2544 Yellowstone

Facility Code: 30314  
Last Inspected On: 11/10/2022  
System Facility ID:56-09695  
Operating Permit Renewal Date: 11/28/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC6027288000

Operator Contact: Chuck Nyberg;Patrick Patnaude;Valeria Jeffries;Veronica Rivera9528308721;9528308722

Owner/Operator: Rocky Mountain Oil LLC

Brad Lee, UST Class B Global Operator  
Chuck Nyberg, UST Class A Operator  
Jeff Reed, UST Class B Global Operator  
Patrick Patnaude, UST Class A Operator  
Valeria Jeffries, UST Class A Operator  
Veronica Rivera, UST Class A Operator  
Veronica Rivera, UST Class B Global Operator

Tank Code	01	Tank Age	37	Tank Installed Date	04/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3048	Spill Test Date	07/02/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/03/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/07/2022	Tank/Piping CP Test Date	07/28/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	07/07/2022	Line Tightness Test Date	08/24/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/29/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	37	Tank Installed Date	04/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3049	Spill Test Date	07/02/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/03/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/07/2022	Tank/Piping CP Test Date	07/28/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes

Capacity	12000	ATG Test Date	07/07/2022	Line Tightness Test Date	05/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/29/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	37	Tank Installed Date	04/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3050	Spill Test Date	12/08/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/03/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/07/2022	Tank/Piping CP Test Date	07/28/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	07/07/2022	Line Tightness Test Date	08/15/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/29/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	37	Tank Installed Date	04/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3051	Spill Test Date	07/02/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/03/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/07/2022	Tank/Piping CP Test Date	07/28/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/07/2022	Line Tightness Test Date	08/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/29/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746284  
3226 Rosebud Dr  
Billings, MT 59102-6017 Yellowstone

System Facility ID:56-09752

Facility Code: 30326  
Last Inspected On: 02/09/2023  
Operating Permit Renewal Date: 05/30/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC	6027288000
Operator Contact: Valeria Jeffries;Veronica Rivera	

Owner/Operator: Rocky Mountain Oil LLC

Brad Lee, UST Class B Global Operator  
Jeff Reed, UST Class B Global Operator  
Teddi Matzen, UST Class B Operator  
Valeria Jeffries, UST Class A Operator  
Veronica Rivera, UST Class A Operator  
Veronica Rivera, UST Class B Operator

Tank Code	01	Tank Age	41	Tank Installed Date	11/05/1983	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3052	Spill Test Date	11/10/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/02/2022	Tank/Piping CP Test Date	06/25/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	06/02/2022	Line Tightness Test Date	08/23/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	06/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	41	Tank Installed Date	11/05/1983	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3053	Spill Test Date	11/10/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/02/2022	Tank/Piping CP Test Date	06/25/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	10000	ATG Test Date	06/02/2022	Line Tightness Test Date	07/10/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No

		Overfill Test Date	06/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	41	Tank Installed Date	11/05/1983	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	3054	Spill Test Date	11/10/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/02/2022	Tank/Piping CP Test Date	06/25/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	6000	ATG Test Date	06/02/2022	Line Tightness Test Date	08/05/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	06/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746285  
785 S 20th St W  
Billings, MT 59102-6463 Yellowstone

System Facility ID:56-09753

Facility Code: 30327  
Last Inspected On: 09/28/2023  
Operating Permit Renewal Date: 09/28/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC6027288000

Operator Contact: Veronica Rivera

Owner/Operator: Rocky Mountain Oil LLC

Jeff Reed, UST Class B Global Operator  
Leonard Slemper, UST Class B Global Operator  
Veronica Rivera, UST Class A Operator

Tank Code	05	Tank Age	27	Tank Installed Date	04/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3055	Spill Test Date	09/28/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	09/28/2023	Tank/Piping CP Test Date	09/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	09/28/2023	Line Tightness Test Date	05/15/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	27	Tank Installed Date	04/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3056	Spill Test Date	09/28/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	09/28/2023	Tank/Piping CP Test Date	09/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	09/28/2023	Line Tightness Test Date	05/15/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	27	Tank Installed Date	04/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3057	Spill Test Date	09/28/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	09/28/2023	Tank/Piping CP Test Date	09/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	09/28/2023	Line Tightness Test Date	03/12/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	27	Tank Installed Date	04/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3058	Spill Test Date	03/29/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	09/28/2023	Tank/Piping CP Test Date	09/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	09/28/2023	Line Tightness Test Date	03/28/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	27	Tank Installed Date	04/01/1997	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;High Level Alarm
Tag Number	3059	Spill Test Date	09/28/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	09/28/2023	Tank/Piping CP Test Date	09/28/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	09/28/2023	Line Tightness Test Date	03/28/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/28/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746385  
3551 Ember Ln  
Billings, MT 59102 Yellowstone

System Facility ID:60-15065

Facility Code: 30837  
Last Inspected On: 12/26/2022  
Operating Permit Renewal Date: 05/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Rocky Mountain Oil LLC	6027288000
Operator Contact:	Patrick Patnaude;Valeria Jeffries;Veronica Rivera	9528308721

Owner/Operator: Rocky Mountain Oil LLC

Jeff Luedtke, UST Class B Global Operator  
Jeff Reed, UST Class B Global Operator  
Patrick Patnaude, UST Class A Operator  
Valeria Jeffries, UST Class A Operator  
Veronica Rivera, UST Class A Operator  
Veronica Rivera, UST Class B Global Operator

Tank Code	01	Tank Age	17	Tank Installed Date	12/11/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5139	Spill Test Date	05/13/2021	Piping Installed Date	07/12/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	20000	ATG Test Date	05/16/2022	Line Tightness Test Date	11/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	17	Tank Installed Date	12/11/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5140	Spill Test Date	05/13/2021	Piping Installed Date	07/12/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes

Capacity	12000	ATG Test Date	05/16/2022	Line Tightness Test Date	10/22/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	17	Tank Installed Date	12/11/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5141	Spill Test Date	05/13/2021	Piping Installed Date	07/12/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	05/16/2022	Line Tightness Test Date	10/24/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	17	Tank Installed Date	12/11/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5142	Spill Test Date	05/13/2021	Piping Installed Date	07/12/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/16/2022	Line Tightness Test Date	10/29/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	17	Tank Installed Date	12/11/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5143	Spill Test Date	05/13/2021	Piping Installed Date	07/12/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/16/2022	Line Tightness Test Date	10/29/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	05/16/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6237	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Under Construction	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	07	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6238	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction		AST	No
Tank Status	Under Construction	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746470  
1212 Mullooney Ln  
Billings, MT 59102 Yellowstone

System Facility ID:60-15327

Facility Code: 31023  
Last Inspected On: 09/23/2022  
Operating Permit Renewal Date: 12/17/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC6027288000

Operator Contact: Chuck Nyberg;Veronica Rivera9528308722

Owner/Operator: Rocky Mountain Oil LLC

Chuck Nyberg, UST Class A Operator  
Teddi Matzen, UST Class B Global Operator  
Veronica Rivera, UST Class A Operator  
Veronica Rivera, UST Class B Global Operator

Tank Code	01	Tank Age	6	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5880	Spill Test Date	08/05/2021	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/05/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/04/2022	Line Tightness Test Date	07/28/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/19/2022			ATG Type	Incon/TS-550 EVO				
Tank Code	02	Tank Age	6	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5881	Spill Test Date	08/05/2021	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/05/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/04/2022	Line Tightness Test Date	07/28/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/19/2022			ATG Type	Incon/TS-550 EVO				

Tank Code	03	Tank Age	6	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5882	Spill Test Date	08/05/2021	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/05/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/04/2022	Line Tightness Test Date	07/28/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/19/2022			ATG Type	Incon/TS-550 EVO				
Tank Code	04	Tank Age	6	Tank Installed Date	11/15/2018	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5883	Spill Test Date	08/05/2021	Piping Installed Date	11/15/2018	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/05/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/04/2022	Line Tightness Test Date	07/28/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/19/2022			ATG Type	Incon/TS-550 EVO				

Facility Summary in Yellowstone County in the City of Billings

Location: CIRCLE K STORE 2746731  
1280 Grand Ave  
Billings, MT 59102 Yellowstone

Facility Code: 30741  
Last Inspected On: 06/18/2021  
System Facility ID:56-14090  
Operating Permit Renewal Date: 10/01/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocky Mountain Oil LLC6027288000

Operator Contact: Chuck Nyberg;Patrick Patnaude;Valeria Jeffries;Veronica Rivera9528308721;9528308722

Owner/Operator: Rocky Mountain Oil LLC

- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Jeff Reed, UST Class B Global Operator
- Patrick Patnaude, UST Class A Operator
- Valeria Jeffries, UST Class A Operator
- Veronica Rivera, UST Class A Operator
- Veronica Rivera, UST Class B Global Operator

Tank Code	01	Tank Age	21	Tank Installed Date	06/24/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4844	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/18/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	02/16/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	21	Tank Installed Date	06/24/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4845	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/18/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No



Capacity	10000	ATG Test Date		Line Tightness Test Date	02/16/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	21	Tank Installed Date	06/24/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4846	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/18/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	02/07/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CITY OF BILLINGS OPERATION CENTER  
4848 Midland Rd  
Billings, MT 59101 Yellowstone

System Facility ID:56-14118

Facility Code: 30759  
Last Inspected On: 07/08/2022  
Operating Permit Renewal Date: 12/10/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	City of Billings Operation Center	4066578216
Operator Contact:	Corey Leonhardt;Mark Balter;Nick Westburg	

Owner/Operator: City of Billings Operation Center

Corey Leonhardt, UST Class A Operator  
Corey Leonhardt, UST Class B Global Operator  
Mark Balter, UST Class A Operator  
Nick Westburg, UST Class A Operator  
Nick Westburg, UST Class B Operator

Tank Code	01	Tank Age	20	Tank Installed Date	07/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4935	Spill Test Date	07/08/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/08/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/08/2022	Line Tightness Test Date	01/21/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	20	Tank Installed Date	07/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4936	Spill Test Date	07/08/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date	07/08/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/08/2022	Line Tightness Test Date	01/25/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	20	Tank Installed Date	07/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4937	Spill Test Date	07/08/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/08/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/08/2022	Line Tightness Test Date	01/15/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	20	Tank Installed Date	07/09/2004	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4938	Spill Test Date	07/08/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/08/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/08/2022	Line Tightness Test Date	01/13/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CITY OF BILLINGS PUBLIC WORKS DEPARTMENT  
2251 Belknap Ave  
Billings, MT 59101-5706 Yellowstone

System Facility ID:56-09746

Facility Code: 30324  
Last Inspected On: 12/08/2023  
Operating Permit Renewal Date: 03/14/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City of Billings Public Works

Operator Contact: Amanda Skewis;Scott Emerick4066578345

Owner/Operator: City of Billings Public Works

- Amanda Skewis, UST Class A Operator
- Amanda Skewis, UST Class B Operator
- Misty Gran, UST Class B Operator
- Scott Emerick, UST Class A Operator
- Scott Emerick, UST Class B Operator

Tank Code	04	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	631	Spill Test Date	12/08/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/08/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	10/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/08/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	34	Tank Installed Date	01/01/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	632	Spill Test Date	12/08/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/08/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	10/06/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/08/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: CITY SERVICE VALCON CARDLOCK 3  
1004 4th Ave N  
Billings, MT 59101 Yellowstone

System Facility ID:56-01290

Facility Code: 29764  
Last Inspected On: 06/03/2022  
Operating Permit Renewal Date: 08/16/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: W G Properties LLC

Operator Contact: Roger Schmechel 4062083147

Owner/Operator: W G Properties LLC

Roger Schmechel, UST Class A Operator  
Roger Schmechel, UST Class B Global Operator

Tank Code	D-1	Tank Age	48	Tank Installed Date	02/04/1976	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	752	Spill Test Date	06/03/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/08/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date	06/03/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	D-2	Tank Age	48	Tank Installed Date	01/01/1976	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	753	Spill Test Date	06/03/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/16/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	05/27/2022	Tank/Piping CP Test Date	07/08/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/03/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	07/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	D-3	Tank Age	48	Tank Installed Date	02/04/1976	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	754	Spill Test Date	06/03/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/16/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/27/2022	Tank/Piping CP Test Date	07/08/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/03/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	D-4	Tank Age	48	Tank Installed Date	02/04/1976	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	755	Spill Test Date	06/03/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/16/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/08/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date	06/03/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	D-5	Tank Age	48	Tank Installed Date	02/04/1976	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	756	Spill Test Date	06/03/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/16/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/27/2022	Tank/Piping CP Test Date	07/08/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	06/03/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/29/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CONO MART SUPER STORE 10  
11 W Wicks Ln  
Billings, MT 59105 Yellowstone

System Facility ID:56-05088

Facility Code: 30006  
Last Inspected On: 09/20/2023  
Operating Permit Renewal Date: 03/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc7018521194

Operator Contact: Justin Franjevic;Nancy Coen;Stephanie Zierke4062940867;4068551749;7204212140

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator  
Mark Zinnecker, UST Class B Operator  
Nancy Coen, UST Class A Operator  
Nancy Coen, UST Class B Operator  
Stephanie Zierke, UST Class A Operator

Tank Code	03	Tank Age	34	Tank Installed Date	11/16/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1154	Spill Test Date	09/20/2023	Piping Installed Date	12/15/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/17/2023	Tank/Piping CP Test Date	09/20/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/17/2023	Line Tightness Test Date	09/03/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	03/17/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	34	Tank Installed Date	11/16/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1155	Spill Test Date	09/20/2023	Piping Installed Date	12/15/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	03/17/2023	Tank/Piping CP Test Date	09/20/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/17/2023	Line Tightness Test Date	09/01/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	03/17/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	34	Tank Installed Date	11/16/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1156	Spill Test Date	09/20/2023	Piping Installed Date	12/15/2009	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/17/2023	Tank/Piping CP Test Date	09/20/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/17/2023	Line Tightness Test Date	09/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	03/17/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



Facility Summary in Yellowstone County in the City of Billings

Location: CONOMART SUPERSTORE 6

1219 Main St

Billings, MT 59105-2539 Yellowstone

System Facility ID:56-06948

Facility Code: 30138

Last Inspected On: 08/15/2023

Operating Permit Renewal Date: 08/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc

7018521194

Operator Contact: Justin Franjevic;Nancy Coen;Stephanie Zierke

4062940867;4068551749;7204212140

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator

Nancy Coen, UST Class A Operator

Nancy Coen, UST Class B Operator

Stephanie Zierke, UST Class A Operator

Troy Davis, UST Class B Operator

Tank Code	01	Tank Age	48	Tank Installed Date	04/21/1976	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3618	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	10/06/2023	Tank/Piping CP Test Date	06/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/06/2023	Line Tightness Test Date	09/16/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	53	Tank Installed Date	04/22/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3619	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	10/06/2023	Tank/Piping CP Test Date	06/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/06/2023	Line Tightness Test Date	08/03/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	10/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	53	Tank Installed Date	04/22/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3620	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	10/06/2023	Tank/Piping CP Test Date	06/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	10/06/2023	Line Tightness Test Date	04/15/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: CONOMART SUPERSTORE 7  
4903 Southgate Dr  
Billings, MT 59101-4668 Yellowstone

Facility Code: 30495  
Last Inspected On: 08/15/2022  
System Facility ID:56-13808  
Operating Permit Renewal Date: 12/31/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc7018521194

Operator Contact: Justin Franjevic;Nancy Coen;Stephanie Zierke4062940867;4068551749;7204212140

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator  
Nancy Coen, UST Class A Operator  
Nancy Coen, UST Class B Operator  
Stephanie Zierke, UST Class A Operator  
Tayler Dickinson, UST Class B Operator

Tank Code	01	Tank Age	27	Tank Installed Date	12/05/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1182	Spill Test Date	12/29/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/01/2022	Tank/Piping CP Test Date	05/29/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/01/2022	Line Tightness Test Date	08/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	27	Tank Installed Date	12/05/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1183	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/01/2022	Tank/Piping CP Test Date	05/29/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/01/2022	Line Tightness Test Date	08/11/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	06/01/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	26	Tank Installed Date	12/05/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1184	Spill Test Date	08/23/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/01/2022	Tank/Piping CP Test Date	05/29/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/01/2022	Line Tightness Test Date	08/07/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: COSTCO BILLINGS LOC 1644  
3800 Zoo Drive  
Billings, MT 59102 Yellowstone

System Facility ID:00-32511

Facility Code: 32511  
Last Inspected On: 02/14/2024  
Operating Permit Renewal Date: 04/23/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Costco Wholesale Corporation Seattle

Operator Contact: Lyssa Logan;Costco Wholesale;Shawn Kipp;Costco Wholesale 4066717789;4252516222;4066723253;4252516222

Owner/Operator: Costco Wholesale Corporation Seattle

Lyssa Logan, UST Class A Operator  
Lyssa Logan, UST Class B Operator  
Shawn Kipp, UST Class A Operator  
Shawn Kipp, UST Class B Operator

Tank Code	01	Tank Age	1	Tank Installed Date	10/12/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6141	Spill Test Date	10/02/2023	Piping Installed Date	10/12/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/02/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	10/02/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	40000	ATG Test Date	10/02/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.1	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/02/2023			ATG Type					
Tank Code	02	Tank Age	1	Tank Installed Date	10/12/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6142	Spill Test Date	10/02/2023	Piping Installed Date	10/12/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/02/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	10/02/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	40000	ATG Test Date	10/02/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.1	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/02/2023			ATG Type					

Tank Code	03	Tank Age	1	Tank Installed Date	10/12/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6143	Spill Test Date	10/02/2023	Piping Installed Date	10/12/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/02/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	10/02/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	40000	ATG Test Date	10/02/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.1	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/02/2023			ATG Type					
Tank Code	04	Tank Age	1	Tank Installed Date	10/12/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6144	Spill Test Date	10/02/2023	Piping Installed Date	10/12/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/02/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Hazardous Substance	PLLD Test Date	10/02/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1500	ATG Test Date	10/02/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/02/2023			ATG Type					
Tank Code	05	Tank Age	1	Tank Installed Date	10/12/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6179	Spill Test Date	10/02/2023	Piping Installed Date	10/12/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/02/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	10/02/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	10/02/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/02/2023			ATG Type					
Tank Code	06	Tank Age	1	Tank Installed Date	10/12/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6180	Spill Test Date	10/02/2023	Piping Installed Date	10/12/2023	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/02/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Hazardous Substance	PLLD Test Date	10/02/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	1500	ATG Test Date	10/02/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/02/2023			ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: COSTCO WHOLESALE GASOLINE 69  
2290 King Ave W  
Billings, MT 59102 Yellowstone

System Facility ID:56-13953

Facility Code: 30621  
Last Inspected On: 01/17/2022  
Operating Permit Renewal Date: 04/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Costco Wholesale4252516222

Operator Contact: Andrew Jurcich;Arthur Kraft;Dan Martinez;Dennis Bock;Keaton Leuthold;Kyle Knox;Michael Schaeffer;Patty Vaughan;Samuel Rodriguez;Shawn Kipp4066528765;4066717789

Owner/Operator: Costco Wholesale

- Andrew Jurcich, UST Class A Operator
- Andrew Jurcich, UST Class B Operator
- Arthur Kraft, UST Class A Operator
- Arthur Kraft, UST Class B Operator
- Brett Smith, UST Class B Operator
- Dan Martinez, UST Class A Operator
- Dennis Bock, UST Class A Operator
- Dennis Bock, UST Class B Global Operator
- Hal Ostlund, UST Class B Operator
- Keaton Leuthold, UST Class A Operator
- Keaton Leuthold, UST Class B Global Operator
- Keaton Leuthold, UST Class B Operator
- Kyle Knox, UST Class A Operator
- Kyle Knox, UST Class B Global Operator
- Kyle Knox, UST Class B Operator
- Michael Schaeffer, UST Class A Operator
- Michael Schaeffer, UST Class B Global Operator
- Patty Vaughan, UST Class A Operator
- Patty Vaughan, UST Class B Operator
- Samuel Rodriguez, UST Class A Operator
- Samuel Rodriguez, UST Class B Global Operator
- Shawn Kipp, UST Class A Operator
- Shawn Kipp, UST Class B Operator

Tank Code	01	Tank Age	25	Tank Installed Date	10/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
-----------	----	----------	----	---------------------	------------	---------------	-------------------------------	-----------------	------------------	----------------	------------------



Tag Number	4109	Spill Test Date	06/07/2019	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/16/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	09/16/2021	Line Tightness Test Date	09/16/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/16/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	25	Tank Installed Date	10/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4110	Spill Test Date	06/07/2019	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/16/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	09/16/2021	Line Tightness Test Date	09/16/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/16/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	25	Tank Installed Date	10/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4111	Spill Test Date	06/07/2019	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/20/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/16/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date	09/16/2021	Line Tightness Test Date	09/16/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/16/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	S4	Tank Age	13	Tank Installed Date	04/01/2011	Tank Material	Concrete	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	5354	Spill Test Date		Piping Installed Date	07/19/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	09/16/2021	Sump Tightness Test Date	09/20/2019	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1200	ATG Test Date	09/16/2021	Line Tightness Test Date	09/16/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DEACONESS BILLINGS CLINIC 9TH AVE  
2800 10th Ave N  
Billings, MT 59101-0703 Yellowstone

System Facility ID:56-02067

Facility Code: 29806  
Last Inspected On: 08/02/2021  
Operating Permit Renewal Date: 09/29/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Deaconess Clinic Billings 4066574036

Operator Contact: Cody Anderson;Lloyd Newman

Owner/Operator: Deaconess Clinic Billings

Cody Anderson, UST Class A Operator  
Cody Anderson, UST Class B Operator  
Lloyd Newman, UST Class A Operator  
Lloyd Newman, UST Class B Operator

Tank Code	02	Tank Age	32	Tank Installed Date	02/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	826	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/02/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/12/2021	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/Other				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH 1433 Main St Billings, MT 59105-1739 Yellowstone				Facility Code: 30058 Last Inspected On: 04/14/2023 Operating Permit Renewal Date: 10/14/2026			
System Facility ID:56-05755				Note: Inspection is due 90 days before the Operating Permit Renewal Date.			

Owner Operator Contact: Automatic Car Wash Inc4062482558

Operator Contact: Gene Carlson4062482558

Owner/Operator: Automatic Car Wash Inc  
Gene Carlson, UST Class A Operator  
Gene Carlson, UST Class B Operator

Tank Code	04	Tank Age	19	Tank Installed Date	11/10/2005	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5030	Spill Test Date	04/14/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/10/2023	Tank/Piping CP Test Date	04/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/10/2023	Line Tightness Test Date	08/09/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/14/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	19	Tank Installed Date	11/10/2005	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5031	Spill Test Date	04/14/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/10/2023	Tank/Piping CP Test Date	04/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/10/2023	Line Tightness Test Date	08/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/14/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	06	Tank Age	19	Tank Installed Date	11/10/2005	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5032	Spill Test Date	04/14/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	03/10/2023	Tank/Piping CP Test Date	04/14/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/10/2023	Line Tightness Test Date	08/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/14/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH 1ST AVE  
1924 1st Ave N  
Billings, MT 59101-2443 Yellowstone

System Facility ID:56-06956

Facility Code: 30143  
Last Inspected On: 09/27/2023  
Operating Permit Renewal Date: 09/27/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Automatic Car Wash Inc4062482558

Operator Contact: Eric Carlson;Gene Carlson4062482558;4068942373

Owner/Operator: Automatic Car Wash Inc

Dick Berg, UST Class B Operator  
Eric Carlson, UST Class A Operator  
Eric Carlson, UST Class B Operator  
Gene Carlson, UST Class A Operator  
Gene Carlson, UST Class B Global Operator  
Gene Carlson, UST Class B Operator

Tank Code	05	Tank Age	36	Tank Installed Date	11/11/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	412	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/27/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/10/2023	Line Tightness Test Date	10/12/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	36	Tank Installed Date	11/11/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	413	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/27/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	6000	ATG Test Date	03/10/2023	Line Tightness Test Date	10/12/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	36	Tank Installed Date	11/11/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	414	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/27/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/10/2023	Line Tightness Test Date	10/12/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH CENTRAL AVE  
2343 Central Ave  
Billings, MT 59102 Yellowstone

System Facility ID:56-05492

Facility Code: 30029  
Last Inspected On: 11/07/2017  
Operating Permit Renewal Date: 04/11/2019

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Automatic Car Wash Inc4062482558

Operator Contact: Gene Carlson4062482558

Owner/Operator: Automatic Car Wash Inc

Gene Carlson, UST Class A Operator  
Gene Carlson, UST Class B Operator  
Jamie Gehring, UST Class B Operator

Tank Code	04	Tank Age	34	Tank Installed Date	05/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	409	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/07/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	04/17/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD Line Tightness Testing	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	34	Tank Installed Date	05/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	411	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/07/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/06/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD Line Tightness Testing	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



Tank Code	05	Tank Age	34	Tank Installed Date	05/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4467	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/07/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	11/06/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD Line Tightness Testing	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH GRAND AVE  
1125 Grand Ave  
Billings, MT 59102-4267 Yellowstone

System Facility ID:56-05491

Facility Code: 30028  
Last Inspected On: 09/27/2023  
Operating Permit Renewal Date: 09/27/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Automatic Car Wash Inc	4062482558
Operator Contact:	Gene Carlson	4062482558

Owner/Operator: Automatic Car Wash Inc

Duane Wiederrich, UST Class B Operator  
Gene Carlson, UST Class A Operator  
Gene Carlson, UST Class B Operator  
Keith Warford, UST Class B Operator

Tank Code	04	Tank Age	36	Tank Installed Date	05/04/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	406	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/10/2023	Tank/Piping CP Test Date	09/27/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/10/2023	Line Tightness Test Date	10/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	36	Tank Installed Date	05/04/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	407	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	03/10/2023	Tank/Piping CP Test Date	09/27/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/10/2023	Line Tightness Test Date	10/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	06	Tank Age	36	Tank Installed Date	05/04/1988	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	408	Spill Test Date	09/27/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/10/2023	Tank/Piping CP Test Date	09/27/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	03/10/2023	Line Tightness Test Date	10/11/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS EXPRESS CENTER  
2344 Central Ave  
Billings, MT 59102 Yellowstone

System Facility ID:56-05072

Facility Code: 29995  
Last Inspected On: 04/05/2023  
Operating Permit Renewal Date: 09/25/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Automatic Car Wash Inc4062482558

Operator Contact: Eric Carlson;Gene Carlson4062482558;4068942373

Owner/Operator: Automatic Car Wash Inc

Eric Carlson, UST Class A Operator  
Eric Carlson, UST Class B Operator  
Gene Carlson, UST Class A Operator

Tank Code	05	Tank Age	30	Tank Installed Date	11/08/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2002	Spill Test Date	04/05/2023	Piping Installed Date	10/07/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/22/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/10/2023	Tank/Piping CP Test Date	04/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	03/10/2023	Line Tightness Test Date	02/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	30	Tank Installed Date	11/08/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2003	Spill Test Date	04/05/2023	Piping Installed Date	10/07/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/22/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/10/2023	Tank/Piping CP Test Date	04/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/10/2023	Line Tightness Test Date	03/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	07	Tank Age	30	Tank Installed Date	11/08/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2004	Spill Test Date	04/05/2023	Piping Installed Date	10/07/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/22/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	03/10/2023	Tank/Piping CP Test Date	04/05/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	03/05/2023	Line Tightness Test Date	02/03/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/10/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DONS EXPRESS CENTER 2  
2324 Main St  
Billings, MT 59105-4024 Yellowstone

Facility Code: 30856  
Last Inspected On: 02/09/2023  
System Facility ID:60-15096  
Operating Permit Renewal Date: 04/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Automatic Car Wash Inc4062482558

Operator Contact: Clinton Deyle;Dallas Amman;Gene Carlson4062482558;4065911913;4066943035

Owner/Operator: Automatic Car Wash Inc

- Brad Wire, UST Class B Operator
- Clinton Deyle, UST Class A Operator
- Clinton Deyle, UST Class B Global Operator
- Clinton Deyle, UST Class B Operator
- Dallas Amman, UST Class A Operator
- Dallas Amman, UST Class B Global Operator
- Dallas Amman, UST Class B Operator
- Eric Carlson, UST Class B Operator
- Gene Carlson, UST Class A Operator
- Gene Carlson, UST Class B Operator

Tank Code	01	Tank Age	16	Tank Installed Date	06/29/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5160	Spill Test Date	02/09/2023	Piping Installed Date	12/11/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/09/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/09/2023	Line Tightness Test Date	08/23/2019	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	02/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	16	Tank Installed Date	06/29/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	5161	Spill Test Date	02/09/2023	Piping Installed Date	12/11/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/09/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	02/09/2023	Line Tightness Test Date	08/23/2019	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	02/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	16	Tank Installed Date	06/29/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5162	Spill Test Date	02/09/2023	Piping Installed Date	12/11/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/09/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	02/09/2023	Line Tightness Test Date	08/25/2019	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	02/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	16	Tank Installed Date	06/29/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5163	Spill Test Date	02/09/2023	Piping Installed Date	12/11/2007	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	02/09/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	02/09/2023	Line Tightness Test Date	08/25/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	02/09/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: DOWNTOWN CONOCO  
2701 6th Ave N  
Billings, MT 59101 Yellowstone

Facility Code: 30152  
Last Inspected On: 11/25/2020  
System Facility ID:56-06967  
Operating Permit Renewal Date: 01/28/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings Clinic4066574036

Operator Contact: Jim Murphy;Mun Lee;Paul Murphy4066708112;4066979003;4068501920

Owner/Operator: Billings Clinic  
Owner/Operator: Downtown Conoco - Stanford  
Owner/Operator: George Woodhall

Jim Murphy, UST Class A Operator  
Jim Murphy, UST Class B Operator  
Mun Lee, UST Class A Operator  
Mun Lee, UST Class B Operator  
Paul Murphy, UST Class A Operator  
Paul Murphy, UST Class B Global Operator

Tank Code	01	Tank Age	56	Tank Installed Date	04/22/1968	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3621	Spill Test Date	02/04/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	09/02/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	01/29/2020	Tank/Piping CP Test Date	01/06/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	16000	ATG Test Date	09/02/2022	Line Tightness Test Date	10/16/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	54	Tank Installed Date	04/22/1970	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3622	Spill Test Date	02/04/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No



Tank Status	Permanently Out of Use	MLLD Test Date	09/02/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	01/29/2020	Tank/Piping CP Test Date	01/06/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/02/2022	Line Tightness Test Date	10/06/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	50	Tank Installed Date	04/22/1974	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3623	Spill Test Date	02/04/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date	09/02/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	01/29/2020	Tank/Piping CP Test Date	01/06/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	09/02/2022	Line Tightness Test Date	10/13/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	09/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: EMERALD MART 2  
3306 Rimrock Rd  
Billings, MT 59102-0325 Yellowstone

System Facility ID:56-05090

Facility Code: 30008  
Last Inspected On: 12/09/2022  
Operating Permit Renewal Date: 02/24/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Vesta Ventures LLP4066568402

Operator Contact: Beverly Mundschenk4068613952

Owner/Operator: Vesta Ventures LLP

Beverly Mundschenk, UST Class A Operator

Tank Code	01	Tank Age	37	Tank Installed Date	11/30/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3681	Spill Test Date	12/09/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/09/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/09/2022	Line Tightness Test Date	12/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	37	Tank Installed Date	11/30/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3682	Spill Test Date	12/09/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	12/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	12/09/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	12/09/2022	Line Tightness Test Date	12/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/21/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	37	Tank Installed Date	11/30/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3683	Spill Test Date	12/09/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	12/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	12/09/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/09/2022	Line Tightness Test Date	12/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/21/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: FED EX FREIGHT  
7107 Commercial Ave  
Billings, MT 59101 Yellowstone

System Facility ID:60-15181

Facility Code: 30907  
Last Inspected On: 11/28/2023  
Operating Permit Renewal Date: 03/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: K W Billings LLC6194351614

Operator Contact: Adren Hillenburg;Chong Lee4086543112

Owner/Operator: K W Billings LLC

Adren Hillenburg, UST Class A Operator  
Adren Hillenburg, UST Class B Global Operator  
Chong Lee, UST Class A Operator  
Jon Schaffer, UST Class B Operator  
Kevin Roberts, UST Class B Operator  
Nick Haynes, UST Class B Operator  
Ted Carlson, UST Class B Operator

Tank Code	01	Tank Age	13	Tank Installed Date	05/23/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm;Positive Shutoff
Tag Number	5293	Spill Test Date	11/06/2023	Piping Installed Date	04/29/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/18/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	11/06/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	11/06/2023	Line Tightness Test Date	09/18/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	11/06/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: FEDEX GROUND BILLINGS  
3815 Hesper Rd  
Billings, MT 59106 Yellowstone

System Facility ID:60-15209

Facility Code: 30929  
Last Inspected On: 10/26/2022  
Operating Permit Renewal Date: 01/17/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: FedEx Ground Package System Inc4122627347

Operator Contact: Gaylyn Frosini;Mark Feasel;FedEx Ground Package System Inc;Peter Bushman;FedEx Ground Package System Inc4066062574;4122627347;4122627347

Owner/Operator: FedEx Ground Package System Inc

Derek Kouzmanoff, UST Class B Operator  
Gaylyn Frosini, UST Class A Operator  
Mark Feasel, UST Class A Operator  
Mark Feasel, UST Class B Operator  
Peter Bushman, UST Class A Operator  
Peter Bushman, UST Class B Operator

Tank Code	01	Tank Age	11	Tank Installed Date	10/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5447	Spill Test Date	09/13/2021	Piping Installed Date	10/24/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/22/2022	Sump Tightness Test Date	09/13/2021	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	09/22/2022	Line Tightness Test Date	09/22/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	11	Tank Installed Date	10/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5448	Spill Test Date	09/13/2021	Piping Installed Date	10/24/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/22/2022	Sump Tightness Test Date	09/13/2021	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	30000	ATG Test Date	09/22/2022	Line Tightness Test Date	09/22/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	11	Tank Installed Date	10/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	Ball Float Valve;Flapper Valve;High Level Alarm
Tag Number	5449	Spill Test Date	09/13/2021	Piping Installed Date	10/24/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/13/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Biodiesel B99	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	09/22/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/22/2022			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	11	Tank Installed Date	10/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material		Overfill Types	High Level Alarm
Tag Number	5450	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type		CP Met Types	Non-corrodible
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	05	Tank Age	5	Tank Installed Date	08/21/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5930	Spill Test Date	09/13/2021	Piping Installed Date	08/21/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	09/13/2021	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	1500	ATG Test Date	09/22/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	09/22/2022			ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: FIRST INTERSTATE CENTER  
401 N 31st St  
Billings, MT 59101-1200 Yellowstone

System Facility ID:56-13766

Facility Code: 30460  
Last Inspected On: 04/29/2022  
Operating Permit Renewal Date: 06/01/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings 401 LLC

Operator Contact: Jerome Ries;Raymond Quenzer

Owner/Operator: Billings 401 LLC

Brad Zimmer, UST Class B Operator  
Jerome Ries, UST Class A Operator  
Jerome Ries, UST Class B Operator  
Jim Zimmer, UST Class B Operator  
Leonard Meyer, UST Class B Operator  
Raymond Quenzer, UST Class A Operator  
Raymond Quenzer, UST Class B Global Operator

Tank Code	02	Tank Age	26	Tank Installed Date	10/01/1998	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	3400	Spill Test Date	06/16/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/29/2022	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/16/2013	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	Manual Interstitial Monitoring	Vapor Recovery	No
Capacity	560	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/16/2022			ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: FLYING J INC BILLINGS  
2775 Old Hardin Rd  
Billings, MT 59101 Yellowstone

System Facility ID:56-12585

Facility Code: 30405  
Last Inspected On: 04/02/2024  
Operating Permit Renewal Date: 02/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings 7 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Billings 7 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	33	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1105	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date	11/29/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/18/2023	Line Tightness Test Date	06/26/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	33	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1108	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date	11/29/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/18/2023	Line Tightness Test Date	06/26/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				



Tank Code	05	Tank Age	33	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1109	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date	11/29/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/18/2023	Line Tightness Test Date	06/26/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	33	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1110	Spill Test Date	09/07/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/31/2023	Tank/Piping CP Test Date	11/29/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/18/2023	Line Tightness Test Date	06/26/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	02	Tank Age	33	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4447	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date	11/29/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/18/2023	Line Tightness Test Date	06/26/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	03	Tank Age	33	Tank Installed Date	08/01/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4448	Spill Test Date	08/18/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date	11/29/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/18/2023	Line Tightness Test Date	06/26/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	11	Tank Installed Date	08/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5425	Spill Test Date	09/07/2023	Piping Installed Date	06/25/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	09/07/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	08	Tank Age	11	Tank Installed Date	08/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5426	Spill Test Date		Piping Installed Date	06/25/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date	10/04/2013	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/20/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	09	Tank Age	11	Tank Installed Date	08/01/2013	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5427	Spill Test Date	08/18/2023	Piping Installed Date	06/25/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/04/2013	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/18/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/18/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/18/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				

Facility Summary in Yellowstone County in the City of Billings

Location: GAS N GO  
800 Jackson St  
Billings, MT 59101-5451 Yellowstone

System Facility ID:56-10866

Facility Code: 30363  
Last Inspected On: 10/21/2022  
Operating Permit Renewal Date: 01/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JLG Inc5103333310

Operator Contact:

Owner/Operator: JLG Inc

Lorraine Boyd, UST Class B Operator

Tank Code	01	Tank Age	40	Tank Installed Date	04/10/1984	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4551	Spill Test Date	10/21/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/21/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	12/21/2022			ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: GM PETROLEUM DISTRIBUTORS  
2100 1st Ave S  
Billings, MT 59101 Yellowstone

System Facility ID:56-06962

Facility Code: 30147  
Last Inspected On: 09/28/2023  
Operating Permit Renewal Date: 03/14/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Service Valcon LLC DBA GM Petroleum Distributors 4062524661

Operator Contact: Jay Brookie;Laura Geffre;Margaret Flynn;Roger Schmechel 4062083147;4062524661;4062940863

Owner/Operator: City Service Valcon LLC

Owner/Operator: City Service Valcon LLC DBA GM Petroleum Distributors  
Bill Grunstead, UST Class A Operator  
Roger Schmechel, UST Class A Operator  
Roger Schmechel, UST Class B Operator  
Bill Grunstead, UST Class A Operator  
Laura Geffre, UST Class A Operator  
Laura Geffre, UST Class B Operator  
Roger Schmechel, UST Class A Operator  
Roger Schmechel, UST Class B Operator  
Jay Brookie, UST Class A Operator  
Jay Brookie, UST Class B Global Operator  
Laura Geffre, UST Class A Operator  
Laura Geffre, UST Class B Operator  
Margaret Flynn, UST Class A Operator  
Margaret Flynn, UST Class B Operator  
Roger Schmechel, UST Class A Operator  
Roger Schmechel, UST Class B Operator

Tank Code	01	Tank Age	39	Tank Installed Date	06/01/1985	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1167	Spill Test Date	01/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No

Capacity	6000	ATG Test Date	01/19/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	39	Tank Installed Date	06/01/1985	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1168	Spill Test Date	01/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	09/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date	01/19/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	39	Tank Installed Date	06/01/1985	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1169	Spill Test Date	01/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date	01/19/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	39	Tank Installed Date	06/01/1985	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	4626	Spill Test Date	01/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	6000	ATG Test Date	01/19/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/19/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	41	Tank Installed Date	05/07/1983	Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	High Level Alarm

Tag Number	4627	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Impressed Current
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	09/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: HEIGHTS CAR CARE  
1320 Main St  
Billings, MT 59105-1742 Yellowstone

System Facility ID:56-06960

Facility Code: 30146  
Last Inspected On: 05/02/2022  
Operating Permit Renewal Date: 05/02/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Christan Automotive Repair Service LLC

Operator Contact: Joseph Borgstrom4062593709

Owner/Operator: Christan Automotive Repair Service LLC

Joseph Borgstrom, UST Class A Operator  
Joseph Borgstrom, UST Class B Global Operator

Tank Code	01	Tank Age	48	Tank Installed Date	04/21/1976	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1164	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/02/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	08/01/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	48	Tank Installed Date	04/21/1976	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1165	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/02/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	08/01/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	03	Tank Age	48	Tank Installed Date	04/21/1976	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve



Tag Number	1166	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/02/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	08/01/2016	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: JTL GROUP INC UST  
1102 Shiloh Rd  
Billings, MT 59106-2415 Yellowstone

System Facility ID:56-14001

Facility Code: 30662  
Last Inspected On: 01/13/2022  
Operating Permit Renewal Date: 05/23/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: JTL Group Inc4066552012

Operator Contact: Brian Nickel;Dan Ottman4066512476

Owner/Operator: JTL Group Inc

Brian Nickel, UST Class A Operator  
Brian Nickel, UST Class B Global Operator  
Brian Nickel, UST Class B Operator  
Dan Ottman, UST Class A Operator  
Dan Ottman, UST Class B Operator

Tank Code	01	Tank Age	23	Tank Installed Date	04/01/2001	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4397	Spill Test Date	01/13/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	1958	ATG Test Date	01/13/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/13/2022			ATG Type	Veeder Root/TLS-350				
Tank Code	02	Tank Age	23	Tank Installed Date	04/01/2001	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4398	Spill Test Date	01/13/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/13/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	13019	ATG Test Date	01/13/2022	Line Tightness Test Date	10/27/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/13/2022			ATG Type	Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: LEWIS AND CLARK MIDDLE SCHOOL  
1315 Lewis Ave  
Billings, MT 59102-4237 Yellowstone

System Facility ID:56-14070

Facility Code: 30722  
Last Inspected On: 12/10/2019  
Operating Permit Renewal Date: 03/30/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lewis and Clark Middle School

Operator Contact: Dennis Stellingwerf

Owner/Operator: Lewis and Clark Middle School

Dennis Stellingwerf, UST Class A Operator  
Timothy Schafft, UST Class B Global Operator

Tank Code	01	Tank Age	20	Tank Installed Date	11/15/2004	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4970	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	12/10/2019	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	12/10/2019	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: LYNCH FLYING SERVICE  
1691 Aviation Pl  
Billings, MT 59105 Yellowstone

System Facility ID:56-07797

Facility Code: 30200  
Last Inspected On: 05/03/2023  
Operating Permit Renewal Date: 10/29/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Lynch Flying Service Inc

Operator Contact: Aaron VanLuchene;Joel Simmons;Parker Hesper;Robert McCullough;Warren Nemitz4062478916;4062520508

Owner/Operator: Lynch Flying Service Inc

- Aaron VanLuchene, UST Class A Operator
- Aaron VanLuchene, UST Class B Global Operator
- Joel Simmons, UST Class A Operator
- Joel Simmons, UST Class B Operator
- Parker Hesper, UST Class A Operator
- Parker Hesper, UST Class B Global Operator
- Robert McCullough, UST Class A Operator
- Robert McCullough, UST Class B Operator
- Warren Nemitz, UST Class A Operator
- Warren Nemitz, UST Class B Global Operator

Tank Code	08	Tank Age	34	Tank Installed Date	10/25/1990	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1563	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	07/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	34	Tank Installed Date	10/25/1990	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1564	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	07/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	34	Tank Installed Date	10/25/1990	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1565	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	07/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	34	Tank Installed Date	10/25/1990	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1566	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	07/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	12	Tank Age	34	Tank Installed Date	10/25/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1567	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	13	Tank Age	26	Tank Installed Date	06/26/1998	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1568	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	07/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	14	Tank Age	26	Tank Installed Date	06/26/1998	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	1569	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date	07/20/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	15	Tank Age	5	Tank Installed Date	05/01/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	5909	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/22/2019	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					
Tank Code	16	Tank Age	5	Tank Installed Date	05/01/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	5910	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/22/2019	Catastrophic L.D Type 3.0	Not Required	Piping Type		CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	30000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: LYNCH FLYING SERVICE INC  
1482 Aviation Place  
Billings, MT 59105 Yellowstone

System Facility ID:60-15100

Facility Code: 30859  
Last Inspected On: 05/04/2023  
Operating Permit Renewal Date: 10/15/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Edwards Jet Center;Paul Gatzemeier4066969842

Operator Contact: Aaron VanLuchene;Joel Simmons;Parker Hesel;Warren Nemitz4062520508

Owner/Operator: Edwards Jet Center

Owner/Operator: Paul Gatzemeier

- Aaron VanLuchene, UST Class A Operator
- Aaron VanLuchene, UST Class B Global Operator
- Joel Simmons, UST Class A Operator
- Joel Simmons, UST Class B Operator
- Parker Hesel, UST Class A Operator
- Parker Hesel, UST Class B Global Operator
- Warren Nemitz, UST Class A Operator
- Warren Nemitz, UST Class B Global Operator

Tank Code	01	Tank Age	16	Tank Installed Date	02/25/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	5172	Spill Test Date	07/20/2020	Piping Installed Date	02/22/2008	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/28/2014	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	05/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	16	Tank Installed Date	02/25/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	5173	Spill Test Date	07/20/2020	Piping Installed Date	02/22/2008	Tank Construction	Double-Walled	Piping Construction	None	AST	No



Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/28/2014	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Jet Fuel (Jet-A, Jet-A1, JP5)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	05/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	16	Tank Installed Date	02/25/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	No Piping	Overfill Types	High Level Alarm
Tag Number	5174	Spill Test Date	05/04/2023	Piping Installed Date	02/22/2008	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/28/2014	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Not Listed	CP Met Types	Non-corrodible
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/04/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	05/04/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: MARKET BASKET STORE  
8014 S Frontage Rd  
Billings, MT 59101 Yellowstone

System Facility ID:56-08286

Facility Code: 30228  
Last Inspected On: 01/25/2023  
Operating Permit Renewal Date: 04/22/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town and Country Supply Association 4066286314

Operator Contact: Kevin Wynia;Town and Country Supply Association;Wes Burley 4062561020;4066286314

Owner/Operator: Town and Country Supply Association

Kevin Wynia, UST Class A Operator  
Kevin Wynia, UST Class B Operator  
Wes Burley, UST Class A Operator

Tank Code	03	Tank Age	29	Tank Installed Date	10/06/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3314	Spill Test Date	07/11/2022	Piping Installed Date	08/25/2022	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/06/2022	Sump Tightness Test Date	07/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/16/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/11/2022	Line Tightness Test Date	08/01/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/11/2022			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	29	Tank Installed Date	10/06/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	3315	Spill Test Date	07/11/2022	Piping Installed Date	08/25/2022	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/06/2022	Sump Tightness Test Date	07/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	07/11/2022	Tank/Piping CP Test Date	04/16/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/11/2022	Line Tightness Test Date	12/31/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	07/11/2022			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	05	Tank Age	21	Tank Installed Date	11/28/2003	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4945	Spill Test Date	07/11/2022	Piping Installed Date	08/25/2022	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/06/2022	Sump Tightness Test Date	07/11/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	07/11/2022	Tank/Piping CP Test Date	04/16/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/11/2022	Line Tightness Test Date	08/24/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	07/11/2022			ATG Type	Veeder Root/TLS-450PLUS				
Tank Code	06	Tank Age	2	Tank Installed Date	06/09/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6092	Spill Test Date	08/25/2022	Piping Installed Date	08/25/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/25/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	8000	ATG Test Date	08/25/2022	Line Tightness Test Date	08/25/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/25/2022			ATG Type					
Tank Code	07	Tank Age	2	Tank Installed Date	06/09/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6093	Spill Test Date		Piping Installed Date	08/25/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/25/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/25/2022	Line Tightness Test Date	08/26/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/25/2022			ATG Type					
Tank Code	08	Tank Age	2	Tank Installed Date	06/02/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6094	Spill Test Date	08/25/2022	Piping Installed Date	08/25/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/25/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Diesel	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/25/2022	Line Tightness Test Date	08/25/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/25/2022			ATG Type					
Tank Code	09	Tank Age	2	Tank Installed Date	06/09/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6095	Spill Test Date	08/25/2022	Piping Installed Date	08/25/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date	08/25/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: MCDONALD LIGHTHOUSE  
3212 1st Ave S  
Billings, MT 59101-3824 Yellowstone

System Facility ID:60-15027

Facility Code: 30811  
Last Inspected On: 05/29/2018  
Operating Permit Renewal Date: 07/01/2019

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Yellowstone Boys & Girls Ranch 4066513100

Operator Contact: Dale Orth;Gregory Leeds 4066728005

Owner/Operator: Yellowstone Boys & Girls Ranch

Dale Orth, UST Class A Operator  
Dale Orth, UST Class B Operator  
Gregory Leeds, UST Class A Operator  
Patrick Friesen, UST Class B Global Operator  
Rick Kelum, UST Class B Operator

Tank Code	01	Tank Age	18	Tank Installed Date	02/06/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5072	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	U.S. Suction	CP Met Types	
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	06/04/2015	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: MDOT BILLINGS  
424 Morey St  
Billings, MT 59101-4732 Yellowstone

System Facility ID:56-09501

Facility Code: 30307  
Last Inspected On: 10/04/2022  
Operating Permit Renewal Date: 10/17/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MDOT Helena4064446163

Operator Contact: Jason Marcum;MDOT Billings;Joe Radonich;Montana Dept of Transportation;Mike Murolo;Montana Dept of Transportation;Tracy Deeds;MDOT Helena;Walt Kerttula;Montana Dept of Transportation4064446151;4064449204;4064446163;4064449204;4064449204;406449204;4064610769;4064446163;4066570252;4062524138

Owner/Operator: MDOT Helena

- Bradley Becker, UST Class B Global Operator
- Jason Marcum, UST Class A Operator
- Jason Marcum, UST Class B Operator
- Joe Radonich, UST Class A Operator
- Joe Radonich, UST Class B Global Operator
- John McCloskey, UST Class B Operator
- Mike Murolo, UST Class A Operator
- Tracy Deeds, UST Class A Operator
- Walt Kerttula, UST Class A Operator

Tank Code	06	Tank Age	31	Tank Installed Date	09/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2948	Spill Test Date	10/04/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/04/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	10/04/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	31	Tank Installed Date	09/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2949	Spill Test Date	10/04/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic

Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/04/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	10/04/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/04/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: MERIDIAN AUTOMOTIVE SERVICE INC  
1240 Ave C  
Billings, MT 59102-3238 Yellowstone

System Facility ID:56-05077

Facility Code: 30000  
Last Inspected On: 07/20/2023  
Operating Permit Renewal Date: 07/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Meridian Automotive Service LLC4062596922

Operator Contact: Richard Skewis4062596922

Owner/Operator: Meridian Automotive Service LLC

Richard Skewis, UST Class A Operator  
Richard Skewis, UST Class B Operator

Tank Code	05	Tank Age	30	Tank Installed Date	01/11/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3182	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/20/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	30	Tank Installed Date	01/11/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3183	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/20/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				



Tank Code	07	Tank Age	30	Tank Installed Date	01/11/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3184	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/20/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: MIDWEST MOTOR EXPRESS INC  
214 Orchard Ln  
Billings, MT 59101-4952 Yellowstone

System Facility ID:56-14075

Facility Code: 30727  
Last Inspected On: 10/12/2023  
Operating Permit Renewal Date: 10/12/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Midwest Motor Express4062455938

Operator Contact: Christopher Booth4062455938

Owner/Operator: Midwest Motor Express

Christopher Booth, UST Class A Operator

Christopher Booth, UST Class B Operator

Tank Code	01	Tank Age	21	Tank Installed Date	01/09/2003	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4782	Spill Test Date	10/12/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/31/2023	Sump Tightness Test Date	10/15/2015	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	09/11/2023	Line Tightness Test Date	01/29/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/12/2023			ATG Type	Veeder Root/Other				

Facility Summary in Yellowstone County in the City of Billings

Location: MONAD DANIELS CARDLOCK #4  
275 Daniels St  
Billings, MT 59101 Yellowstone

System Facility ID:56-09271

Facility Code: 30294  
Last Inspected On: 11/10/2021  
Operating Permit Renewal Date: 04/20/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Monad Daniels LLC

Operator Contact: Bill Grunstead;Jay Brookie;Laura Geffre;Roger Schmechel 4062083147;4062524661

Owner/Operator: Monad Daniels LLC

- Bill Grunstead, UST Class A Operator
- Jay Brookie, UST Class A Operator
- Jay Brookie, UST Class B Global Operator
- Laura Geffre, UST Class A Operator
- Laura Geffre, UST Class B Operator
- Roger Schmechel, UST Class A Operator
- Roger Schmechel, UST Class B Operator

Tank Code	01	Tank Age	31	Tank Installed Date	01/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4716	Spill Test Date	05/26/2020	Piping Installed Date	11/13/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/07/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/07/2021	Line Tightness Test Date	10/19/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/07/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	31	Tank Installed Date	01/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4717	Spill Test Date	05/26/2020	Piping Installed Date	11/13/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/07/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	8000	ATG Test Date	05/07/2021	Line Tightness Test Date	10/25/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/07/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: MSU FACILITY SERVICES BLDG  
1500 University Dr  
Billings, MT 59101-0245 Yellowstone

System Facility ID:56-00904

Facility Code: 29741  
Last Inspected On: 03/12/2021  
Operating Permit Renewal Date: 08/21/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana State University Billings 4066572309

Operator Contact: Brian Mackey;Jason McGimpsey 4066725594

Owner/Operator: Montana State University Billings

Brian Mackey, UST Class A Operator  
Brian Mackey, UST Class B Global Operator  
Brian Mackey, UST Class B Operator  
Jason McGimpsey, UST Class A Operator  
John Grimstad, UST Class B Operator

Tank Code	05	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	846	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	Yes
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: MT STATE WOMENS PRISON  
701 S 27th St  
Billings, MT 59101-4511 Yellowstone

System Facility ID:56-01757

Facility Code: 29788  
Last Inspected On: 11/24/2023  
Operating Permit Renewal Date: 04/04/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Montana State Womens Prison4062475100

Operator Contact: Joel Carlson;Michael Bangert

Owner/Operator: Montana State Womens Prison

Joel Carlson, UST Class A Operator  
Joel Carlson, UST Class B Operator  
Michael Bangert, UST Class A Operator  
Michael Bangert, UST Class B Operator

Tank Code	02	Tank Age	19	Tank Installed Date	10/01/2005	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5053	Spill Test Date	01/18/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/03/2023	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/22/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	11/03/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/03/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: NORTHWESTERN ENERGY FACILITY  
405 S 20th St W  
Billings, MT 59102-6343 Yellowstone

System Facility ID:56-01188

Facility Code: 29758  
Last Inspected On: 08/30/2023  
Operating Permit Renewal Date: 12/09/2020

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Northwestern Energy Butte 4066552521

Operator Contact: Brian Ranf;John Habeger

Owner/Operator: Northwestern Energy Butte

Brian Ranf, UST Class A Operator  
Darren Brockel, UST Class B Global Operator  
John Habeger, UST Class A Operator

Tank Code	04	Tank Age	0	Tank Installed Date		Tank Material	Concrete	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Not Listed	CP Met Types	
Product	Oil/Water Separator	PLLD Test Date		Tank/Piping CP Test Date	12/18/2007	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	800	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	3-1	Tank Age	44	Tank Installed Date	04/30/1980	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1683	Spill Test Date	11/06/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	09/06/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	08/30/2023	Line Tightness Test Date	10/05/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/06/2023			ATG Type	EMCO Electronics/EECO 1500				

Tank Code	3-2	Tank Age	44	Tank Installed Date	04/30/1980	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1684	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	07/08/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				
Tank Code	3-3	Tank Age	44	Tank Installed Date	04/30/1980	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	1685	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/08/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	07/08/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	07/08/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	EMCO Electronics/EECO 1500				



Facility Summary in Yellowstone County in the City of Billings

Location: OLD DOMINION FREIGHT LINES  
1030 Intermountain St  
Billings, MT 59101 Yellowstone

System Facility ID:60-15216

Facility Code: 30935  
Last Inspected On: 08/16/2023  
Operating Permit Renewal Date: 09/19/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Old Dominion Freight Line;Robert Alexander4062566506

Operator Contact: Christopher Hauger;Old Dominion Freight Line4064441415

Owner/Operator: Old Dominion Freight Line

Owner/Operator: Robert Alexander

Christopher Hauger, UST Class A Operator

Christopher Hauger, UST Class B Operator

Tank Code	S1	Tank Age	12	Tank Installed Date	10/01/2012	Tank Material	Other	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5393	Spill Test Date		Piping Installed Date	10/05/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/02/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	09/01/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: PACIFIC SUPPLY  
600 Daniel St  
Billings, MT 59101-3221 Yellowstone

System Facility ID:56-04965

Facility Code: 29960  
Last Inspected On: 01/31/2023  
Operating Permit Renewal Date: 01/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Pacific Coast Building Products Rancho Cordova 9169712301

Operator Contact: Dennis Yonts;Kate Renner;Ryan Eklund 4062458876

Owner/Operator: Pacific Coast Building Products Rancho Cordova

Dennis Yonts, UST Class A Operator  
Kate Renner, UST Class A Operator  
Kayla Wittman, UST Class B Operator  
Ryan Eklund, UST Class A Operator  
Ryan Eklund, UST Class B Operator

Tank Code	03	Tank Age	31	Tank Installed Date	11/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4350	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Other/Other				

Facility Summary in Yellowstone County in the City of Billings

Location: PAR MONTANA BILLINGS PRODUCTS TERMINAL  
607 Exxonmobil Rd  
Billings, MT 59101 Yellowstone

System Facility ID:56-11335

Facility Code: 30374  
Last Inspected On: 09/30/2021  
Operating Permit Renewal Date: 10/13/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: PAR MONTANA2818994847

Operator Contact: Bry Joaillier Allen;Christopher Martin;Christy Minnis;James Vokral;Janie Lee;Jason Martin;Michael Bailey;Michael James;Robert Ochsenbein;Tyler Wattles4064138460;4064424190;4065866927;4066575404;4357647049;8326247774;8326247876;9013028249

Owner/Operator: PAR MONTANA

- Bry Joaillier Allen, UST Class A Operator
- Bry Joaillier Allen, UST Class B Global Operator
- Christopher Martin, UST Class A Operator
- Christopher Martin, UST Class B Operator
- Christy Minnis, UST Class A Operator
- Christy Minnis, UST Class B Global Operator
- James Vokral, UST Class A Operator
- James Vokral, UST Class B Global Operator
- Janie Lee, UST Class A Operator
- Janie Lee, UST Class B Global Operator
- M Martin, UST Class A Operator
- M Martin, UST Class B Global Operator
- Michael Bailey, UST Class A Operator
- Michael Bailey, UST Class B Global Operator
- Michael James, UST Class A Operator
- Michael James, UST Class B Global Operator
- Robert Ochsenbein, UST Class A Operator
- Robert Ochsenbein, UST Class B Global Operator
- Tyler Wattles, UST Class A Operator

Tank Code	S16	Tank Age	0	Tank Installed Date		Tank Material	Bare Steel	Piping Material	Steel	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product	Oil/Water Separator	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Deferred	Vapor Recovery	No

Capacity	4000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	37	Tank Age	30	Tank Installed Date	10/01/1994	Tank Material	Steel Clad	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	2736	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Impressed Current
Product	Mixture	PLLD Test Date		Tank/Piping CP Test Date	10/20/2020	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	11/16/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S02	Tank Age	74	Tank Installed Date	01/01/1950	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2738	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/20/2020	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	197000	ATG Test Date		Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S13	Tank Age	74	Tank Installed Date	01/01/1950	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2749	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/20/2020	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	60000	ATG Test Date		Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S14	Tank Age	74	Tank Installed Date	01/01/1950	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2750	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/20/2020	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No

Capacity	60000	ATG Test Date		Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S44	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2751	Spill Test Date		Piping Installed Date	01/04/2017	Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S45	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2752	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S46	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2753	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S47	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2754	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S48	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2755	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S49	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2756	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S39	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2758	Spill Test Date		Piping Installed Date	01/04/2017	Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type					
Tank Code	S40	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2759	Spill Test Date		Piping Installed Date	01/04/2017	Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S41	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2760	Spill Test Date		Piping Installed Date	01/04/2017	Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S42	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2761	Spill Test Date		Piping Installed Date	01/04/2017	Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S43	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2762	Spill Test Date		Piping Installed Date	01/04/2017	Tank Construction		Piping Construction	Secondary Containment Chase	AST	Yes

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S50	Tank Age	27	Tank Installed Date	05/01/1997	Tank Material	Unknown	Piping Material	Steel	Overfill Types	
Tag Number	2763	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/14/2019	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Hazardous Substance	PLLD Test Date		Tank/Piping CP Test Date	10/03/2008	Primary Tank Leak Detection		Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/10/2009	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S34	Tank Age	72	Tank Installed Date	01/01/1952	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2764	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/20/2020	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	2959110	ATG Test Date		Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S35	Tank Age	72	Tank Installed Date	01/01/1952	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	
Tag Number	2765	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/20/2020	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	1784454	ATG Test Date		Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S36	Tank Age	72	Tank Installed Date	01/01/1952	Tank Material	Unknown	Piping Material	Steel - Terminal Piping	Overfill Types	



Tag Number	2766	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/20/2020	Primary Tank Leak Detection		Primary Pipe Detection	Terminal Piping Annual Line Test	Vapor Recovery	No
Capacity	1749888	ATG Test Date		Line Tightness Test Date	11/13/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: PEPSI COLA BOTTLING CO BILLINGS  
344 Howard Ave  
Billings, MT 59101-3039 Yellowstone

System Facility ID:56-08323

Facility Code: 30261  
Last Inspected On: 02/08/2024  
Operating Permit Renewal Date: 06/13/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Pepsi Cola Bottling Co

Operator Contact: Patrick Boehm

Owner/Operator: Pepsi Cola Bottling Co

Patrick Boehm, UST Class A Operator  
Patrick Boehm, UST Class B Operator

Tank Code	03	Tank Age	34	Tank Installed Date	08/01/1990	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1798	Spill Test Date	02/08/2024	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/08/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date	02/08/2024	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/08/2024			ATG Type	OPW/EECO 1500				

Facility Summary in Yellowstone County in the City of Billings

Location: POLY CONOCO  
1704 Poly Dr  
Billings, MT 59102-1729 Yellowstone

System Facility ID:56-04414

Facility Code: 29908  
Last Inspected On: 01/10/2019  
Operating Permit Renewal Date: 02/13/2022

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Morledge - Hampton Family LLC	4066721044
Operator Contact:	Lawrence Sperry	4062456944

Owner/Operator: Morledge - Hampton Family LLC

Lawrence Sperry, UST Class A Operator  
Lawrence Sperry, UST Class B Operator

Tank Code	05	Tank Age	26	Tank Installed Date	02/11/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4718	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/10/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	01/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	26	Tank Installed Date	02/11/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4719	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/10/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	7000	ATG Test Date		Line Tightness Test Date	01/08/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	07	Tank Age	26	Tank Installed Date	02/11/1998	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4720	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/10/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	01/09/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: QWEST BILLINGS WEST CENTRAL OFFICE  
3190 Central Ave  
Billings, MT 59102-6606 Yellowstone

System Facility ID:56-08762

Facility Code: 30285  
Last Inspected On: 10/03/2023  
Operating Permit Renewal Date: 05/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Qwest Corporation/Century Link8012380337

Operator Contact: Kevin Robison;Stephanie Miller;Thomas Pitts2063467532;5016808141;8012380337

Owner/Operator: Qwest Corporation/Century Link

- Kevin Robison, UST Class A Operator
- Kevin Robison, UST Class B Global Operator
- Stephanie Miller, UST Class A Operator
- Stephanie Miller, UST Class B Global Operator
- Thomas Pitts, UST Class A Operator
- Thomas Pitts, UST Class B Global Operator
- Thomas Pitts, UST Class B Operator

Tank Code	02	Tank Age	30	Tank Installed Date	11/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1733	Spill Test Date	10/03/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/20/2012	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	1000	ATG Test Date	10/03/2023	Line Tightness Test Date	10/03/2023	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	10/03/2023			ATG Type	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: REDDI ELECTRIC INC  
1045 1/2 Central Ave  
Billings, MT 59102-5821 Yellowstone

System Facility ID:56-06953

Facility Code: 30142  
Last Inspected On: 06/15/2021  
Operating Permit Renewal Date: 09/16/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Reddi Electric Inc

Operator Contact: Jordan Schmidt

Owner/Operator: Reddi Electric Inc

Jordan Schmidt, UST Class A Operator  
Jordan Schmidt, UST Class B Operator

Tank Code	02	Tank Age	37	Tank Installed Date	01/10/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1837	Spill Test Date	06/15/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	06/15/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	560	ATG Test Date	06/15/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/15/2021			ATG Type	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: RENTAL CAR WASH  
3301 Overlook Dr  
Billings, MT 59105 Yellowstone

System Facility ID:60-15179

Facility Code: 30905  
Last Inspected On: 12/18/2023  
Operating Permit Renewal Date: 03/24/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings Logan International Airport

Operator Contact: Donald Kim Annin;Shawn Gaalswyk 4066578495

Owner/Operator: Billings Logan International Airport

Dennis Couch, UST Class B Operator  
Donald Kim Annin, UST Class A Operator  
Shawn Gaalswyk, UST Class A Operator

Tank Code	01	Tank Age	13	Tank Installed Date	04/11/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5288	Spill Test Date		Piping Installed Date	03/29/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	03/17/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	03/17/2023	Line Tightness Test Date	03/17/2023	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	03/17/2023			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: SAINT VINCENT HOSPITAL AND HEALTH CENTER  
1233 N 30th St  
Billings, MT 59101-0127 Yellowstone

System Facility ID:56-02666

Facility Code: 29838  
Last Inspected On: 01/20/2023  
Operating Permit Renewal Date: 05/22/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Saint Vincent Hospital and Health Center

Operator Contact: Christopher Tull;Saint Vincent Hospital and Health Center;Kevin Maddox;Noah Foley 4066903980

Owner/Operator: Saint Vincent Hospital and Health Center

Christopher Tull, UST Class A Operator  
Christopher Tull, UST Class B Operator  
Kevin Maddox, UST Class A Operator  
Kevin Maddox, UST Class B Operator  
Noah Foley, UST Class A Operator  
Noah Foley, UST Class B Operator

Tank Code	07	Tank Age	8	Tank Installed Date	11/01/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Positive Shutoff
Tag Number	5700	Spill Test Date		Piping Installed Date	11/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/20/2023	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	11/14/2016	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	8	Tank Installed Date	11/01/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Positive Shutoff
Tag Number	5701	Spill Test Date		Piping Installed Date	11/01/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/17/2020	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible



Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	11/14/2016	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: SAMS CLUB  
4420 King Ave E  
Billings, MT 59101 Yellowstone

System Facility ID:60-15138

Facility Code: 30882  
Last Inspected On: 03/21/2022  
Operating Permit Renewal Date: 06/17/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sams West Inc7855508812

Operator Contact: Donald Elderbaum;Kevin Allen;Sandy Goff;Stacie Greer;Steven Hodge;Tyler Babb4062567277;4066980157;4792046131;5132574034;9375439552

Owner/Operator: Sams West Inc

- Debbie Nette, UST Class B Operator
- Donald Elderbaum, UST Class A Operator
- Donald Elderbaum, UST Class B Global Operator
- James Ray, UST Class B Global Operator
- Johney Miller, UST Class B Global Operator
- Joseph Khan, UST Class B Operator
- Kevin Allen, UST Class A Operator
- Kevin Allen, UST Class B Global Operator
- Rick Weaver, UST Class B Global Operator
- Sandy Goff, UST Class A Operator
- Sandy Goff, UST Class B Global Operator
- Stacie Greer, UST Class A Operator
- Stacie Greer, UST Class B Operator
- Steven Hodge, UST Class A Operator
- Steven Hodge, UST Class B Global Operator
- Tyler Babb, UST Class A Operator

Tank Code	01	Tank Age	15	Tank Installed Date	09/08/2009	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5210	Spill Test Date	03/17/2022	Piping Installed Date	05/20/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/17/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	03/17/2022	Line Tightness Test Date	03/17/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	03/17/2022			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	02	Tank Age	15	Tank Installed Date	09/08/2009	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5211	Spill Test Date	03/17/2022	Piping Installed Date	05/20/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/17/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	20000	ATG Test Date	03/17/2022	Line Tightness Test Date	03/17/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/17/2022			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	03	Tank Age	15	Tank Installed Date	09/08/2009	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5212	Spill Test Date	03/17/2022	Piping Installed Date	05/20/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/17/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	03/17/2022	Line Tightness Test Date	03/17/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	03/17/2022			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	04	Tank Age	15	Tank Installed Date	09/08/2009	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5213	Spill Test Date	03/17/2022	Piping Installed Date	05/20/2009	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	03/17/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	8000	ATG Test Date	03/17/2022	Line Tightness Test Date	03/17/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	03/17/2022			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
--	--	--------------------	------------	--	--	----------	--	--	--	--	--

Facility Summary in Yellowstone County in the City of Billings

Location: SHORT STOP  
804 Central Ave  
Billings, MT 59102-5818 Yellowstone

System Facility ID:56-06609

Facility Code: 30126  
Last Inspected On: 04/22/2022  
Operating Permit Renewal Date: 04/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Stockton Oil Co Billings4062456376

Operator Contact:

Owner/Operator: Montana Marketing and Development LLC

Owner/Operator: Stockton Oil Co Billings

Christopher Stockton, UST Class B Global Operator  
Joey McConnell , UST Class B Global Operator  
Joseph Stockton, UST Class B Global Operator

Tank Code	01	Tank Age	43	Tank Installed Date	03/26/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3754	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	43	Tank Installed Date	03/26/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3899	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type					
Tank Code	03	Tank Age	43	Tank Installed Date	03/26/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4920	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	04	Tank Age	43	Tank Installed Date	03/26/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4921	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	04/22/2022	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: SKYVIEW HIGH SCHOOL DIST 2  
1775 High Sierra Blvd  
Billings, MT 59105 Yellowstone

System Facility ID:56-10585

Facility Code: 30356  
Last Inspected On: 11/03/2021  
Operating Permit Renewal Date: 12/10/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings School District

Operator Contact: Megan Trevino

Owner/Operator: Billings School District

Megan Trevino, UST Class A Operator  
Michael Heinzman, UST Class B Global Operator

Tank Code	S1	Tank Age	37	Tank Installed Date	03/16/1987	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	448	Spill Test Date	11/03/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	11/03/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Heating Oil	PLLD Test Date		Tank/Piping CP Test Date	11/03/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	11/03/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/04/2021			ATG Type	Veeder Root/TLS-300				

Facility Summary in Yellowstone County in the City of Billings

Location: STOCKTON OIL CO 4TH AVE N  
1607 4th Ave N  
Billings, MT 59101-1522 Yellowstone

System Facility ID:56-04839

Facility Code: 29940  
Last Inspected On: 08/19/2022  
Operating Permit Renewal Date: 08/19/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Stockton Oil Co Billings4062456376

Operator Contact: Dan Stockton

Owner/Operator: Stockton Oil Co Billings

Christopher Stockton, UST Class B Global Operator  
Dan Stockton, UST Class A Operator  
Dan Stockton, UST Class B Global Operator  
Joseph Stockton, UST Class B Global Operator

Tank Code	11	Tank Age	30	Tank Installed Date	07/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number		Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product	Oil/Water Separator	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	01	Tank Age	44	Tank Installed Date	03/26/1980	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1988	Spill Test Date		Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	11/27/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



Tank Code	06	Tank Age	32	Tank Installed Date	04/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1989	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	11/27/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	32	Tank Installed Date	04/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1990	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	11/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	32	Tank Installed Date	04/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1991	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/26/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	32	Tank Installed Date	04/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1992	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	11/26/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	32	Tank Installed Date	04/01/1992	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1993	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	11/27/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: SUPERPUMPER 74  
1240 S 27th St  
Billings, MT 59101 Yellowstone

System Facility ID:56-00503

Facility Code: 29716  
Last Inspected On: 06/01/2022  
Operating Permit Renewal Date: 09/28/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc7018521194

Operator Contact: Justin Franjevic;Nancy Coen;Stephanie Zierke4062940867;4068551749;7204212140

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator  
Kim Hauck, UST Class B Operator  
Nancy Coen, UST Class A Operator  
Nancy Coen, UST Class B Operator  
Stephanie Zierke, UST Class A Operator

Tank Code	04	Tank Age	26	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1148	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/01/2022	Tank/Piping CP Test Date	05/28/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/01/2022	Line Tightness Test Date	05/19/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	26	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1149	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	06/01/2022	Tank/Piping CP Test Date	05/28/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/01/2022	Line Tightness Test Date	12/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	06/01/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	26	Tank Installed Date	05/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1150	Spill Test Date	06/01/2022	Piping Installed Date	04/01/2015	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/01/2015	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	06/01/2022	Tank/Piping CP Test Date	05/28/2013	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/01/2022	Line Tightness Test Date	03/16/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: SYSCO FOOD SERVICES OF MONTANA MONAD RD  
1509 Monad Rd  
Billings, MT 59101 Yellowstone

System Facility ID:56-03530

Facility Code: 29872  
Last Inspected On: 01/27/2023  
Operating Permit Renewal Date: 06/11/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sysco Food Services of Montana 4062471157

Operator Contact: Christopher Murphy;Jason O'Connor 4062004591

Owner/Operator: Sysco Food Services of Montana

Christopher Murphy, UST Class A Operator  
Christopher Murphy, UST Class B Global Operator  
Jason O'Connor, UST Class A Operator  
Jason O'Connor, UST Class B Operator

Tank Code	04	Tank Age	17	Tank Installed Date	12/27/2007	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5144	Spill Test Date		Piping Installed Date	07/10/2007	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	01/27/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/27/2023	Line Tightness Test Date	12/06/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	05	Tank Age	17	Tank Installed Date	12/27/2007	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5145	Spill Test Date		Piping Installed Date	07/10/2007	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	01/27/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	01/27/2023	Line Tightness Test Date	12/29/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: THE WAVE CAR WASH  
858 S 29th St W  
Billings, MT 59102-7449 Yellowstone

System Facility ID:56-13884

Facility Code: 30559  
Last Inspected On: 06/03/2022  
Operating Permit Renewal Date: 09/13/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: The Wave and Rocky Toppers

Operator Contact: Stacy Ott;Steven Ott4066562781

Owner/Operator: The Wave and Rocky Toppers

Stacy Ott, UST Class A Operator  
Stacy Ott, UST Class B Operator  
Steven Ott, UST Class A Operator

Tank Code	01	Tank Age	26	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3527	Spill Test Date	06/03/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/03/2022	Tank/Piping CP Test Date	06/03/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/03/2022	Line Tightness Test Date	04/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	26	Tank Installed Date	06/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3528	Spill Test Date	06/03/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/03/2022	Tank/Piping CP Test Date	06/03/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	06/03/2022	Line Tightness Test Date	04/19/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/03/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN AND COUNTRY HILL TOP  
523 Hilltop Rd  
Billings, MT 59105-2374 Yellowstone

System Facility ID:56-13731

Facility Code: 30458  
Last Inspected On: 07/08/2022  
Operating Permit Renewal Date: 12/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town and Country Supply Association 4066286314

Operator Contact: Karissa Lueck;Mark Heimbichner;Tammi Pritchett;Town and Country Supply Association 4066286314

Owner/Operator: Town and Country Supply Association

Karissa Lueck, UST Class A Operator  
Karissa Lueck, UST Class B Operator  
Mark Heimbichner, UST Class A Operator  
Tammi Pritchett, UST Class A Operator  
Tammi Pritchett, UST Class B Operator

Tank Code	01	Tank Age	28	Tank Installed Date	07/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3419	Spill Test Date	07/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	07/08/2022	Tank/Piping CP Test Date	07/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/08/2022	Line Tightness Test Date	05/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	07/08/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	28	Tank Installed Date	07/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3420	Spill Test Date	07/08/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	07/08/2022	Tank/Piping CP Test Date	07/08/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/08/2022	Line Tightness Test Date	05/03/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	07/08/2022			ATG Type	Gilbarco/EMC Basic				
Tank Code	03	Tank Age	10	Tank Installed Date	06/30/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5509	Spill Test Date	07/08/2022	Piping Installed Date	06/10/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/08/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	4000	ATG Test Date	07/08/2022	Line Tightness Test Date	05/03/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	07/08/2022			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				



Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS #12  
3415 Grand Ave  
Billings, MT 59102 Yellowstone

System Facility ID:60-15328

Facility Code: 31024  
Last Inspected On: 01/25/2024  
Operating Permit Renewal Date: 06/04/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings 12 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Billings 12 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Operator

Tank Code	01	Tank Age	5	Tank Installed Date	03/01/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5884	Spill Test Date	08/25/2023	Piping Installed Date	03/01/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	01/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	5	Tank Installed Date	06/27/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5885	Spill Test Date	08/25/2023	Piping Installed Date	06/27/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	01/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	03	Tank Age	5	Tank Installed Date	06/27/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5886	Spill Test Date	09/19/2023	Piping Installed Date	06/27/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	01/25/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	04	Tank Age	5	Tank Installed Date	06/27/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5887	Spill Test Date	08/25/2023	Piping Installed Date	06/27/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	01/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	7000	ATG Test Date	01/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	5	Tank Installed Date	06/27/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5888	Spill Test Date	08/25/2023	Piping Installed Date	06/27/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	01/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	5	Tank Installed Date	06/27/2019	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5889	Spill Test Date	08/25/2023	Piping Installed Date	06/27/2019	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/15/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	01/25/2024	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date	01/25/2024	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	08/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS #8  
3969 Grand Ave  
Billings, MT 59102-7512 Yellowstone

System Facility ID:56-13741

Facility Code: 30459  
Last Inspected On: 04/02/2024  
Operating Permit Renewal Date: 11/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings 8 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Billings 8 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2013	Spill Test Date	07/07/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/24/2023	Tank/Piping CP Test Date	12/22/2011	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2014	Spill Test Date	01/25/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/24/2023	Tank/Piping CP Test Date	12/22/2011	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	08/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	03	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2015	Spill Test Date	07/07/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/24/2023	Tank/Piping CP Test Date	12/22/2011	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2016	Spill Test Date	01/25/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/24/2023	Tank/Piping CP Test Date	12/22/2011	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/25/2024			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	28	Tank Installed Date	09/01/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2017	Spill Test Date	01/25/2024	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/24/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	08/24/2023	Tank/Piping CP Test Date	12/22/2011	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/24/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/24/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS 11  
450 Main St  
Billings, MT 59105 Yellowstone

System Facility ID:60-15297

Facility Code: 31001  
Last Inspected On: 03/08/2024  
Operating Permit Renewal Date: 04/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings 11 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Billings 11 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Operator

Tank Code	01	Tank Age	7	Tank Installed Date	09/12/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5709	Spill Test Date	10/05/2023	Piping Installed Date	09/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/05/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	25000	ATG Test Date	10/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	7	Tank Installed Date	09/12/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5710	Spill Test Date	10/05/2023	Piping Installed Date	09/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/05/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	10/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	03	Tank Age	7	Tank Installed Date	09/12/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5711	Spill Test Date	10/05/2023	Piping Installed Date	09/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/05/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	7	Tank Installed Date	09/12/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5712	Spill Test Date	10/05/2023	Piping Installed Date	09/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/05/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	7000	ATG Test Date	10/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	7	Tank Installed Date	09/12/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5713	Spill Test Date	10/05/2023	Piping Installed Date	09/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/05/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	10/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	7	Tank Installed Date	09/12/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	5714	Spill Test Date	10/05/2023	Piping Installed Date	09/12/2017	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2017	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	10/05/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	10/05/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	10/05/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	7	Tank Installed Date	09/12/2017	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	5715	Spill Test Date		Piping Installed Date	09/12/2017	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2017	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	7000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring;Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					



Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS 13  
3975 King Avenue West  
Billings, MT 59102 Yellowstone

System Facility ID:00-32484

Facility Code: 32484  
Last Inspected On: 03/08/2024  
Operating Permit Renewal Date: 06/26/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings 13 RE, LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Billings 13 RE, LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Operator

Tank Code	01	Tank Age	2	Tank Installed Date	12/06/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6080	Spill Test Date	12/16/2022	Piping Installed Date	12/06/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	12/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/15/2022			ATG Type					
Tank Code	02	Tank Age	2	Tank Installed Date	12/06/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6081	Spill Test Date	12/16/2022	Piping Installed Date	12/06/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/15/2022			ATG Type					
Tank Code	03	Tank Age	2	Tank Installed Date	12/06/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	6082	Spill Test Date	12/16/2022	Piping Installed Date	12/06/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	12/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/15/2022			ATG Type					
Tank Code	04	Tank Age	2	Tank Installed Date	12/06/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6083	Spill Test Date	12/16/2022	Piping Installed Date	12/06/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	7000	ATG Test Date	12/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/15/2022			ATG Type					
Tank Code	05	Tank Age	2	Tank Installed Date	12/06/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6084	Spill Test Date	12/16/2022	Piping Installed Date	12/06/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	7000	ATG Test Date	12/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/15/2022			ATG Type					
Tank Code	06	Tank Age	2	Tank Installed Date	12/06/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6085	Spill Test Date	12/16/2022	Piping Installed Date	12/06/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	12/15/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	23000	ATG Test Date	12/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date	12/15/2022			ATG Type					
Tank Code	07	Tank Age	2	Tank Installed Date	12/06/2022	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6086	Spill Test Date	12/16/2022	Piping Installed Date	12/06/2022	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date	12/15/2022	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	12/15/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP INC BILLINGS 1  
1028 US Hwy 87 E  
Billings, MT 59101-6658 Yellowstone

System Facility ID:56-00767

Facility Code: 29729  
Last Inspected On: 03/11/2024  
Operating Permit Renewal Date: 11/08/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings 1 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Billings 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	07	Tank Age	28	Tank Installed Date	10/02/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2665	Spill Test Date	07/31/2023	Piping Installed Date	07/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/08/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/31/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	28	Tank Installed Date	10/02/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2666	Spill Test Date	07/31/2023	Piping Installed Date	02/15/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/08/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/31/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	09	Tank Age	28	Tank Installed Date	10/02/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2667	Spill Test Date	07/31/2023	Piping Installed Date	02/15/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/08/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/31/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	25	Tank Installed Date	02/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	3921	Spill Test Date	07/31/2023	Piping Installed Date	04/20/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/08/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	07/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/31/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	07/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	28	Tank Installed Date	10/02/1996	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4583	Spill Test Date	07/31/2023	Piping Installed Date	07/11/2013	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/08/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/31/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/31/2023	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/31/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP INC BILLINGS 3  
3150 King Ave W  
Billings, MT 59102-6438 Yellowstone

System Facility ID:60-15023

Facility Code: 30809  
Last Inspected On: 02/05/2024  
Operating Permit Renewal Date: 07/21/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings 3 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Billings 3 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	02	Tank Age	18	Tank Installed Date	04/01/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5056	Spill Test Date	11/03/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date	05/01/2006	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/24/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	18	Tank Installed Date	04/06/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5057	Spill Test Date	05/24/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date	05/01/2006	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/24/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Tank Code	04	Tank Age	18	Tank Installed Date	04/14/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5058	Spill Test Date	05/24/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/24/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	18	Tank Installed Date	04/06/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5059	Spill Test Date	05/24/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date	05/01/2006	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/24/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	18	Tank Installed Date	04/06/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5060	Spill Test Date	11/03/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date	05/01/2006	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	05/24/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	01	Tank Age	18	Tank Installed Date	04/14/2006	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5062	Spill Test Date	11/03/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/24/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/24/2021	Line Tightness Test Date	05/01/2006	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350				



Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP INC BILLINGS 4  
2711 N Frontage Rd  
Billings, MT 59101-7327 Yellowstone

System Facility ID:60-15104

Facility Code: 30863  
Last Inspected On: 02/05/2024  
Operating Permit Renewal Date: 07/21/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Billings 4 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Billings 4 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	16	Tank Installed Date	12/15/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5180	Spill Test Date	05/06/2021	Piping Installed Date	05/27/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/06/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	30000	ATG Test Date	07/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	16	Tank Installed Date	12/15/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5181	Spill Test Date	06/29/2021	Piping Installed Date	05/27/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/06/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	30000	ATG Test Date	07/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	03	Tank Age	16	Tank Installed Date	12/15/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5182	Spill Test Date	02/23/2023	Piping Installed Date	05/27/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/06/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	30000	ATG Test Date	07/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	02/23/2023			ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	16	Tank Installed Date	12/15/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5183	Spill Test Date	01/24/2024	Piping Installed Date	05/27/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/16/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	22000	ATG Test Date	07/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	16	Tank Installed Date	12/18/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5184	Spill Test Date	05/06/2021	Piping Installed Date	05/27/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/06/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	16	Tank Installed Date	12/18/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5185	Spill Test Date	06/29/2021	Piping Installed Date	05/27/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/06/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	Yes
Capacity	22000	ATG Test Date	07/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	16	Tank Installed Date	12/15/2008	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5186	Spill Test Date	05/06/2021	Piping Installed Date	05/27/2008	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/06/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/06/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/07/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/Gilbarco-Veeder Root/TLS-450				
Tank Code	08	Tank Age	15	Tank Installed Date	05/01/2009	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	5353	Spill Test Date		Piping Installed Date	04/10/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: TRAILHEAD INN  
5500 Midland Rd  
Billings, MT 59101-6321 Yellowstone

System Facility ID:56-14103

Facility Code: 30746  
Last Inspected On: 05/03/2022  
Operating Permit Renewal Date: 06/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Terrapin Hospitality Properties One LLC2162150557

Operator Contact: Gary Giangreco4086919074

Owner/Operator: Terrapin Hospitality Properties One LLC

Gary Giangreco, UST Class A Operator  
Gary Giangreco, UST Class B Global Operator

Tank Code	02	Tank Age	20	Tank Installed Date	03/12/2004	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4887	Spill Test Date	05/03/2022	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/20/2016	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	05/03/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	500	ATG Test Date	05/03/2022	Line Tightness Test Date	05/03/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/03/2022			ATG Type	EMCO Electronics/EECO 1500				

Facility Summary in Yellowstone County in the City of Billings

Location: UNFI DISTRIBUTION COMPANY LLC - BILLINGS  
1629 King Ave W  
Billings, MT 59102-6448 Yellowstone

System Facility ID:56-06097

Facility Code: 30085  
Last Inspected On: 04/01/2022  
Operating Permit Renewal Date: 08/28/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	UNFI DISTRIBUTION COMPANY LLC	5039362348
Operator Contact:	Jeffrey Lindell;Mike Frost;Scott Combs	4062471523

Owner/Operator: UNFI DISTRIBUTION COMPANY LLC

Jeffrey Lindell, UST Class A Operator  
John Beadle, UST Class B Operator  
Mike Frost, UST Class A Operator  
Scott Combs, UST Class A Operator  
Scott Combs, UST Class B Global Operator  
Steve Schilling, UST Class B Operator

Tank Code	04	Tank Age	26	Tank Installed Date	09/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1867	Spill Test Date	03/20/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/03/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	04/01/2022	Tank/Piping CP Test Date	09/24/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/01/2022	Line Tightness Test Date	04/01/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	26	Tank Installed Date	09/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1868	Spill Test Date	03/20/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/03/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	04/01/2022	Tank/Piping CP Test Date	09/24/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date	04/01/2022	Line Tightness Test Date	04/01/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: UNITED PARCEL SERVICES BILLINGS  
1830 Lampman Dr  
Billings, MT 59102-6442 Yellowstone

System Facility ID:56-04542

Facility Code: 29919  
Last Inspected On: 12/02/2021  
Operating Permit Renewal Date: 03/22/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: United Parcel Service Inc Seattle

Operator Contact: Erin Englert;Kaytee Villafrancaa;Robert Counts;Russell Stott;Treair Smith2066216286;2066216380;5039787678

Owner/Operator: United Parcel Service Inc Seattle

- Erin Englert, UST Class A Operator
- Erin Englert, UST Class B Operator
- Kaytee Villafrancaa, UST Class A Operator
- Kaytee Villafrancaa, UST Class B Global Operator
- Robert Counts, UST Class A Operator
- Robert Counts, UST Class B Operator
- Russell Stott, UST Class A Operator
- Russell Stott, UST Class B Operator
- Treair Smith, UST Class A Operator
- Treair Smith, UST Class B Global Operator

Tank Code	05	Tank Age	31	Tank Installed Date	07/20/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2183	Spill Test Date	04/05/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/05/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/05/2022	Line Tightness Test Date	04/05/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/05/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	31	Tank Installed Date	07/20/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	2184	Spill Test Date	04/05/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/27/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	Yes
Capacity	12000	ATG Test Date	04/05/2022	Line Tightness Test Date	04/27/2021	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/05/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



Facility Summary in Yellowstone County in the City of Billings

Location: US FOODS INC. 9J - BILLINGS  
802 Parkway Ln  
Billings, MT 59101-4651 Yellowstone

System Facility ID:56-06132

Facility Code: 30089  
Last Inspected On: 06/16/2022  
Operating Permit Renewal Date: 06/16/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: US Foods, Inc. 4022125976

Operator Contact: James Pavelka;US Foods. Inc, J9 - Billings;Jeff Brent;Rick Hansen;Rod Ostman;Stace Hovland 4062387800;4062387810;4066960810;4068395990

Owner/Operator: US Foods, Inc.

- David Lake, UST Class B Operator
- James Pavelka, UST Class A Operator
- James Pavelka, UST Class B Operator
- Jeff Brent, UST Class A Operator
- Jeff Brent, UST Class B Operator
- Rick Hansen, UST Class A Operator
- Rod Ostman, UST Class A Operator
- Stace Hovland, UST Class A Operator
- Stace Hovland, UST Class B Global Operator
- Stace Hovland, UST Class B Operator

Tank Code	05	Tank Age	31	Tank Installed Date	11/02/1993	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1781	Spill Test Date	06/02/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	06/16/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	06/02/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/02/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: USF REDDAWAY INC  
833 Mallowney Ln  
Billings, MT 59101-4654 Yellowstone

System Facility ID:56-01340

Facility Code: 29768  
Last Inspected On: 11/29/2021  
Operating Permit Renewal Date: 12/06/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Halfway Holdings LLC4062599360

Operator Contact: Paul Heath;EnergiSystems LLC4068484357;4062241856

Owner/Operator: Halfway Holdings LLC

Kimberly Allbright Heath, UST Class B Operator  
Paul Heath, UST Class A Operator

Tank Code	03	Tank Age	31	Tank Installed Date	08/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3154	Spill Test Date	11/29/2021	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	04/30/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	20000	ATG Test Date	11/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/29/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: WARRENS MARKET AND DELI INC  
3189 King Ave W  
Billings, MT 59102-7466 Yellowstone

System Facility ID:56-10075

Facility Code: 30344  
Last Inspected On: 02/27/2020  
Operating Permit Renewal Date: 02/27/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Stockton Oil Co Billings4062456376

Operator Contact: Johnnathon Harvey;Paul DiLorenzo4063711700;4068392399

Owner/Operator: Stockton Oil Co Billings

Christopher Stockton, UST Class B Global Operator  
Johnnathon Harvey, UST Class A Operator  
Johnnathon Harvey, UST Class B Operator  
Joseph Stockton, UST Class B Global Operator  
Paul DiLorenzo, UST Class A Operator

Tank Code	01	Tank Age	37	Tank Installed Date	01/13/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3834	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/28/2017	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	02/28/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	02	Tank Age	37	Tank Installed Date	01/13/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3835	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/28/2017	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	6000	ATG Test Date		Line Tightness Test Date	02/28/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	03	Tank Age	37	Tank Installed Date	01/13/1987	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3836	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/28/2017	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	02/28/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Billings

Location: WELLS FARGO BANK OPERATIONS CENTER  
2324 Overland Ave  
Billings, MT 59102-6401 Yellowstone

System Facility ID:56-13992

Facility Code: 30653  
Last Inspected On: 11/28/2022  
Operating Permit Renewal Date: 12/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wells Fargo Bank Billings Operations Center

Operator Contact: Timothy McCurdy4062001778

Owner/Operator: Wells Fargo Bank Billings Operations Center

Greg Amos, UST Class B Operator  
Richard Brodston, UST Class B Operator  
Stan Barr, UST Class B Global Operator  
Stan Barr, UST Class B Operator  
Timothy McCurdy, UST Class A Operator  
Trevor Mill, UST Class B Operator

Tank Code	01	Tank Age	24	Tank Installed Date	09/01/2000	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4279	Spill Test Date	11/18/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/18/2022	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/30/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/18/2022	Line Tightness Test Date	11/18/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	24	Tank Installed Date	09/01/2000	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4280	Spill Test Date	11/18/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/18/2022	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/30/2008	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No

Capacity	8000	ATG Test Date	11/18/2022	Line Tightness Test Date	11/18/2022	Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	11/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: WELLS FARGO CENTER  
175 N 27th St  
Billings, MT Yellowstone

System Facility ID:56-13972

Facility Code: 30634  
Last Inspected On: 08/07/2023  
Operating Permit Renewal Date: 08/20/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: S F H II LLC4066510603

Operator Contact: John Schafnitz4066510603

Owner/Operator: S F H II LLC

John Schafnitz, UST Class A Operator  
John Schafnitz, UST Class B Operator

Tank Code	02	Tank Age	24	Tank Installed Date	11/01/2000	Tank Material	Cathodically Protected Steel	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	4231	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/14/2020	Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	400	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Pneumercator/Other				

Facility Summary in Yellowstone County in the City of Billings

Location: WILD TORNADO  
1225 Mallowney Ln  
Billings, MT 59101-6301 Yellowstone

System Facility ID:56-06963

Facility Code: 30148  
Last Inspected On: 09/16/2022  
Operating Permit Renewal Date: 11/30/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: OED LLC4066706097

Operator Contact: Jay Doucette;OED LLC4066706097;4066706097

Owner/Operator: OED LLC

Jay Doucette, UST Class A Operator  
Jay Doucette, UST Class B Operator

Tank Code	05	Tank Age	21	Tank Installed Date	05/09/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4836	Spill Test Date	01/14/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date	08/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	01/14/2022	Line Tightness Test Date	09/15/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/14/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	21	Tank Installed Date	05/09/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4837	Spill Test Date	01/14/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date	08/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	01/14/2022	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/14/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	21	Tank Installed Date	05/09/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4838	Spill Test Date	01/14/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No



Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date	08/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	01/14/2022	Line Tightness Test Date	09/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/14/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	21	Tank Installed Date	05/09/2003	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4839	Spill Test Date	01/14/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date	08/25/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	01/14/2022	Line Tightness Test Date	09/14/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	01/14/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Billings

Location: WILSON DUNHAM SERVICE INC  
2511 1st Ave S  
Billings, MT 59101-4220 Yellowstone

System Facility ID:56-07756

Facility Code: 30197  
Last Inspected On: 05/12/2017  
Operating Permit Renewal Date: 06/03/2020

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Wilson Dunham Petroleum Supply 4062520880

Operator Contact: Joan Erickson;William Dunham 4062520880;4067247335

Owner/Operator: Wilson Dunham Petroleum Supply

Joan Erickson, UST Class A Operator  
Joan Erickson, UST Class B Operator  
William Dunham, UST Class A Operator  
William Dunham, UST Class B Global Operator

Tank Code	05	Tank Age	34	Tank Installed Date	11/16/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2277	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/12/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	34	Tank Installed Date	11/16/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2278	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/12/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.1;ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	04/23/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	34	Tank Installed Date	11/16/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2279	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/12/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.1;ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	04/23/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	34	Tank Installed Date	11/16/1990	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	2280	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/12/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.1;ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	04/23/2017	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: YELLOWSTONE COUNTY PUBLIC WORKS DEPT  
3321 King Ave E  
Billings, MT 59101 Yellowstone

System Facility ID:56-03658

Facility Code: 29878  
Last Inspected On: 09/27/2018  
Operating Permit Renewal Date: 09/29/2021

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Yellowstone County Public Works Dept

Operator Contact: Greg Fisher4062080547

Owner/Operator: Yellowstone County Public Works Dept

Greg Fisher, UST Class A Operator  
Greg Fisher, UST Class B Operator

Tank Code	06	Tank Age	25	Tank Installed Date	06/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4092	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Permanently Out of Use	MLLD Test Date		Sump Tightness Test Date	09/27/2018	Catastrophic L.D Type 3.0	Not Required	Piping Type	U.S. Suction	CP Met Types	Galvanic
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date	09/27/2018	Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 51  
1544 Broadwater Ave  
Billings, MT 59102-5002 Yellowstone

System Facility ID:56-00050

Facility Code: 29683  
Last Inspected On: 02/14/2024  
Operating Permit Renewal Date: 07/14/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley5095357701

Operator Contact: Ian Johnstone;Jim Alford;Nicholas Merritt4066330023;5095367418

Owner/Operator: CHS Inc Spokane Valley

Darcy Ziegler, UST Class B Operator  
Ian Johnstone, UST Class A Operator  
Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Global Operator  
Nicholas Merritt, UST Class A Operator  
Nicholas Merritt, UST Class B Global Operator  
Nicholas Merritt, UST Class B Operator

Tank Code	04	Tank Age	27	Tank Installed Date	10/30/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3074	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/23/2015	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	27	Tank Installed Date	10/30/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3075	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/23/2015	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	27	Tank Installed Date	10/30/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3076	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/23/2015	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date	02/05/2018	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 52  
1201 Central Ave  
Billings, MT 59102-5528 Yellowstone

Facility Code: 30290  
Last Inspected On: 05/10/2022  
System Facility ID:56-08903  
Operating Permit Renewal Date: 05/15/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley 5095357701

Operator Contact: Jim Alford;Sean Hurley 5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Global Operator  
Sean Hurley, UST Class A Operator

Tank Code	06	Tank Age	14	Tank Installed Date	11/22/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5270	Spill Test Date	08/31/2021	Piping Installed Date	08/06/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	08/04/2022	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/04/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	08/04/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	14	Tank Installed Date	11/22/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5271	Spill Test Date	08/31/2021	Piping Installed Date	08/06/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	08/04/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	7000	ATG Test Date	08/04/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	08/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	14	Tank Installed Date	11/22/2010	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5272	Spill Test Date	08/31/2021	Piping Installed Date	08/06/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	08/04/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	08/04/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	08/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 53  
2975 Grand Ave  
Billings, MT 59102 Yellowstone

System Facility ID:56-13245

Facility Code: 30433  
Last Inspected On: 04/02/2021  
Operating Permit Renewal Date: 07/14/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley 5095357701

Operator Contact: Jim Alford;Nicholas Merritt 4066330023;5095367418

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Global Operator  
Nicholas Merritt, UST Class A Operator  
Nicholas Merritt, UST Class B Global Operator  
Nicholas Merritt, UST Class B Operator

Tank Code	01	Tank Age	31	Tank Installed Date	09/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	592	Spill Test Date	08/26/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/21/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				
Tank Code	02	Tank Age	31	Tank Installed Date	09/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	593	Spill Test Date	08/26/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/21/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Tank Code	03	Tank Age	31	Tank Installed Date	09/01/1993	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	594	Spill Test Date	08/26/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/21/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 54  
151 Rosebud Ln  
Billings, MT 59101-6503 Yellowstone

System Facility ID:56-08208

Facility Code: 30220  
Last Inspected On: 04/04/2024  
Operating Permit Renewal Date: 06/25/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley 5095357701

Operator Contact: Jim Alford;Nicholas Merritt;Pete Nussbaum;Tom Savas 4066330023;5095367418

Owner/Operator: CHS Inc Spokane Valley

- Chuck Crane, UST Class B Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Karina Serrano, UST Class B Global Operator
- Nicholas Merritt, UST Class A Operator
- Nicholas Merritt, UST Class B Global Operator
- Nicholas Merritt, UST Class B Operator
- Pete Nussbaum, UST Class A Operator
- Tom Savas, UST Class A Operator

Tank Code	07	Tank Age	10	Tank Installed Date	09/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5525	Spill Test Date	09/01/2021	Piping Installed Date	11/03/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	17000	ATG Test Date		Line Tightness Test Date	02/13/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/01/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	08	Tank Age	10	Tank Installed Date	09/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5526	Spill Test Date	09/01/2021	Piping Installed Date	11/03/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	02/13/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/01/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	09	Tank Age	10	Tank Installed Date	09/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5527	Spill Test Date	09/01/2021	Piping Installed Date	11/03/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	17000	ATG Test Date		Line Tightness Test Date	02/13/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/01/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	10	Tank Age	10	Tank Installed Date	09/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5528	Spill Test Date	09/01/2021	Piping Installed Date	11/03/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	02/13/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/01/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	11	Tank Age	10	Tank Installed Date	09/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	5529	Spill Test Date	09/01/2021	Piping Installed Date	11/03/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	25000	ATG Test Date		Line Tightness Test Date	02/13/2015	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	09/01/2021			ATG Type	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450				
Tank Code	12	Tank Age	10	Tank Installed Date	09/01/2014	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5530	Spill Test Date		Piping Installed Date	11/03/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date	11/01/2014	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type	Veeder Root/TLS-450				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 55  
236 Main St  
Billings, MT 59105-3232 Yellowstone

System Facility ID:56-08904

Facility Code: 30291  
Last Inspected On: 04/03/2024  
Operating Permit Renewal Date: 07/11/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley5095357701

Operator Contact: Ian Johnstone;Jim Alford5095367418

Owner/Operator: CHS Inc Spokane Valley

- Chuck Crane, UST Class B Operator
- Darcy Ziegler, UST Class B Operator
- Ian Johnstone, UST Class A Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Karina Serrano, UST Class B Global Operator
- Nicholas Merritt, UST Class B Global Operator

Tank Code	01	Tank Age	42	Tank Installed Date	10/03/1982	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	589	Spill Test Date	09/02/2021	Piping Installed Date	10/13/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/08/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/21/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	10/13/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/02/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	42	Tank Installed Date	10/03/1982	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	590	Spill Test Date	09/02/2021	Piping Installed Date	10/13/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/08/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/21/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	10/13/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/02/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	42	Tank Installed Date	10/03/1982	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	591	Spill Test Date	09/02/2021	Piping Installed Date	10/13/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/08/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/21/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	10/13/2014	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	09/02/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 56  
16 Shiloh Rd  
Billings, MT 59106 Yellowstone

System Facility ID:56-01664

Facility Code: 29782  
Last Inspected On: 02/14/2024  
Operating Permit Renewal Date: 07/09/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley5095357701

Operator Contact: Jim Alford;Sean Hurley5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator  
Jim Alford, UST Class B Global Operator  
Nicholas Merritt, UST Class B Global Operator  
Nicholas Merritt, UST Class B Operator  
Sean Hurley, UST Class A Operator

Tank Code	01	Tank Age	40	Tank Installed Date	12/31/1984	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4344	Spill Test Date	02/14/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/03/2023	Tank/Piping CP Test Date	02/14/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/03/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	40	Tank Installed Date	12/31/1984	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4345	Spill Test Date	02/14/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/03/2023	Tank/Piping CP Test Date	02/14/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/03/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No



		Overfill Test Date	08/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	35	Tank Installed Date	11/10/1989	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	4346	Spill Test Date	02/14/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/03/2023	Tank/Piping CP Test Date	02/14/2024	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/03/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	08/03/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 57  
1046 N 27th St  
Billings, MT 59101-0710 Yellowstone

System Facility ID:56-01665

Facility Code: 29783  
Last Inspected On: 02/14/2024  
Operating Permit Renewal Date: 07/11/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley 5095357701

Operator Contact: Ian Johnstone;Jim Alford;Tom Savas 5095367418

Owner/Operator: CHS Inc Spokane Valley

- Chuck Crane, UST Class B Operator
- Don Thoreson, UST Class B Global Operator
- Ian Johnstone, UST Class A Operator
- Ian Johnstone, UST Class B Global Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Katherine Warmus, UST Class B Global Operator
- Nicholas Merritt, UST Class B Global Operator
- Robert Hays, UST Class B Operator
- Tom Savas, UST Class A Operator

Tank Code	03	Tank Age	26	Tank Installed Date	01/28/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3080	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/08/2009	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	26	Tank Installed Date	01/28/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3081	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/08/2009	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 58  
610 Wicks Ln  
Billings, MT 59105 Yellowstone

System Facility ID:56-08209

Facility Code: 30221  
Last Inspected On: 01/05/2024  
Operating Permit Renewal Date: 03/17/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley 5095357701

Operator Contact: Jim Alford;Nicholas Merritt;Sean Hurley;Tom Savas 4066330023;5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

- Chuck Crane, UST Class B Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Karina Serrano, UST Class B Global Operator
- Nicholas Merritt, UST Class A Operator
- Nicholas Merritt, UST Class B Operator
- Paul Workin, UST Class B Global Operator
- Sean Hurley, UST Class A Operator
- Tom Savas, UST Class A Operator

Tank Code	04	Tank Age	25	Tank Installed Date	01/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4256	Spill Test Date	08/30/2021	Piping Installed Date	11/20/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/26/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/05/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	25	Tank Installed Date	01/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4257	Spill Test Date	08/30/2021	Piping Installed Date	11/20/2007	Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/26/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/05/2024			ATG Type	Gilbarco/TLS-350				
Tank Code	06	Tank Age	25	Tank Installed Date	01/01/1999	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	4258	Spill Test Date	08/30/2021	Piping Installed Date	11/20/2007	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/26/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	01/05/2024			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Broadview

Location: BROADVIEW OASIS LLC  
16437 Iowa Ave  
Broadview, MT 59015 Yellowstone

System Facility ID:56-02373

Facility Code: 29819  
Last Inspected On: 10/19/2023  
Operating Permit Renewal Date: 02/24/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: BROADVIEW OASIS LLC6609985690

Operator Contact: Jody McCloud4066721698

Owner/Operator: BROADVIEW OASIS LLC

Jody McCloud, UST Class A Operator

Jody McCloud, UST Class B Operator

Tank Code	06	Tank Age	28	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3410	Spill Test Date	10/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/03/2023	Line Tightness Test Date	07/31/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	28	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	3411	Spill Test Date	10/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/03/2023	Line Tightness Test Date	07/31/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	28	Tank Installed Date	05/01/1996	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	3412	Spill Test Date	10/19/2023	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/03/2023	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/03/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/03/2023	Line Tightness Test Date	07/31/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/02/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Custer

Location: SURE STOP  
523 2nd Ave  
Custer, MT 59024 Yellowstone

System Facility ID:56-05291

Facility Code: 30014  
Last Inspected On: 12/13/2021  
Operating Permit Renewal Date: 04/30/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Valley Farmers Supply

Operator Contact:

Owner/Operator: Valley Farmers Supply

Trina McClure, UST Class B Operator

Tank Code	S5	Tank Age	25	Tank Installed Date	07/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4079	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	11/04/2021	Sump Tightness Test Date	06/10/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S6	Tank Age	25	Tank Installed Date	07/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4080	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	11/04/2021	Sump Tightness Test Date	06/10/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S7	Tank Age	25	Tank Installed Date	07/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4081	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes



Tank Status	Currently in Use	MLLD Test Date	11/04/2021	Sump Tightness Test Date	06/10/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	12000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	S8	Tank Age	25	Tank Installed Date	07/01/1999	Tank Material	Unknown	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	4082	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date	11/04/2021	Sump Tightness Test Date	06/10/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	07/28/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/04/2021	Line Tightness Test Date	11/04/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Huntley

Location: HUNTLEY EXPRESSWAY  
135 Northern Ave  
Huntley, MT 59037-9101 Yellowstone

Facility Code: 29722  
Last Inspected On: 01/26/2023  
System Facility ID:56-00627  
Operating Permit Renewal Date: 06/26/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Set Five LLC Big Sky 4066402860

Operator Contact: Abigail Onstad;Greg Haines;William Woods 4065902667

Owner/Operator: Set Five LLC Big Sky

Abigail Onstad, UST Class A Operator  
Abigail Onstad, UST Class B Operator  
Greg Haines, UST Class A Operator  
Greg Haines, UST Class B Global Operator  
William Woods, UST Class A Operator  
William Woods, UST Class B Operator

Tank Code	03	Tank Age	26	Tank Installed Date	11/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3660	Spill Test Date	07/26/2022	Piping Installed Date	06/17/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date	05/06/2022	Line Tightness Test Date	02/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	26	Tank Installed Date	11/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3661	Spill Test Date	07/26/2022	Piping Installed Date	06/17/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	01/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No

Capacity	5000	ATG Test Date	05/06/2022	Line Tightness Test Date	02/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	26	Tank Installed Date	11/01/1998	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	3662	Spill Test Date	05/09/2022	Piping Installed Date	06/17/2008	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	01/26/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/06/2022	Line Tightness Test Date	02/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/06/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: CONOMART SUPERSTORE 2  
411 E 1st St  
Laurel, MT 59044 Yellowstone

System Facility ID:56-06966

Facility Code: 30151  
Last Inspected On: 02/13/2024  
Operating Permit Renewal Date: 06/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc7018521194

Operator Contact: Justin Franjevic;Nancy Coen;Parkland USA Corporation;Stephanie Zierke4062940867;4068551749;7204212140;7018521194

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator  
Linda Degele, UST Class B Operator  
Nancy Coen, UST Class A Operator  
Nancy Coen, UST Class B Operator  
Stephanie Zierke, UST Class A Operator

Tank Code	01	Tank Age	47	Tank Installed Date	04/22/1977	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1175	Spill Test Date	02/13/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	06/15/2023	Tank/Piping CP Test Date	06/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/15/2023	Line Tightness Test Date	05/22/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	47	Tank Installed Date	04/22/1977	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1176	Spill Test Date	02/13/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/15/2023	Tank/Piping CP Test Date	06/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/15/2023	Line Tightness Test Date	05/24/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	08/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	47	Tank Installed Date	04/22/1977	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1177	Spill Test Date	02/13/2024	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	06/15/2023	Tank/Piping CP Test Date	06/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/15/2023	Line Tightness Test Date	05/24/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/25/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: CONOMART SUPERSTORE 3  
519 W Main St  
Laurel, MT 59044-2926 Yellowstone

Facility Code: 30150  
Last Inspected On: 02/13/2024  
System Facility ID:56-06965  
Operating Permit Renewal Date: 06/03/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Superpumper Inc7018521194

Operator Contact: Justin Franjevic;Nancy Coen;Stephanie Zierke4062940867;4068551749;7204212140

Owner/Operator: Superpumper Inc

Jewell Borchardt, UST Class B Operator  
Justin Franjevic, UST Class A Operator  
Nancy Coen, UST Class A Operator  
Nancy Coen, UST Class B Operator  
Stephanie Zierke, UST Class A Operator

Tank Code	04	Tank Age	29	Tank Installed Date	10/17/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1172	Spill Test Date	02/13/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/15/2023	Tank/Piping CP Test Date	06/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/15/2023	Line Tightness Test Date	01/08/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/15/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	05	Tank Age	29	Tank Installed Date	10/17/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1173	Spill Test Date	02/13/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/15/2023	Tank/Piping CP Test Date	06/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/15/2023	Line Tightness Test Date	06/01/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No

		Overfill Test Date	06/15/2023			ATG Type	Gilbarco/EMC Basic				
Tank Code	06	Tank Age	29	Tank Installed Date	10/17/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1174	Spill Test Date	02/13/2024	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/15/2023	Tank/Piping CP Test Date	06/15/2023	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/15/2023	Line Tightness Test Date	06/01/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/15/2023			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Yellowstone County in the City of Laurel

Location: FASTLANE C STORES  
815 E Main St  
Laurel, MT 59044-2810 Yellowstone

Facility Code: 30002  
Last Inspected On: 03/31/2023  
System Facility ID:56-05083  
Operating Permit Renewal Date: 09/25/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Service Valcon LLC4062940865

Operator Contact: Dan Foos4066286204

Owner/Operator: City Service Valcon LLC

Dan Foos, UST Class A Operator  
Dan Foos, UST Class B Operator  
Rochelle Foos, UST Class B Operator

Tank Code	01	Tank Age	49	Tank Installed Date	10/01/1975	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3831	Spill Test Date	05/29/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/29/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/21/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/29/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	49	Tank Installed Date	10/01/1975	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3832	Spill Test Date	05/29/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/29/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5200	ATG Test Date		Line Tightness Test Date	05/23/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/29/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				



Tank Code	03	Tank Age	49	Tank Installed Date	10/01/1975	Tank Material	Bare Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	3833	Spill Test Date	05/29/2020	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/29/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/29/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: FORMER LAUREL SERVICE CENTER  
201 W Main St  
Laurel, MT 59044-3108 Yellowstone

System Facility ID:56-01069

Facility Code: 29751  
Last Inspected On: 06/29/2017  
Operating Permit Renewal Date: 08/20/2020

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: H AND M CAPITAL LLC	4066286330
Operator Contact: Mike Jones;H AND M CAPITAL LLC	4066286330

Owner/Operator: H AND M CAPITAL LLC

Mike Jones, UST Class A Operator  
Mike Jones, UST Class B Operator

Tank Code	08	Tank Age	38	Tank Installed Date	04/29/1986	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	1808	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/03/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	08/08/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	36	Tank Installed Date	04/28/1988	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	1809	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/03/2017	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	08/08/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	10	Tank Age	37	Tank Installed Date	04/29/1987	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	1810	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/03/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	08/08/2006	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	36	Tank Installed Date	04/28/1988	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	1811	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/03/2017	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	08/08/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	12	Tank Age	36	Tank Installed Date	04/28/1988	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	1812	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/03/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date	08/08/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	13	Tank Age	36	Tank Installed Date	04/28/1988	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	1813	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	05/03/2017	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	08/08/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Tank Code	14	Tank Age	36	Tank Installed Date	04/28/1988	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	1814	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/03/2017	Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	4000	ATG Test Date		Line Tightness Test Date	08/08/2007	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					
Tank Code	15	Tank Age	26	Tank Installed Date	11/15/1998	Tank Material	Cathodically Protected Steel	Piping Material	No Piping	Overfill Types	Flapper Valve
Tag Number	1815	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Temporarily Out of Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	05/03/2017	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Deferred	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	08/08/2007	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: LAUREL 406 AERO LLC  
3900 Fox Rd  
Laurel, MT 59044 Yellowstone

System Facility ID:56-13474

Facility Code: 30443  
Last Inspected On: 11/05/2021  
Operating Permit Renewal Date: 01/27/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: LAUREL 406 AERO LLC	4066984829
Operator Contact: Arlene Lauer;Tom Boyce;LAUREL 406 AERO LLC	4066720991;4253305823;4066984829

Owner/Operator: LAUREL 406 AERO LLC

Arlene Lauer, UST Class A Operator  
Elliot Whitcomb, UST Class B Operator  
Tom Boyce, UST Class A Operator  
Tom Boyce, UST Class B Global Operator

Tank Code	01	Tank Age	30	Tank Installed Date	06/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4295	Spill Test Date	11/05/2021	Piping Installed Date	07/28/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	11/05/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	11/05/2021	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	7000	ATG Test Date		Line Tightness Test Date	11/05/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/05/2021			ATG Type					
Tank Code	02	Tank Age	30	Tank Installed Date	06/01/1994	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4296	Spill Test Date	11/05/2021	Piping Installed Date	07/28/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Galvanic
Product	Aviation Gas	PLLD Test Date		Tank/Piping CP Test Date	11/05/2021	Primary Tank Leak Detection	Manual Interstitial Monitoring	Primary Pipe Detection		Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/05/2021			ATG Type					

Facility Summary in Yellowstone County in the City of Laurel

Location: LAUREL CENEX C STORE  
315 S 1st Ave  
Laurel, MT 59044-3303 Yellowstone

System Facility ID:56-08161

Facility Code: 30215  
Last Inspected On: 08/09/2022  
Operating Permit Renewal Date: 12/27/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town and Country Supply Association 4066286314

Operator Contact: Danielle Keyser;Town and Country Supply Association;Makayla Rawson;Town and Country Supply Association;Wesley Burley 4066286314

Owner/Operator: Town and Country Supply Association

Danielle Keyser, UST Class A Operator  
Danielle Keyser, UST Class B Operator  
Makayla Rawson, UST Class A Operator  
Makayla Rawson, UST Class B Operator  
Wesley Burley, UST Class A Operator

Tank Code	05	Tank Age	29	Tank Installed Date	05/22/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1523	Spill Test Date	12/28/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date	08/09/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/09/2022	Line Tightness Test Date	04/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	01/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	29	Tank Installed Date	05/22/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1524	Spill Test Date	07/09/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date	08/09/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/09/2022	Line Tightness Test Date	03/14/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No

		Overfill Test Date	01/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	29	Tank Installed Date	05/22/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1525	Spill Test Date	07/09/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date	08/09/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/09/2022	Line Tightness Test Date	07/16/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	01/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	08	Tank Age	29	Tank Installed Date	05/22/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1526	Spill Test Date	07/09/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date	08/09/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/09/2022	Line Tightness Test Date	04/13/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	01/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	29	Tank Installed Date	05/22/1995	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1527	Spill Test Date	12/28/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	08/09/2022	Tank/Piping CP Test Date	08/09/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/09/2022	Line Tightness Test Date	02/18/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.1	Energy Act	No
		Overfill Test Date	01/16/2023			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: LAUREL TRAVEL CENTER  
11360 S Frontage Rd  
Laurel, MT 59044 Yellowstone

System Facility ID:56-00626

Facility Code: 29721  
Last Inspected On: 07/12/2022  
Operating Permit Renewal Date: 12/31/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: TA Operating LLC4408087406

Operator Contact: Mike Rathbone;Renee Andrews4069279658

Owner/Operator: TA Operating LLC

Mike Rathbone, UST Class A Operator  
Renee Andrews, UST Class A Operator  
Renee Andrews, UST Class B Operator  
Tammy Wieting, UST Class B Global Operator

Tank Code	01	Tank Age	56	Tank Installed Date	05/02/1968	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1791	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/12/2022	Sump Tightness Test Date	08/18/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/12/2022	Line Tightness Test Date	07/12/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	56	Tank Installed Date	05/02/1968	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1792	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/12/2022	Sump Tightness Test Date	08/18/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	10/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/12/2022	Line Tightness Test Date	07/12/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				



Tank Code	03	Tank Age	56	Tank Installed Date	05/02/1968	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	High Level Alarm
Tag Number	1793	Spill Test Date	07/12/2022	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/12/2022	Sump Tightness Test Date	08/18/2016	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/12/2022	Line Tightness Test Date	07/12/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	56	Tank Installed Date	05/02/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1794	Spill Test Date	07/12/2022	Piping Installed Date	08/17/2016	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/12/2022	Sump Tightness Test Date	07/12/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/12/2022	Line Tightness Test Date	07/12/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	07/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	53	Tank Installed Date	05/03/1971	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1795	Spill Test Date	07/12/2022	Piping Installed Date	05/10/2023	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/10/2023	Sump Tightness Test Date	07/12/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/12/2022	Line Tightness Test Date	07/12/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	07/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	56	Tank Installed Date	05/02/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1796	Spill Test Date	08/26/2022	Piping Installed Date	08/17/2016	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date	07/12/2022	Sump Tightness Test Date	07/12/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/12/2022	Line Tightness Test Date	10/19/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	07/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	56	Tank Installed Date	05/02/1968	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1797	Spill Test Date	07/12/2022	Piping Installed Date	08/17/2016	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	07/12/2022	Sump Tightness Test Date	07/12/2022	Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	10/20/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/12/2022	Line Tightness Test Date	07/12/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	MLLD Line Tightness Testing	Energy Act	No
		Overfill Test Date	07/12/2022			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	8	Tank Installed Date	04/01/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5649	Spill Test Date		Piping Installed Date	08/17/2016	Tank Construction		Piping Construction		AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN AND COUNTRY SUPPLY LAUREL ASSN  
800 E Main St  
Laurel, MT 59044-2866 Yellowstone

Facility Code: 29916  
Last Inspected On: 08/09/2022  
System Facility ID:56-04497  
Operating Permit Renewal Date: 12/14/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town and Country Supply Association 4066286314

Operator Contact: Amber Larson;Karissa Lueck;Wesley Burley 4066286314

Owner/Operator: Town and Country Supply Association

Amber Larson, UST Class A Operator  
Amber Larson, UST Class B Operator  
Karissa Lueck, UST Class A Operator  
Wesley Burley, UST Class A Operator

Tank Code	08	Tank Age	34	Tank Installed Date	02/12/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1518	Spill Test Date	08/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/06/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/09/2022	Line Tightness Test Date	08/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/09/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	34	Tank Installed Date	02/12/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	1520	Spill Test Date	08/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/06/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/09/2022	Line Tightness Test Date	08/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/09/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	12	Tank Age	34	Tank Installed Date	02/12/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4470	Spill Test Date	08/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	09/06/2016	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	08/09/2022	Line Tightness Test Date	08/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/09/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	34	Tank Installed Date	02/12/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4471	Spill Test Date	08/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date	08/09/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	2000	ATG Test Date	08/09/2022	Line Tightness Test Date	08/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/09/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	34	Tank Installed Date	02/12/1990	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4472	Spill Test Date	08/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/09/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	08/09/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	4000	ATG Test Date	08/09/2022	Line Tightness Test Date	08/09/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	08/09/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN AND COUNTRY WEST MAIN  
801 W Main St  
Laurel, MT 59044 Yellowstone

System Facility ID:60-15264

Facility Code: 30978  
Last Inspected On: 12/05/2022  
Operating Permit Renewal Date: 02/14/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Town and Country Supply Association 4066286314

Operator Contact: Lacey Anest;Makayla Rawson;Wes Burley;Town and Country Supply Association 4062561020;4066286314

Owner/Operator: Town and Country Supply Association

Lacey Anest, UST Class A Operator  
Lacey Anest, UST Class B Operator  
Makayla Rawson, UST Class A Operator  
Makayla Rawson, UST Class B Operator  
Wes Burley, UST Class A Operator

Tank Code	01	Tank Age	8	Tank Installed Date	10/19/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5611	Spill Test Date	10/27/2022	Piping Installed Date	10/19/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/26/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date	10/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/27/2022	Line Tightness Test Date	11/07/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	8	Tank Installed Date	10/19/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5612	Spill Test Date	10/27/2022	Piping Installed Date	10/19/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/26/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date	10/27/2022	Line Tightness Test Date	11/03/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	8	Tank Installed Date	10/19/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5613	Spill Test Date	10/27/2022	Piping Installed Date	10/19/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/26/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	10/27/2022	Line Tightness Test Date	11/03/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	04	Tank Age	8	Tank Installed Date	10/19/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5614	Spill Test Date	10/27/2022	Piping Installed Date	10/19/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/26/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	10/27/2022	Line Tightness Test Date	11/16/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	8	Tank Installed Date	10/19/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5615	Spill Test Date	10/27/2022	Piping Installed Date	10/19/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/26/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	10/27/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	10000	ATG Test Date	10/27/2022	Line Tightness Test Date	11/05/2022	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/27/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	8	Tank Installed Date	10/19/2016	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Positive Shutoff
Tag Number	5616	Spill Test Date		Piping Installed Date	10/19/2016	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date	10/07/2016	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Not Listed	Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN PUMP INC LAUREL 1  
312 S 1st Ave  
Laurel, MT 59044 Yellowstone

System Facility ID:56-08710

Facility Code: 30282  
Last Inspected On: 03/06/2024  
Operating Permit Renewal Date: 04/29/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Laurel 1 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Laurel 1 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	50	Tank Installed Date	04/14/1974	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2668	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/25/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	01/23/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/14/2022	Line Tightness Test Date	08/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	50	Tank Installed Date	04/14/1974	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2669	Spill Test Date	05/18/2021	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/25/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	01/23/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/14/2022	Line Tightness Test Date	08/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				



Tank Code	03	Tank Age	50	Tank Installed Date	04/14/1974	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2670	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction	Lined Interior/Impressed Current	Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	08/25/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	01/23/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/14/2022	Line Tightness Test Date	08/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	44	Tank Installed Date	04/14/1980	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2672	Spill Test Date	05/18/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	09/28/2022	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/25/2022	Tank/Piping CP Test Date	01/23/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/14/2022	Line Tightness Test Date	09/28/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	44	Tank Installed Date	04/14/1980	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4589	Spill Test Date	05/18/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	01/23/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	23	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4590	Spill Test Date	05/18/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	11/18/2014	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	23	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4591	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	11/18/2014	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	07/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	09	Tank Age	23	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4592	Spill Test Date	08/04/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	11/18/2014	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	5000	ATG Test Date	07/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	23	Tank Installed Date	06/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4593	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	11/18/2014	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	10000	ATG Test Date	07/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	23	Tank Installed Date	08/25/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4594	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	11/18/2014	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	07/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	37	Tank Installed Date	04/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Galvanized Steel	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4603	Spill Test Date	09/05/2023	Piping Installed Date		Tank Construction		Piping Construction	Single Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	07/14/2022	Tank/Piping CP Test Date	01/23/2019	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/14/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/18/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN PUMP OF LAUREL #3  
704 1st Ave  
Laurel, MT 59044-2100 Yellowstone

System Facility ID:60-15061

Facility Code: 30833  
Last Inspected On: 03/06/2024  
Operating Permit Renewal Date: 09/07/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Laurel 3 Town Pump LLC4064976700

Operator Contact: Trent Biggers;Town Pump

Owner/Operator: Laurel 3 Town Pump LLC

Trent Biggers, UST Class A Operator  
Trent Biggers, UST Class B Operator

Tank Code	01	Tank Age	17	Tank Installed Date	03/28/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5105	Spill Test Date	08/03/2021	Piping Installed Date	10/25/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/14/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/15/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/15/2022	Line Tightness Test Date	05/07/2014	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/14/2021			ATG Type					
Tank Code	02	Tank Age	17	Tank Installed Date	03/28/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	5106	Spill Test Date	05/14/2021	Piping Installed Date	10/25/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/14/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/15/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	07/15/2022	Line Tightness Test Date	05/11/2014	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/14/2021			ATG Type					
Tank Code	03	Tank Age	17	Tank Installed Date	03/28/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm

Tag Number	5107	Spill Test Date	05/14/2021	Piping Installed Date	10/25/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/14/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	07/15/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	07/15/2022	Line Tightness Test Date	05/13/2014	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/14/2021			ATG Type					

Facility Summary in Yellowstone County in the City of Pompeys Pillar

Location: BAYER TRUCKING BILLINGS TERMINAL  
2722 Fly Creek road  
Pompeys Pillar, MT 59064 Yellowstone

Facility Code: 32533  
Last Inspected On:  
System Facility ID:00-32533  
Operating Permit Renewal Date: 10/06/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:

Operator Contact:

Tank Code	01	Tank Age	1	Tank Installed Date	10/16/2023	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve;High Level Alarm
Tag Number	6194	Spill Test Date	04/02/2024	Piping Installed Date	01/08/2024	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/02/2024	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	04/02/2024	Line Tightness Test Date	04/02/2024	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	04/02/2024			ATG Type					
Tank Code	02	Tank Age	0	Tank Installed Date	10/16/2024	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	
Tag Number	6195	Spill Test Date	04/02/2024	Piping Installed Date	01/08/2024	Tank Construction		Piping Construction		AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/02/2024	Catastrophic L.D Type 3.0		Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection		Primary Pipe Detection		Vapor Recovery	No
Capacity	4000	ATG Test Date	04/02/2024	Line Tightness Test Date	04/02/2024	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	04/02/2024			ATG Type					

Facility Summary in Yellowstone County in the City of Worden

Location: VALLEY FARMERS SUPPLY  
1545 Northern Ave  
Worden, MT 59088-2215 Yellowstone

System Facility ID:56-02326

Facility Code: 29815  
Last Inspected On: 10/26/2023  
Operating Permit Renewal Date: 02/27/2027

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Valley Farmers Supply

Operator Contact: Scott Black4069673100

Owner/Operator: Valley Farmers Supply

Scott Black, UST Class A Operator  
Scott Black, UST Class B Global Operator

Tank Code	04	Tank Age	33	Tank Installed Date	11/01/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1006	Spill Test Date		Piping Installed Date	02/15/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/11/2020	Tank/Piping CP Test Date	09/16/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	05/29/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	05	Tank Age	33	Tank Installed Date	11/01/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1007	Spill Test Date		Piping Installed Date	02/15/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	09/11/2020	Tank/Piping CP Test Date	09/16/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	05/27/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	33	Tank Installed Date	11/01/1991	Tank Material	Steel Clad	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	1008	Spill Test Date		Piping Installed Date	02/15/2007	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	09/11/2020	Tank/Piping CP Test Date	09/16/2011	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	3000	ATG Test Date		Line Tightness Test Date	05/21/2017	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	03/31/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	S7	Tank Age	1	Tank Installed Date	05/30/2023	Tank Material	Other	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6149	Spill Test Date		Piping Installed Date	05/30/2023	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel, Dyed	PLLD Test Date	05/30/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/30/2023			ATG Type					
Tank Code	S8	Tank Age	1	Tank Installed Date	05/30/2023	Tank Material	Other	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	6150	Spill Test Date		Piping Installed Date	05/30/2023	Tank Construction		Piping Construction	Double Walled	AST	Yes
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/30/2023	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	05/30/2023	Tank/Piping CP Test Date		Primary Tank Leak Detection	Deferred	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/30/2023	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	05/30/2023			ATG Type					