

Facility Summary in Yellowstone County in the City of Ballantine

Location: TIGER TOWN
2253 S 16th Rd
Ballantine, MT 59006 Yellowstone

Legacy ID:56-06325

Facility ID: 30099
Last Inspected On: 05/13/2020
Operating Permit Renewal Date: 07/10/2023

Owner Operator Contact: Carol Hayes

4069672753

Operator Contact: Carol Hayes

4069672753

Owner/Operator: Carol Hayes

Carol Hayes, UST Class A Operator
Patti Anderson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	29	11/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3310	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		05/12/2017	Automatic Tank Gauging 0.2	Deferred	No
3,000			Incon/TS-1001		No
11	29	11/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3311	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		05/12/2017	Automatic Tank Gauging 0.2	Deferred	No
4,000			Incon/TS-1001		No
12	29	11/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3312	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic

Gasoline	05/12/2017	Automatic Tank Gauging 0.2	Deferred	No
5,000		Incon/TS-1001		No

Facility Summary in Yellowstone County in the City of Billings

Location: 24TH STREET CENEX
1031 N 24th St W
Billings, MT 59102-3807 Yellowstone

Legacy ID:56-05750

Facility ID: 30057
Last Inspected On: 08/31/2018
Operating Permit Renewal Date: 02/05/2022

Owner Operator Contact: Quast Inc

4066704290

Operator Contact: Teresa Bidleman

Owner/Operator: Quast Inc

Jeff Bidleman, UST Class B Operator
Teresa Bidleman, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	09/01/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3720	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/24/2018	Automatic Tank Gauging 0.2	ELLD 0.2;ELLD Line Tightness Testing	No
10,000		05/18/2018	Gilbarco/EMC Basic		No
02	37	09/01/1984	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3721	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/24/2018	Automatic Tank Gauging 0.2	ELLD 0.2;ELLD Line Tightness Testing	No
10,000		08/28/2018	Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE CENTER 27TH ST
702 S 27th St
Billings, MT 59101-4510 Yellowstone

Legacy ID:56-10797

Facility ID: 30360
Last Inspected On: 11/30/2020
Operating Permit Renewal Date: 01/07/2024

Owner Operator Contact: Larry Grosulak;Sng Inc;SNG Inc 3

4062450161

Operator Contact: Bergundi Grosulak;John Grosulak;Kelly Groslack;Larry Groslack **4062450161;4066702563;4066902993**

Owner/Operator: Larry Grosulak

Owner/Operator: SNG Inc 3

Bergundi Grosulak, UST Class A Operator
Bergundi Grosulak, UST Class B Operator
John Grosulak, UST Class A Operator
John Grosulak, UST Class B Operator
Kelly Groslack, UST Class A Operator
Kelly Groslack, UST Class B Operator
Larry Groslack, UST Class A Operator
Larry Groslack, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	23	07/01/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4751	No			Double Walled	Yes
Currently in Use		06/09/2010	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/23/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000		07/18/2008	Veeder Root/TLS-300		No
05	23	07/01/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4752	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/23/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No

4,000

07/18/2008

Veeder Root/TLS-300

No

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE CENTER 3
730 Lake Elmo Dr
Billings, MT 59105-3128 Yellowstone

Legacy ID:56-00063

Facility ID: 29689
Last Inspected On: 11/30/2020
Operating Permit Renewal Date: 01/08/2024

Owner Operator Contact: SNG Inc 3

Operator Contact: Bergundi Grosulak;John Grosulak;Kelly Groslack;Larry Groslack **4062450161;4066702563;4066902993**

Owner/Operator: SNG Inc 3

- Bergundi Grosulak, UST Class A Operator
- Bergundi Grosulak, UST Class B Operator
- John Grosulak, UST Class A Operator
- John Grosulak, UST Class B Operator
- Kelly Groslack, UST Class A Operator
- Kelly Groslack, UST Class B Operator
- Larry Groslack, UST Class A Operator
- Larry Groslack, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	12/20/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1871	No		Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		10/08/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		11/30/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	37	12/20/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1872	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current

Gasoline	10/08/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
10,000	11/30/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No	
03	37	12/20/1984	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
1873	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline	10/08/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No	
10,000	11/30/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No	

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE CENTER E WICKS LANE
1221 Wicks Ln
Billings, MT 59105-4417 Yellowstone

Legacy ID:56-04957

Facility ID: 29954
Last Inspected On: 07/08/2020
Operating Permit Renewal Date: 09/12/2023

Owner Operator Contact: SNG Inc 3

Operator Contact: Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack

4062450161;4066702563;4066902993;4068508456

Owner/Operator: SNG Inc 3

- Bergundi Grosulak, UST Class A Operator
- Bergundi Grosulak, UST Class B Operator
- Daniel Grosulak, UST Class A Operator
- Daniel Grosulak, UST Class B Operator
- John Grosulak, UST Class A Operator
- John Grosulak, UST Class B Operator
- Kelly Groslack, UST Class A Operator
- Kelly Groslack, UST Class B Operator
- Larry Groslack, UST Class A Operator
- Larry Groslack, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

03	7	09/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
----	---	------------	-------------------------------	------------------	---------------

5532	No	12/17/2014	Double-Walled	Double Walled	Yes
Currently in Use		12/17/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		12/17/2014	Incon/TS-550 EVO		Yes
04	7	09/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5533	No	12/17/2014	Double-Walled	Double Walled	Yes
Currently in Use		12/17/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		12/17/2014	Incon/TS-550 EVO		Yes
05	7	09/14/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5534	No	12/17/2014	Double-Walled	Double Walled	Yes
Currently in Use		12/17/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000		12/17/2014	Incon/TS-550 EVO		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: 3 GS CONVENIENCE CENTER STATE AVE
4410 State Ave
Billings, MT 59101-5060 Yellowstone

Legacy ID:56-04946

Facility ID: 29946
Last Inspected On: 08/09/2019
Operating Permit Renewal Date: 11/05/2022

Owner Operator Contact:

Operator Contact: Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Grosulak;Larry Grosulak **4062450161;4066702563;4066902993;4068508456**

Owner/Operator: SNG Inc 3

Bergundi Grosulak, UST Class A Operator
Bergundi Grosulak, UST Class B Operator
Daniel Grosulak, UST Class A Operator
Daniel Grosulak, UST Class B Operator
John Grosulak, UST Class A Operator

John Grosulak, UST Class B Operator
 Kelly Groslack, UST Class A Operator
 Kelly Groslack, UST Class B Operator
 Larry Groslack, UST Class A Operator
 Larry Groslack, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	8	04/01/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5400	No	05/01/2013	Double-Walled	Double Walled	Yes
Currently in Use		10/24/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-450		Yes
04	8	04/01/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5401	No	05/01/2013	Double-Walled	Double Walled	Yes
Currently in Use		10/24/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-450		Yes
05	8	04/01/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5402	No	05/01/2013	Double-Walled	Double Walled	Yes
Currently in Use		10/24/2012	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-450		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: 3 Gs CONVENIENCE STORE #5
 4106 State Ave
 Billings, MT 59101-3550 Yellowstone

Legacy ID:56-05748

Facility ID: 30055
Last Inspected On: 11/12/2020
Operating Permit Renewal Date: 01/06/2024

Owner Operator Contact: Cindy Konecny;Vesta Ventures LLP

4062080129;4066568402

Operator Contact: Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack

4062450161;4066702563;4066902993;4068508456

Owner/Operator: G & L Properties LLC

- Bergundi Grosulak, UST Class A Operator
- Bergundi Grosulak, UST Class B Operator
- Daniel Grosulak, UST Class A Operator
- Daniel Grosulak, UST Class B Operator
- John Grosulak, UST Class A Operator
- John Grosulak, UST Class B Operator
- Kelly Groslack, UST Class A Operator
- Kelly Groslack, UST Class B Operator
- Larry Groslack, UST Class A Operator
- Larry Groslack, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	19	08/23/2002	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4714	No	05/03/2016		Double Walled	Yes
Currently in Use		05/13/2016	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/01/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
9,000		05/13/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	19	08/23/2002	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4715	No	05/03/2016		Double Walled	Yes
Currently in Use		05/13/2016	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/01/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No

3,000

05/13/2016

Gilbarco-Veeder Root/TLS-350/Gilbarco EMC

No

Facility Summary in Yellowstone County in the City of Billings

Location: 3 G'S CONVENIENCE STORE #6
1425 US Hwy 87 E
Billings, MT 59101-6657 Yellowstone

Legacy ID:56-05086

Facility ID: 30004
Last Inspected On: 07/08/2020
Operating Permit Renewal Date: 11/07/2023

Owner Operator Contact:

Operator Contact: Bergundi Grosulak;Daniel Grosulak;John Grosulak;Kelly Groslack;Larry Groslack

4062450161;4066702563;4066902993;4068508456

Owner/Operator: G & L Properties LLC

Owner/Operator: Kelly Grosulak

- Bergundi Grosulak, UST Class A Operator
- Bergundi Grosulak, UST Class B Operator
- Daniel Grosulak, UST Class A Operator
- Daniel Grosulak, UST Class B Operator
- John Grosulak, UST Class A Operator
- John Grosulak, UST Class B Operator
- Kelly Groslack, UST Class A Operator
- Kelly Groslack, UST Class B Operator
- Larry Groslack, UST Class A Operator
- Larry Groslack, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	4	05/09/2017	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff
5679	No	04/03/2017	Double-Walled	Double Walled	Yes
Currently in Use		05/09/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		04/03/2017	Incon/TS-550 EVO		Yes
05	4	05/09/2017	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm;Positive Shutoff

5680	No	04/03/2017	Double-Walled	Double Walled	Yes
Currently in Use		05/09/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		04/03/2017	Incon/TS-550 EVO		Yes
06	4	05/09/2017	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm; Positive Shutoff
5681	No	04/03/2017	Double-Walled	Double Walled	Yes
Currently in Use		05/09/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		04/03/2017	Incon/TS-550 EVO		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: AIR TRAFFIC CONTROL TOWER
1907 Terminal Cir
Billings, MT 59105-1990 Yellowstone

Legacy ID:56-14127

Facility ID: 30768
Last Inspected On: 10/18/2019
Operating Permit Renewal Date: 10/21/2022

Owner Operator Contact: Federal Aviation Admin Billings

4066576455

Operator Contact: Craig Fitzgerald;Evan Wolfe;Kevonte Daniels;Paul Henley

4065986855;4066576981;4066701577;4068551891

Owner/Operator: Federal Aviation Admin Billings

- Craig Fitzgerald, UST Class A Operator
- Craig Fitzgerald, UST Class B Global Operator
- Evan Wolfe, UST Class A Operator
- Evan Wolfe, UST Class B Global Operator
- Kevonte Daniels, UST Class A Operator
- Kevonte Daniels, UST Class B Operator
- Paul Henley, UST Class A Operator
- Paul Henley, UST Class B Global Operator
- Paul Henley, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	17	12/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
4976	No	08/14/2015	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
4,000			Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: ARCHIE COCHRANE MOTORS
2133 King Ave W
Billings, MT 59102-6420 Yellowstone

Legacy ID:56-00123

Facility ID: 29692
Last Inspected On: 01/15/2021
Operating Permit Renewal Date: 03/26/2024

Owner Operator Contact: Archie Cochrane Motors;Garry Brayko;Archie Cochrane Motors

4066561100;4066561100;4066561100

Operator Contact:

Owner/Operator: Archie Cochrane Motors

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	28	08/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
390	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		10/04/2017	Manual Interstitial Monitoring	Deferred	No
2,000					No
05	28	08/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
391	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		10/04/2017	Manual Interstitial Monitoring	Deferred	No
1,000					No

Facility Summary in Yellowstone County in the City of Billings

Location: AT and T COMMUNICATIONS BILLINGS
3011 2nd Ave N
Billings, MT 59101-2028 Yellowstone

Legacy ID:56-05758

Facility ID: 30061
Last Inspected On: 01/21/2019
Operating Permit Renewal Date: 03/09/2022

Owner Operator Contact: AT and T Communications Inc

8005669347

Operator Contact: Daniel Donigian;Gary Vantress;Gerald Eshbaugh;Philip Bunker;Richard Powell;Robert Pickens 2147410476;5094596211

Owner/Operator: AT and T Communications Inc

Daniel Donigian, UST Class A Operator

Daniel Donigian, UST Class B Global Operator
 David Klase, UST Class B Operator
 Gary Vantress, UST Class A Operator
 Gary Vantress, UST Class B Operator
 Gerald Eshbaugh, UST Class A Operator
 Philip Bunker, UST Class A Operator
 Richard Powell, UST Class A Operator
 Robert Pickens, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	27	09/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
399	No		Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		11/23/2015	Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
8,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS DIGITAL AIRPORT SURVEILLANCE
 RADAR
 1901 Terminal Cir
 Billings, MT 59105-1990 Yellowstone

Legacy ID:56-14077

Facility ID: 30729
Last Inspected On: 03/11/2021
Operating Permit Renewal Date: 03/26/2024

Owner Operator Contact: Federal Aviation Admin Billings

4066576455

Operator Contact: Dennis Schuelka;Evan Wolfe;Paul Henley

4062252711;4066701577;4068551891

Owner/Operator: Federal Aviation Admin Billings

Dennis Schuelka, UST Class A Operator
 Dennis Schuelka, UST Class B Operator
 Evan Wolfe, UST Class A Operator
 Evan Wolfe, UST Class B Global Operator
 Paul Henley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	19	12/30/2002	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
4780	No	05/10/2018	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
1,000		04/25/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS DISTRIBUTION COMPANY LLC
1629 King Ave W
Billings, MT 59102-6448 Yellowstone

Legacy ID:56-06097

Facility ID: 30085
Last Inspected On: 03/21/2019
Operating Permit Renewal Date: 08/28/2022

Owner Operator Contact: Billings Distribution Company LLC;Scott Armstrong;Supervalu Inc Ryans Wholesale Division

Operator Contact: Jeffrey Lindell;John Beadle;Mike Frost;Scott Combs **4062471523**

Owner/Operator: Billings Distribution Company LLC

- Jeffrey Lindell, UST Class A Operator
- Jeffrey Lindell, UST Class B Global Operator
- John Beadle, UST Class A Operator
- John Beadle, UST Class B Operator
- Mike Frost, UST Class A Operator
- Mike Frost, UST Class B Global Operator
- Scott Combs, UST Class A Operator
- Scott Combs, UST Class B Global Operator
- Steve Schilling, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
04	23	09/01/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1867	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel	04/18/2016		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
05	23	09/01/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1868	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel	04/18/2016		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 1
2305 8th Ave N
Billings, MT 59101-1018 Yellowstone

Legacy ID:56-09739

Facility ID: 30317
Last Inspected On: 01/20/2021
Operating Permit Renewal Date: 02/20/2024

Owner Operator Contact: City of Billings Fire Dept

4066578428

Operator Contact: Froilan Valdez

4066987701

Owner/Operator: City of Billings Fire Dept

Froilan Valdez, UST Class A Operator
Froilan Valdez, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

03	28	12/01/1993	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
----	----	------------	------------------------------	------------------	------------------

2728	No	11/10/2017		Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	U.S. Suction	Galvanic
Diesel		06/19/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
1,035			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	28	12/01/1993	Cathodically Protected Steel	Copper	High Level Alarm
2729	No			Secondary Containment Chase	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		06/19/2015	Automatic Tank Gauging 0.2	Deferred	No
517			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 2
501 S 28th St
Billings, MT 59101-4143 Yellowstone

Legacy ID:56-09740

Facility ID: 30318
Last Inspected On: 01/20/2021
Operating Permit Renewal Date: 02/20/2024

Owner Operator Contact: City of Billings Fire Dept

4066578428

Operator Contact: Froilan Valdez

4066987701

Owner/Operator: City of Billings Fire Dept

Froilan Valdez, UST Class A Operator
Froilan Valdez, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	06/12/1990	Cathodically Protected Steel	Steel	Flapper Valve
3699	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/10/2017	Automatic Tank Gauging 0.2	Deferred	No
1,000			Gilbarco/EMC Basic		No
04	31	06/12/1990	Cathodically Protected Steel	Steel	Flapper Valve
3700	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		11/10/2017	Automatic Tank Gauging 0.2	Deferred	No
1,000			Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 3
1928 17th St W
Billings, MT 59102-2907 Yellowstone

Legacy ID:56-09741

Facility ID: 30319
Last Inspected On: 01/20/2021
Operating Permit Renewal Date: 02/20/2024

Owner Operator Contact: City of Billings Fire Dept;N/A ZZZ - TBL_OWN : **4066578428**
177;City of Billings Fire Dept

Operator Contact: Froilan Valdez **4066987701**

Owner/Operator: City of Billings Fire Dept

Froilan Valdez, UST Class A Operator
Froilan Valdez, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	29	03/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4297	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		06/19/2015	Automatic Tank Gauging 0.2	Not Listed	No
500			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 5
605 S 24th St W
Billings, MT 59102-6246 Yellowstone

Legacy ID:56-09742

Facility ID: 30320
Last Inspected On: 01/20/2021
Operating Permit Renewal Date: 02/20/2024

Owner Operator Contact: City of Billings Fire Dept **4066578428**

Operator Contact: Froilan Valdez **4066987701**

Owner/Operator: City of Billings Fire Dept

Froilan Valdez, UST Class A Operator
Froilan Valdez, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

04	28	01/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2731	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		06/19/2015	Automatic Tank Gauging 0.2	Deferred	No
517			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	28	01/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2732	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		06/19/2015	Automatic Tank Gauging 0.2	Deferred	No
517			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS FIRE STATION 6
1601 St Andrews Dr
Billings, MT 59105-3863 Yellowstone

Legacy ID:56-09743

Facility ID: 30321
Last Inspected On: 01/20/2021
Operating Permit Renewal Date: 02/20/2024

Owner Operator Contact: City of Billings Fire Dept **4066578428**

Operator Contact: Froilan Valdez **4066987701**

Owner/Operator: City of Billings Fire Dept

Froilan Valdez, UST Class A Operator
Froilan Valdez, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	34	10/19/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2733	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		06/19/2015	Automatic Tank Gauging 0.2	Deferred	No
500			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS LOGAN INTERNATIONAL AIRPORT UST
1901 Terminal Cir Ste 216
Billings, MT 59105-1991 Yellowstone

Legacy ID:56-00909

Facility ID: 29743
Last Inspected On: 06/27/2019
Operating Permit Renewal Date: 09/04/2022

Owner Operator Contact: Billings Logan International Airport **4066578482**

Operator Contact: Shawn Gaalswyk

Owner/Operator: Billings Logan International Airport

Colter Smith, UST Class B Operator
Shawn Gaalswyk, UST Class A Operator
Shawn Gaalswyk, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
17	28	10/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
4826	No		Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Oil, Waste		06/09/2016	Manual Interstitial Monitoring	3-Year Line Tightness Test	No
500		06/09/2016			No
11	34	01/01/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
623	No		Double-Walled	Double Walled	Yes
Currently in Use				Pressurized	Galvanic
Diesel		06/06/2016	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring		No
4,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
12	28	10/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
624	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/09/2016	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
13	28	10/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
625	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic

Diesel	06/09/2016	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS METROPOLITAN TRANSIT
1705 Monad Rd
Billings, MT 59101-3234 Yellowstone

Legacy ID:56-09747

Facility ID: 30325
Last Inspected On: 08/13/2021
Operating Permit Renewal Date: 12/18/2024

Owner Operator Contact: City of Billings MET Transit;John Bishop;City of Billings MET Transit **4066578218;4066578219;4066578219**

Operator Contact: John Bishop;Josh Smith;Billings Metropolitan Transit;Lindsay Gran;Rusty Logan **4066578218;4066578219**

Owner/Operator: City of Billings MET Transit

- John Bishop, UST Class A Operator
- Josh Smith, UST Class A Operator
- Josh Smith, UST Class B Operator
- Lindsay Gran, UST Class A Operator
- Rick Pirami, UST Class B Operator
- Rusty Logan, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	18	09/03/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4862	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000		08/30/2018	Gilbarco/EMC Basic		No
05	18	09/03/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4863	No		Double-Walled	Double Walled	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000		08/30/2018	Gilbarco/EMC Basic		No
03	38	10/15/1983	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
635	No			None	Yes
Currently in Use			Not Required	Gravity Feed	Galvanic
Oil, Waste		08/30/2018	Automatic Tank Gauging 0.2	3-Year Line Tightness Test	No
2,000		08/30/2018	Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS OPERATION CENTER
4848 Midland Rd
Billings, MT 59101 Yellowstone

Legacy ID:56-14118

Facility ID: 30759
Last Inspected On: 07/19/2019
Operating Permit Renewal Date: 12/10/2022

Owner Operator Contact: City of Billings Operation Center

Operator Contact: Larry Deschene

Owner/Operator: City of Billings Operation Center

Larry Deschene, UST Class A Operator
Troy Namen, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	17	07/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4935	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No

10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	17	07/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4936	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	17	07/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4937	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	17	07/09/2004	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4938	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS REGIONAL LANDFILL
5240 Jellison Rd
Billings, MT 59101 Yellowstone

Legacy ID:56-09744

Facility ID: 30322
Last Inspected On: 07/01/2021
Operating Permit Renewal Date: 09/04/2021

Owner Operator Contact: City of Billings Solid Waste Division

4066578240

Operator Contact: Margaret Pegues

4062478633

Owner/Operator: City of Billings Solid Waste Division

Margaret Pegues, UST Class A Operator
Margaret Pegues, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	35	10/01/1986	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
630	No	09/04/2018	Double-Walled	Double Walled	Yes
Temporarily Out of Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		07/30/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
10,000			Veeder Root/TLS-300		No

Facility Summary in Yellowstone County in the City of Billings

Location: BILLINGS SENIOR HIGH SCHOOL
425 Grand Ave
Billings, MT 59101-5999 Yellowstone

Legacy ID:56-14045

Facility ID: 30700
Last Inspected On: 12/05/2018
Operating Permit Renewal Date:

Owner Operator Contact: Billings School District

4062473777

Operator Contact: Dennis Stellingwerf

Owner/Operator: Billings School District

Bruce Schliticing, UST Class B Global Operator
Dennis Stellingwerf, UST Class A Operator
Rodney Grotbo, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	12/17/2001	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4601	No	10/27/2012	Double-Walled	Double Walled	Yes
Temporarily Out of Use			Auto Dialer	Pressurized	Galvanic
Diesel		11/30/2018	Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
3,000					No

Facility Summary in Yellowstone County in the City of Billings

Location: BROADWATER QUICK STOP
942 Broadwater Ave
Billings, MT 59101 Yellowstone

Legacy ID:56-08671

Facility ID: 30281
Last Inspected On: 12/16/2020
Operating Permit Renewal Date: 12/16/2023

Owner Operator Contact: Bill Grinsell;Don Edmisten;Broadwater Town Pump Inc **4064976948;4067402686**

Operator Contact:

Owner/Operator: Bill Grinsell

Bill Grinsell, UST Class B Operator
Shay Grinsell, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	28	12/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3169	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/25/2017	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No

8,000		10/25/2017			No
05	28	12/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3170	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/25/2017	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
8,000		10/25/2017			No

Facility Summary in Yellowstone County in the City of Billings

Location: CARDLOCK #2
3520 1st Ave S
Billings, MT 59101 Yellowstone

Legacy ID:56-08324

Facility ID: 30262
Last Inspected On: 07/03/2019
Operating Permit Renewal Date: 12/24/2022

Owner Operator Contact: Dennis Whitmore;Petro Services Co Inc **4066515101**

Operator Contact: Bill Grunstead;Jay Brookie;Laura Geffre;Roger Schmechel **4062083147;4062524661**

Owner/Operator: GM Petroleum Distributing Inc

- Bill Grunstead, UST Class A Operator
- Jay Brookie, UST Class A Operator
- Jay Brookie, UST Class B Global Operator
- Laura Geffre, UST Class A Operator
- Laura Geffre, UST Class B Operator
- Roger Schmechel, UST Class A Operator
- Roger Schmechel, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	43	05/06/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1179	No		Lined Interior/Impressed Current	Single Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		06/01/2015	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No

10,000		10/29/2010	Gilbarco/EMC Basic		No
02	43	05/06/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1180	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		06/01/2015	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		10/29/2010	Gilbarco/EMC Basic		No
03	43	05/06/1978	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1181	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/01/2015	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		10/29/2010	Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: CARDLOCK #3
1004 4th Ave N
Billings, MT 59101 Yellowstone

Legacy ID:56-01290

Facility ID: 29764
Last Inspected On: 06/06/2019
Operating Permit Renewal Date: 08/16/2022

Owner Operator Contact: Dennis Whitmore;Petro Services Co Inc **4066515101**

Operator Contact: Bill Grunstead;Laura Geffre;Roger Schmechel **4062083147**

Owner/Operator: W G Properties LLC

Bill Grunstead, UST Class A Operator
Cody O'Connor, UST Class B Operator
Laura Geffre, UST Class A Operator
Laura Geffre, UST Class B Operator
Roger Schmechel, UST Class A Operator
Roger Schmechel, UST Class B Global Operator
Roger Schmechel, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
D-1	45	02/04/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
752	No	06/23/2016		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		07/08/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
D-2	45	01/01/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
753	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		07/08/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
D-3	45	02/04/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
754	No	06/23/2016		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		07/08/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
D-4	45	02/04/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
755	No	06/23/2016		Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		07/08/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
D-5	45	02/04/1976	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
756	No			Double Walled	Yes

Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline	07/08/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: CARDLOCK #4
275 Daniels St
Billings, MT 59101 Yellowstone

Legacy ID:56-09271

Facility ID: 30294
Last Inspected On: 05/15/2019
Operating Permit Renewal Date: 04/20/2022

Owner Operator Contact:

Operator Contact: Bill Grunstead;Jay Brookie;Laura Geffre;Roger Schmechel

4062083147;4062524661

Owner/Operator: Monad Daniels LLC

- Bill Grunstead, UST Class A Operator
- Jay Brookie, UST Class A Operator
- Jay Brookie, UST Class B Global Operator
- Laura Geffre, UST Class A Operator
- Laura Geffre, UST Class B Operator
- Roger Schmechel, UST Class A Operator
- Roger Schmechel, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	28	01/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4716	No		Double-Walled	Double Walled	Yes
Currently in Use		11/13/2008	Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
12,000		10/15/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	28	01/01/1993	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm

4717	No		Double-Walled	Double Walled	Yes
Currently in Use	11/13/2008		Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000	10/17/2018		Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS #7
2007 Blue Creek Rd
Billings, MT 59101 Yellowstone

Legacy ID:56-06595

Facility ID: 30120
Last Inspected On: 01/08/2021
Operating Permit Renewal Date: 11/29/2023

Owner Operator Contact: Donna Madson;Central Holdings, LLC;Story
Distributing Co Bozeman

Operator Contact: Calvin Wilson;Jason Shanley

Owner/Operator: Story Distributing Co Bozeman

- Amber Olson, UST Class B Operator
- Calvin Wilson, UST Class A Operator
- Calvin Wilson, UST Class B Global Operator
- Irene Matzen, UST Class B Operator
- Jason Shanley, UST Class A Operator
- Jason Shanley, UST Class B Operator
- Kelly Shutes, UST Class B Global Operator
- Melanie Sims, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	29	11/02/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
466	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/19/2014	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		07/24/2014	Veeder Root/TLS-300		No

04	29	11/02/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
467	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/19/2014	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		07/28/2014	Veeder Root/TLS-350		No
05	29	11/02/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
468	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/19/2014	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		08/07/2014	Veeder Root/TLS-350		No

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS #8
2816 Old Hardin Rd
Billings, MT 59101 Yellowstone

Legacy ID:56-06594

Facility ID: 30119
Last Inspected On: 10/12/2020
Operating Permit Renewal Date: 02/28/2024

Owner Operator Contact: Donna Madson;Central Holdings, LLC;Story
Distributing Co Bozeman

Operator Contact: Calvin Wilson;Jason Shanley

Owner/Operator: Story Distributing Co Bozeman

- Andrew McLellan, UST Class B Operator
- Ann LeVeque, UST Class B Operator
- Calvin Wilson, UST Class A Operator
- Calvin Wilson, UST Class B Global Operator
- Chuck Crane, UST Class B Operator
- Jason Shanley, UST Class A Operator
- Jason Shanley, UST Class B Operator
- Kelly Shutes, UST Class B Global Operator
- Steve Willden, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
04	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
462	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline	08/25/2011	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No	
20,000			Gilbarco-Veeder Root/TLS-350	No	
05	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
463	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline	08/25/2011	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No	
10,000			Gilbarco-Veeder Root/TLS-350	No	
06	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
464	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline	08/25/2011	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No	
8,000			Gilbarco-Veeder Root/TLS-350	No	
07	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
465	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel	08/25/2011	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No	
8,000			Gilbarco-Veeder Root/TLS-350	No	

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS CORNER #10
3443 Central Ave
Billings, MT 59102 Yellowstone

Legacy ID:56-05085

Facility ID: 30003
Last Inspected On: 01/04/2019
Operating Permit Renewal Date: 06/14/2022

Owner Operator Contact: Mike Stock;Central Property LLC;Story Distributing Co
Bozeman

Operator Contact: Calvin Wilson;Jeffrey Fletcher

4065459099

Owner/Operator: Story Distributing Co Bozeman

Calvin Wilson, UST Class A Operator
Calvin Wilson, UST Class B Global Operator
Ethan Granzow, UST Class B Operator
Faron Siers, UST Class B Operator
Jeffrey Fletcher, UST Class A Operator
Natalie Johnson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	26	05/01/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2007	No	06/30/2014		Double Walled	Yes
Currently in Use		05/06/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/04/2019	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000		07/17/2018	Veeder Root/TLS-450		No
08	26	05/01/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2009	No	06/30/2014		Double Walled	Yes
Currently in Use		05/06/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		01/04/2019	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
6,000		07/09/2018	Veeder Root/TLS-450		No

07	26	05/01/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4473	No	06/30/2014		Double Walled	Yes
Currently in Use		05/06/2014	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/04/2019	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000		07/17/2018	Veeder Root/TLS-450		No

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS CORNER STORE #11
2347 Main St
Billings, MT 59105-4023 Yellowstone

Legacy ID:56-06593

Facility ID: 30118
Last Inspected On: 01/24/2020
Operating Permit Renewal Date: 04/25/2023

Owner Operator Contact: Donna Madson; Story Distributing Co Bozeman; Story Distributing Co Bozeman

Operator Contact: Brit Miller; Calvin Wilson **4062520166**

Owner/Operator: Story Distributing Co Bozeman

- Bill Bonner, UST Class B Operator
- Brit Miller, UST Class A Operator
- Calvin Wilson, UST Class A Operator
- Calvin Wilson, UST Class B Global Operator
- Dawn Jones, UST Class B Global Operator
- Randy Lowe, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	40	10/01/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
459	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		01/27/2017	Automatic Tank Gauging 0.2	ELLD 0.1; ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

02	40	10/01/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
460	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/27/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	40	10/01/1981	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
461	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		01/27/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: CASEYS CORNER STORE #12
5550 US Hwy 312
Billings, MT 59105-4944 Yellowstone

Legacy ID:56-00062

Facility ID: 29688
Last Inspected On: 11/22/2019
Operating Permit Renewal Date: 11/28/2022

Owner Operator Contact:

Operator Contact: Michael Stockton

4062456376

Owner/Operator: Story Distributing Company

Christopher Stockton, UST Class B Global Operator
Joey McConnell , UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Michael Stockton, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

04	5	06/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
----	---	------------	-------------------------------	-------------------------------	---------------

5653	No	06/30/2016	Double-Walled	Double Walled	Yes
Currently in Use		06/30/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000		06/29/2016	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
05	5	06/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5654	No	06/30/2016	Double-Walled	Double Walled	Yes
Currently in Use		06/30/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000		06/29/2016	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
06	5	06/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5655	No	06/30/2016	Double-Walled	Double Walled	Yes
Currently in Use		06/30/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000		06/29/2016	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
07	5	06/30/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5656	No	06/30/2016	Double-Walled	Double Walled	Yes
Currently in Use		06/30/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000		06/29/2016	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: CONO MART SUPER STORE 10
 11 W Wicks Ln
 Billings, MT 59105 Yellowstone

Legacy ID:56-05088

Facility ID: 30006
Last Inspected On: 09/22/2020
Operating Permit Renewal Date: 03/03/2024

Owner Operator Contact: Dennis Whitmore;Petro Services Co Inc;Superpumper Inc **4066515101**

Operator Contact: Justin Franjevic;Stephanie Zierke **4062940867;4068551749**

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator
 Mark Zinnecker, UST Class B Operator
 Stephanie Zierke, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1154	No			Double Walled	Yes
Currently in Use		12/15/2009	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/17/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		06/04/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	31	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1155	No			Double Walled	Yes
Currently in Use		12/15/2009	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		03/17/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2;ELLD Line Tightness Testing	No
8,000		06/02/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	31	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1156	No			Double Walled	Yes

Currently in Use	12/15/2009	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline	03/17/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2; ELLD Line Tightness Testing	No
6,000	06/04/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: CONO MART SUPER STORE 6
1219 Main St
Billings, MT 59105-2539 Yellowstone

Legacy ID:56-06948

Facility ID: 30138
Last Inspected On: 09/22/2020
Operating Permit Renewal Date: 01/28/2024

Owner Operator Contact: Dennis Whitmore;Grunstead Family Limited Partnership;Superpumper Inc

4066515101;4062524661

Operator Contact: Justin Franjevic;Stephanie Zierke

4062940867;4068551749

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Troy Davis, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	45	04/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3618	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/29/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		08/27/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	50	04/22/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3619	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		06/29/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No

10,000		07/14/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	50	04/22/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3620	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/29/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		10/06/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: CONOMART SUPERSTORE 4
1240 S 27th St
Billings, MT 59101 Yellowstone

Legacy ID:56-00503

Facility ID: 29716
Last Inspected On: 06/05/2019
Operating Permit Renewal Date: 09/28/2022

Owner Operator Contact: Dennis Whitmore;Petro Services Co Inc;Superpumper Inc **4066515101**

Operator Contact: Justin Franjevic;Stephanie Zierke **4062940867;4068551749**

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator
Kim Hauck, UST Class B Operator
Stephanie Zierke, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1148	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/28/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		08/23/2010	Gilbarco/EMC Basic		No
05	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm

1149	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/28/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		08/22/2010	Gilbarco/EMC Basic		No
06	23	05/01/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1150	No	04/01/2015	Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		05/28/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000		05/03/2015	Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: CONOMART SUPERSTORE 7
4903 Southgate Dr
Billings, MT 59101-4668 Yellowstone

Legacy ID: 56-13808

Facility ID: 30495
Last Inspected On: 10/07/2019
Operating Permit Renewal Date: 12/31/2022

Owner Operator Contact: Superpumper Inc

Operator Contact: Justin Franjevic; Stephanie Zierke

4062940867; 4068551749

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator
Stephanie Zierke, UST Class A Operator
Tammie Turner, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	24	12/05/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1182	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline		05/29/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No
02	24	12/05/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1183	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/29/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No
03	23	12/05/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1184	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		05/29/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000			Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: COSTCO WHOLESALE GASOLINE 69
2290 King Ave W
Billings, MT 59102 Yellowstone

Legacy ID:56-13953

Facility ID: 30621
Last Inspected On: 12/14/2018
Operating Permit Renewal Date: 04/01/2022

Owner Operator Contact:

Operator Contact: Andrew Jurcich; Arthur Kraft; Dan Martinez; Dennis Bock; Keaton Leuthold; Kyle Knox; Lyssa Logan; Michael Schaeffer; Patty Vaughan; Samuel Rodriguez; Shawn Kipp
4066528765; 4066717789; 4066723253

Owner/Operator: Costco Wholesale

- Andrew Jurcich, UST Class A Operator
- Andrew Jurcich, UST Class B Operator
- Arthur Kraft, UST Class A Operator
- Arthur Kraft, UST Class B Operator
- Brett Smith, UST Class B Operator
- Dan Martinez, UST Class A Operator
- Dennis Bock, UST Class A Operator
- Dennis Bock, UST Class B Global Operator
- Hal Ostlund, UST Class B Operator

Keaton Leuthold, UST Class A Operator
 Keaton Leuthold, UST Class B Global Operator
 Keaton Leuthold, UST Class B Operator
 Kyle Knox, UST Class A Operator
 Kyle Knox, UST Class B Global Operator
 Kyle Knox, UST Class B Operator
 Lyssa Logan, UST Class A Operator
 Lyssa Logan, UST Class B Operator
 Michael Schaeffer, UST Class A Operator
 Michael Schaeffer, UST Class B Global Operator
 Patty Vaughan, UST Class A Operator
 Patty Vaughan, UST Class B Operator
 Samuel Rodriguez, UST Class A Operator
 Samuel Rodriguez, UST Class B Global Operator
 Shawn Kipp, UST Class A Operator
 Shawn Kipp, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	22	10/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4109	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Approved Remote Monitoring;Continuous Interstitial Monitoring;ELLD 0.2	No
30,000		11/01/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	22	10/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4110	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	

Gasoline			Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Approved Remote Monitoring;Continuous Interstitial Monitoring;ELLD 0.2	No
15,000		11/01/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	22	10/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4111	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Approved Remote Monitoring;Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Approved Remote Monitoring;Continuous Interstitial Monitoring;ELLD 0.2	No
15,000		11/01/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
S4	10	04/01/2011	Concrete	Fiberglass Reinforced Plastic	High Level Alarm
5354	Yes		Double-Walled	Double Walled	Yes
Currently in Use		07/19/2012	Mechanical Line Leak Detector	Pressurized	
Hazardous Substance			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring;Deferred	Approved Remote Monitoring;Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
1,200		11/01/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: DEACONESS BILLINGS CLINIC 9TH AVE
2800 10th Ave N
Billings, MT 59101-0703 Yellowstone

Legacy ID:56-02067

Facility ID: 29806
Last Inspected On: 08/02/2021
Operating Permit Renewal Date: 09/29/2024

Owner Operator Contact: Deaconess Clinic Billings

4066574036

Operator Contact: Cody Anderson;Lloyd Newman

Owner/Operator: Deaconess Clinic Billings

Cody Anderson, UST Class A Operator
Cody Anderson, UST Class B Operator
Lloyd Newman, UST Class A Operator
Lloyd Newman, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	29	02/01/1992	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
826	No	10/09/2015	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Diesel		02/27/2018	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
10,000			Gilbarco-Veeder Root/Other		No

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH
1433 Main St
Billings, MT 59105-1739 Yellowstone

Legacy ID:56-05755

Facility ID: 30058
Last Inspected On: 10/14/2020
Operating Permit Renewal Date: 10/14/2023

Owner Operator Contact: Automatic Car Wash Inc;Gary Carlson;Automatic Car Wash Inc

4062482558

Operator Contact: Gene Carlson

4062482558

Owner/Operator: Automatic Car Wash Inc

Gene Carlson, UST Class A Operator
Gene Carlson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	16	11/10/2005	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
5030	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/02/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000		07/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	16	11/10/2005	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
5031	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		01/02/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000		07/26/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	16	11/10/2005	Cathodically Protected Steel	Flexible Plastic	Ball Float Valve
5032	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		01/02/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000		07/28/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH 1ST AVE
1924 1st Ave N
Billings, MT 59101-2443 Yellowstone

Legacy ID:56-06956

Facility ID: 30143
Last Inspected On: 10/14/2020
Operating Permit Renewal Date: 02/10/2024

Owner Operator Contact: Automatic Car Wash Inc; Gary Carlson; Automatic Car Wash Inc **4062482558**

Operator Contact: Eric Carlson; Gene Carlson **4062482558; 4068942373**

Owner/Operator: Automatic Car Wash Inc

Dick Berg, UST Class B Operator
 Eric Carlson, UST Class A Operator
 Eric Carlson, UST Class B Operator
 Gene Carlson, UST Class A Operator
 Gene Carlson, UST Class B Global Operator
 Gene Carlson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	33	11/11/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
412	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		11/07/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	33	11/11/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
413	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
6,000		11/05/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	33	11/11/1988	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
414	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/07/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No

6,000

10/28/2017

Gilbarco-Veeder Root/TLS-350/Gilbarco EMC

No

Facility Summary in Yellowstone County in the City of Billings

Location: DONS CAR WASH GRAND AVE
1125 Grand Ave
Billings, MT 59102-4267 Yellowstone

Legacy ID:56-05491

Facility ID: 30028
Last Inspected On: 10/14/2020
Operating Permit Renewal Date: 02/10/2024

Owner Operator Contact: Automatic Car Wash Inc;Gary Carlson;Automatic Car Wash Inc **4062482558**

Operator Contact: Gene Carlson **4062482558**

Owner/Operator: Automatic Car Wash Inc

Duane Wiederrich, UST Class B Operator
Gene Carlson, UST Class A Operator
Gene Carlson, UST Class B Operator
Keith Warford, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	33	05/04/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
406	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/07/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		11/05/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	33	05/04/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
407	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/07/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		11/06/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

06	33	05/04/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
408	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/07/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		11/06/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: DONS EXPRESS CENTER
2344 Central Ave
Billings, MT 59102 Yellowstone

Legacy ID:56-05072

Facility ID: 29995
Last Inspected On: 06/22/2020
Operating Permit Renewal Date: 09/25/2023

Owner Operator Contact: Automatic Car Wash Inc;Candy Woolford;Exxon Company USA Dallas

2143484566

Operator Contact: Eric Carlson;Gene Carlson

4062482558;4068942373

Owner/Operator: Automatic Car Wash Inc

- Eric Carlson, UST Class A Operator
- Eric Carlson, UST Class B Operator
- Gene Carlson, UST Class A Operator
- Clinton Deyle, UST Class A Operator
- Clinton Deyle, UST Class B Global Operator
- Clinton Deyle, UST Class B Operator
- Dallas Amman, UST Class A Operator
- Dallas Amman, UST Class B Global Operator
- Dallas Amman, UST Class B Operator
- Gene Carlson, UST Class A Operator
- Gene Carlson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

05	27	11/08/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2002	No			Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/17/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
20,000		08/10/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	27	11/08/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2003	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/17/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		08/07/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	27	11/08/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2004	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		07/17/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		08/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
01	13	06/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5160	No		Double-Walled	Double Walled	Yes
Currently in Use		12/11/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
12,000		01/23/2017	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
02	13	06/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5161	No		Double-Walled	Double Walled	Yes
Currently in Use		12/11/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No

5,000		01/23/2017	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
03	13	06/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5162	No		Double-Walled	Double Walled	Yes
Currently in Use		12/11/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
5,000		01/23/2017	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
04	13	06/29/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5163	No		Double-Walled	Double Walled	Yes
Currently in Use		12/11/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
5,000		01/23/2017	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: DOWNTOWN CONOCO
2701 6th Ave N
Billings, MT 59101 Yellowstone

Legacy ID:56-06967

Facility ID: 30152
Last Inspected On: 11/25/2020
Operating Permit Renewal Date: 01/28/2024

Owner Operator Contact: Suzanne Lucas;RMG Inc

4066704115

Operator Contact: Jim Murphy;Mun Lee;Paul Murphy

4066708112;4066979003;4068501920

Owner/Operator: Downtown Conoco - Stanford

Owner/Operator: George Woodhall

Owner/Operator: RMG Inc

- Jim Murphy, UST Class A Operator
- Jim Murphy, UST Class B Operator
- Mun Lee, UST Class A Operator
- Mun Lee, UST Class B Operator
- Paul Murphy, UST Class A Operator
- Paul Murphy, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	53	04/22/1968	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
3621	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		02/28/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000		10/16/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	51	04/22/1970	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
3622	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		02/28/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000		10/06/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	47	04/22/1974	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
3623	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		02/28/2017	Automatic Tank Gauging 0.2	ELLD 0.2	No
6,000		10/13/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: EXXONMOBIL BILLINGS PRODUCTS TERMINAL
607 Exxonmobil Rd
Billings, MT 59101 Yellowstone

Legacy ID:56-11335

Facility ID: 30374
Last Inspected On: 03/13/2019
Operating Permit Renewal Date: 05/12/2022

Owner Operator Contact: Exxon Mobil Corporation Billings

8326254085

Operator Contact: Bry Joaillier Allen;Christopher Martin;Christy Minnis;James Vokral;Janie Lee;Jason Martin;Michael Bailey;Michael James;Robert Ochsenbein;Tyler Wattles

4064138460;4065866927;4066575404;4357647049;8326247774;8326247876;9013028249

Owner/Operator: Exxon Mobil Corporation Billings

Bry Joaillier Allen, UST Class A Operator
 Bry Joaillier Allen, UST Class B Global Operator
 Christopher Martin, UST Class A Operator
 Christopher Martin, UST Class B Operator
 Christy Minnis, UST Class A Operator
 Christy Minnis, UST Class B Global Operator
 James Vokral, UST Class A Operator
 James Vokral, UST Class B Global Operator
 Janie Lee, UST Class A Operator
 Janie Lee, UST Class B Global Operator
 M Martin, UST Class A Operator
 M Martin, UST Class B Global Operator
 Michael Bailey, UST Class A Operator
 Michael Bailey, UST Class B Global Operator
 Michael James, UST Class A Operator
 Michael James, UST Class B Global Operator
 Robert Ochsenbein, UST Class A Operator
 Robert Ochsenbein, UST Class B Global Operator
 Tyler Wattles, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S16	0		Bare Steel	Steel	
	No			None	Yes
Currently in Use				Not Listed	
Oil/Water Separator		10/03/2008	Deferred	Deferred	No
4,000		11/10/2009			No

37	27	10/01/1994	Steel Clad	Steel	High Level Alarm
2736	No		Double-Walled	None	Yes
Currently in Use			Not Required	Gravity Feed	Impressed Current
Mixture		12/05/2015	Continuous Interstitial Monitoring	3-Year Line Tightness Test	No
3,000		11/22/2015			No
S02	71	01/01/1950	Unknown	Steel - Terminal Piping	
2738	Yes			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		12/05/2015	Deferred	Terminal Piping Annual Line Test	No
197,000		11/17/2015			No
S13	71	01/01/1950	Unknown	Steel - Terminal Piping	
2749	Yes			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		12/05/2015	Deferred	Terminal Piping Annual Line Test	No
60,000		11/22/2015			No
S14	71	01/01/1950	Unknown	Steel - Terminal Piping	
2750	Yes			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		12/05/2015	Deferred	Terminal Piping Annual Line Test	No
60,000		11/22/2015			No
S44	24	05/01/1997	Unknown	Steel	
2751	Yes	12/22/2016		Secondary Containment Chase	Yes
Currently in Use		01/04/2017	Continuous Interstitial Monitoring	Pressurized	

Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
15,000		11/10/2009			No
S45	24	05/01/1997	Unknown	Steel	
2752	Yes			None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
6,000		11/10/2009			No
S46	24	05/01/1997	Unknown	Steel	
2753	Yes			None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
6,000		11/10/2009			No
S47	24	05/01/1997	Unknown	Steel	
2754	Yes			None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
6,000		11/10/2009			No
S48	24	05/01/1997	Unknown	Steel	
2755	Yes			None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
6,000		11/10/2009			No
S49	24	05/01/1997	Unknown	Steel	

2756	Yes			None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
6,000		11/10/2009			No
S39	24	05/01/1997	Unknown	Steel	
2758	Yes	12/22/2016		Secondary Containment Chase	Yes
Currently in Use		01/04/2017	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
15,000		11/10/2009			No
S40	24	05/01/1997	Unknown	Steel	
2759	Yes	12/22/2016		Secondary Containment Chase	Yes
Currently in Use		01/04/2017	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
15,000		11/10/2009			No
S41	24	05/01/1997	Unknown	Steel	
2760	Yes	12/22/2016		Secondary Containment Chase	Yes
Currently in Use		01/04/2017	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
15,000		11/10/2009			No
S42	24	05/01/1997	Unknown	Steel	
2761	Yes	12/22/2016		Secondary Containment Chase	Yes
Currently in Use		01/04/2017	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No

15,000		11/10/2009			No
S43	24	05/01/1997	Unknown	Steel	
2762	Yes	12/22/2016		Secondary Containment Chase	Yes
Currently in Use		01/04/2017	Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
15,000		11/10/2009			No
S50	24	05/01/1997	Unknown	Steel	
2763	Yes			None	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Impressed Current
Hazardous Substance		10/03/2008	Deferred	Continuous Interstitial Monitoring	No
6,000		11/10/2009			No
S34	69	01/01/1952	Unknown	Steel - Terminal Piping	
2764	Yes			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Gasoline		12/05/2015	Deferred	Terminal Piping Annual Line Test	No
2,959,110		11/17/2015			No
S35	69	01/01/1952	Unknown	Steel - Terminal Piping	
2765	Yes			None	Yes
Currently in Use			Not Required	Pressurized	Impressed Current
Diesel		12/05/2015	Deferred	Terminal Piping Annual Line Test	No
1,784,454		11/17/2015			No
S36	69	01/01/1952	Unknown	Steel - Terminal Piping	
2766	Yes			None	Yes

Currently in Use		Not Required	Pressurized	Impressed Current
Diesel	12/05/2015	Deferred	Terminal Piping Annual Line Test	No
1,749,888	11/17/2015			No

Facility Summary in Yellowstone County in the City of Billings

Location: FED EX FREIGHT
7107 Commercial Ave
Billings, MT 59101 Yellowstone

Legacy ID:60-15181

Facility ID: 30907
Last Inspected On: 10/22/2020
Operating Permit Renewal Date: 03/17/2024

Owner Operator Contact: K W Billings LLC

6194351614

Operator Contact: Adren Hillenburg;Chong Lee

4086543112

Owner/Operator: K W Billings LLC

Adren Hillenburg, UST Class A Operator
Adren Hillenburg, UST Class B Global Operator
Chong Lee, UST Class A Operator
Jon Schaffer, UST Class B Operator
Kevin Roberts, UST Class B Operator
Nick Haynes, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	10	05/23/2011	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5293	No		Double-Walled	Double Walled	Yes
Currently in Use		04/29/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
20,000		11/17/2017	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: FEDEX GROUND BILLINGS
3815 Hesper Rd
Billings, MT 59106 Yellowstone

Legacy ID:60-15209

Facility ID: 30929
Last Inspected On: 01/13/2020
Operating Permit Renewal Date: 01/17/2023

Owner Operator Contact: FedEx Ground Package System Inc

Operator Contact: Gaylyn Frosini

Owner/Operator: FedEx Ground Package System Inc

Derek Kouzmanoff, UST Class B Operator
Gaylyn Frosini, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	8	10/01/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
5447	No	11/06/2013	Double-Walled	Double Walled	Yes
Currently in Use		10/24/2013	Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
30,000		10/27/2017	Gilbarco-Veeder Root/TLS-450		Yes
02	8	10/01/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
5448	No	11/09/2013	Double-Walled	Double Walled	Yes
Currently in Use		10/24/2013	Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
30,000		10/27/2017	Gilbarco-Veeder Root/TLS-450		Yes
03	8	10/01/2013	Fiberglass Reinforced Plastic	Steel	Ball Float Valve;High Level Alarm
5449	No	11/09/2014	Double-Walled	Double Walled	Yes
Currently in Use		10/24/2013	Not Required	Safe Suction	Non-corrodible

Biodiesel, <=B20			Continuous Interstitial Monitoring	Deferred	No
12,000			Gilbarco-Veeder Root/TLS-450		Yes
04	8	10/01/2013	Fiberglass Reinforced Plastic		High Level Alarm
5450	No		Double-Walled		Yes
Currently in Use					Non-corrodible
DEF (Not Regulated)			Continuous Interstitial Monitoring		No
8,000					No
05	0		Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5930	No		Double-Walled	Double Walled	No
Currently in Use			Not Required	Safe Suction	Non-corrodible
Other			Continuous Interstitial Monitoring	Deferred	No
1,500					Yes

Facility Summary in Yellowstone County in the City of Billings

Location: FIRST INTERSTATE CENTER
401 N 31st St
Billings, MT 59101-1200 Yellowstone

Legacy ID:56-13766

Facility ID: 30460
Last Inspected On: 12/07/2018
Operating Permit Renewal Date: 06/01/2022

Owner Operator Contact: Billings 401 LLC

4062557100

Operator Contact: Jerome Ries

Owner/Operator: Billings 401 LLC

Brad Zimmer, UST Class B Operator
Jerome Ries, UST Class A Operator
Jerome Ries, UST Class B Operator
Jim Zimmer, UST Class B Operator
Leonard Meyer, UST Class B Operator
Patrick Kelly, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	23	10/01/1998	Steel Clad	Flexible Plastic	Flapper Valve
3400	No	09/20/2018	Double-Walled	Double Walled	Yes
Currently in Use		Not Required	U.S. Suction	Galvanic	
Diesel	01/16/2013	Manual Interstitial Monitoring	Manual Interstitial Monitoring	No	
560				No	

Facility Summary in Yellowstone County in the City of Billings

Location: FLYING J INC BILLINGS
2775 Old Hardin Rd
Billings, MT 59101 Yellowstone

Legacy ID:56-12585

Facility ID: 30405
Last Inspected On: 08/18/2020
Operating Permit Renewal Date: 02/13/2024

Owner Operator Contact: Don Edmisten;Montana Innovations LLC;Joey Cupp;Pilot Flying J

4064976948

Operator Contact: Trent Biggers

Owner/Operator: Billings 7 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	30	08/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1105	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline	11/29/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No	
12,000	06/26/2007	Gilbarco-Veeder Root/TLS-350		No	

04	30	08/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1108	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		11/29/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
20,000		06/26/2007			No
05	30	08/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1109	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		11/29/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
20,000		06/26/2007			No
06	30	08/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
1110	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		11/29/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
20,000		06/26/2007			No
02	30	08/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
4447	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		11/29/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		06/26/2007			No
03	30	08/01/1991	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve

4448	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		11/29/2012	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000		06/26/2007			No
07	8	08/01/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5425	No	10/04/2013	Double-Walled	Double Walled	Yes
Currently in Use		06/25/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		Yes
09	8	08/01/2013	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5427	No	10/04/2013	Double-Walled	Double Walled	Yes
Currently in Use		06/25/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: FOOD SERVICES OF AMERICA BILLINGS
802 Parkway Ln
Billings, MT 59101-4651 Yellowstone

Legacy ID:56-06132

Facility ID: 30089
Last Inspected On: 07/10/2019
Operating Permit Renewal Date: 12/14/2022

Owner Operator Contact: Food Services of America Inc

Operator Contact: Jeff Brent;Rick Hansen;Rod Ostman;Stace Hovland **4062387810;4066960810;4068395990**

Owner/Operator: Food Services of America Inc

David Lake, UST Class B Operator
Jeff Brent, UST Class A Operator
Jeff Brent, UST Class B Operator
Rick Hansen, UST Class A Operator

Rod Ostman, UST Class A Operator
 Stace Hovland, UST Class A Operator
 Stace Hovland, UST Class B Global Operator
 Stace Hovland, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	28	11/02/1993	Cathodically Protected Steel	Steel	High Level Alarm
1781	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		09/09/2016	Automatic Tank Gauging 0.2	Deferred	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: GAS N GO
 800 Jackson St
 Billings, MT 59101-5451 Yellowstone

Legacy ID:56-10866

Facility ID: 30363
Last Inspected On: 10/10/2019
Operating Permit Renewal Date: 01/04/2023

Owner Operator Contact:

Operator Contact: Connie Pelican

4066565882

Owner/Operator: Connie Pelican

Owner/Operator: TLC Enterprises Inc Laurel

Connie Pelican, UST Class A Operator
 Lisa Pelican, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	04/10/1984	Cathodically Protected Steel	Steel	Flapper Valve

4551	No	Lined Interior/Impressed Current	None	Yes
Currently in Use		Not Required	Safe Suction	Impressed Current
Gasoline	10/13/2016	Statistical Inventory Reconciliation	Deferred	No
6,000				No

Facility Summary in Yellowstone County in the City of Billings

Location: GM PETROLEUM DISTRIBUTORS
2100 1st Ave S
Billings, MT 59101 Yellowstone

Legacy ID:56-06962

Facility ID: 30147
Last Inspected On: 01/15/2021
Operating Permit Renewal Date: 03/14/2024

Owner Operator Contact: City Service Valcon LLC DBA GM Petroleum Distributors

Operator Contact: Jay Brookie;Laura Geffre;Margaret Flynn;Roger Schmechel

4062083147;4062524661;4062940863

Owner/Operator: City Service Valcon LLC

Owner/Operator: City Service Valcon LLC DBA GM Petroleum Distributors

- Bill Grunstead, UST Class A Operator
- Roger Schmechel, UST Class A Operator
- Roger Schmechel, UST Class B Operator
- Bill Grunstead, UST Class A Operator
- Laura Geffre, UST Class A Operator
- Laura Geffre, UST Class B Operator
- Roger Schmechel, UST Class A Operator
- Roger Schmechel, UST Class B Operator
- Jay Brookie, UST Class A Operator
- Jay Brookie, UST Class B Global Operator
- Laura Geffre, UST Class A Operator
- Laura Geffre, UST Class B Operator
- Margaret Flynn, UST Class A Operator
- Margaret Flynn, UST Class B Operator
- Roger Schmechel, UST Class A Operator
- Roger Schmechel, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	36	06/01/1985	Bare Steel	Steel	High Level Alarm
1167	No			None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		07/05/2018	Automatic Tank Gauging 0.2	Not Listed	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	36	06/01/1985	Bare Steel	Steel	High Level Alarm
1168	No			None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		07/05/2018	Automatic Tank Gauging 0.2	Not Listed	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	36	06/01/1985	Bare Steel	Steel	High Level Alarm
1169	No			None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		07/05/2018	Automatic Tank Gauging 0.2	Not Listed	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	36	06/01/1985	Bare Steel	Steel	High Level Alarm
4626	No			None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		07/05/2018	Automatic Tank Gauging 0.2	Not Listed	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	38	05/07/1983	Bare Steel	Steel	High Level Alarm
4627	No			None	Yes

Currently in Use		Not Required	Gravity Feed	Impressed Current
Oil, Waste	07/05/2018	Automatic Tank Gauging 0.2	Deferred	No
1,000		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: HEIGHTS CAR CARE
1320 Main St
Billings, MT 59105-1742 Yellowstone

Legacy ID:56-06960

Facility ID: 30146
Last Inspected On: 04/02/2019
Operating Permit Renewal Date: 12/12/2019

Owner Operator Contact: Christan Automotive Repair Service LLC;Dennis Whitmore;Petro Services Co Inc **4062593709;4066515101**

Operator Contact: Joseph Borgstrom **4062593709**

Owner/Operator: Christan Automotive Repair Service LLC

Joseph Borgstrom, UST Class A Operator
Joseph Borgstrom, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	45	04/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1164	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing	No
10,000		08/01/2016			No
02	45	04/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1165	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing	No
10,000		08/01/2016			No

03	45	04/21/1976	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1166	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing	No
5,000		08/01/2016			No

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STATIONSTORE 108
790 S Billings Blvd
Billings, MT 59101-4709 Yellowstone

Legacy ID:56-13994

Facility ID: 30655
Last Inspected On: 11/26/2019
Operating Permit Renewal Date: 02/04/2023

Owner Operator Contact: Camie Pederson;Rocky Mountain Oil LLC - Env Director **9528308899**

Operator Contact: Chuck Nyberg;Kegan Krueger;Patrick Patnaude;Stephen Reckinger;Valeria Jeffries;Veronica Rivera **4063210938;9528308028;9528308721;9528308722**

Owner/Operator: Rocky Mountain Oil Co Inc

- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Jeff Reed, UST Class B Global Operator
- Kegan Krueger, UST Class A Operator
- Patrick Patnaude, UST Class A Operator
- Stephanie Wilz, UST Class B Global Operator
- Stephen Reckinger, UST Class A Operator
- Valeria Jeffries, UST Class A Operator
- Veronica Rivera, UST Class A Operator
- Veronica Rivera, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	05/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4285	No		Double-Walled	Double Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2;Statistical Inventory Reconciliation	No
10,000		06/19/2010	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
02	20	05/04/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4286	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2;Statistical Inventory Reconciliation	Yes
10,000		06/29/2010	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
03	20	05/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4287	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2;Statistical Inventory Reconciliation	Yes
10,000		07/25/2010	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
04	20	05/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4288	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2;Statistical Inventory Reconciliation	Yes
20,000		06/22/2009	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STATIONSTORE 266
745 Grand Ave
Billings, MT 59101 Yellowstone

Legacy ID:56-08058

Facility ID: 30210
Last Inspected On: 05/08/2019
Operating Permit Renewal Date: 05/23/2022

Owner Operator Contact: Camie Pederson;Rocky Mountain Oil LLC - Env Director

9528308899

Operator Contact: Chuck Nyberg;Kegan Krueger;Patrick Patnaude;Stephen Reckinger;Valeria Jeffries

4063210938;9528308028;9528308721;9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator
Chuck Nyberg, UST Class A Operator
Courtney Sheriff, UST Class B Operator
Jeff Reed, UST Class B Global Operator
Kegan Krueger, UST Class A Operator
Kenneth Sheehan, UST Class B Operator
Leonard Slemp, UST Class B Global Operator
Patrick Patnaude, UST Class A Operator
Stephen Reckinger, UST Class A Operator
Valeria Jeffries, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	26	06/08/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3036	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		07/29/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
12,000		03/23/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	26	06/08/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3037	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline		07/29/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000		03/23/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	26	06/08/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3038	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		07/29/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000		03/23/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	26	06/08/1995	Steel Clad	Flexible Plastic	Ball Float Valve
3039	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		07/29/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000		03/23/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STATIONSTORE 274
2620 6th Ave N
Billings, MT 59101 Yellowstone

Legacy ID:56-08062

Facility ID: 30211
Last Inspected On: 05/08/2019
Operating Permit Renewal Date: 10/29/2022

Owner Operator Contact: Camie Pederson;Rocky Mountain Oil LLC - Env Director **9528308899**

Operator Contact: Chuck Nyberg;Kegan Krueger;Patrick Patnaude;Stephen Reckinger;Valeria Jeffries **4063210938;9528308028;9528308721;9528308722**

Owner/Operator: Rocky Mountain Oil Co Inc

- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Jeff Reed, UST Class B Global Operator
- Kegan Krueger, UST Class A Operator
- Melissa Nightengale, UST Class B Operator
- Michael Boileau, UST Class B Operator
- Patrick Patnaude, UST Class A Operator
- Stephen Reckinger, UST Class A Operator
- Stephen Reckinger, UST Class B Global Operator
- Valeria Jeffries, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	26	10/01/1995	Steel Clad	Flexible Plastic	Positive Shutoff
3040	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		08/23/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
8,000		12/25/2009	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	26	10/01/1995	Steel Clad	Flexible Plastic	Positive Shutoff
3042	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		08/23/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
10,000		12/25/2009	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	26	10/01/1995	Steel Clad	Flexible Plastic	Positive Shutoff
4399	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		08/23/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
8,000		12/25/2009	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STATIONSTORE 275
105 Broadwater Ave
Billings, MT 59101 Yellowstone

Legacy ID:56-08063

Facility ID: 30212
Last Inspected On: 05/14/2020
Operating Permit Renewal Date: 11/06/2023

Owner Operator Contact: Camie Pederson; Rocky Mountain Oil LLC - Env Director

9528308899

Operator Contact: Chuck Nyberg;Kegan Krueger;Lisa Pedersen;Patrick Patnaude;Valeria Jeffries;Veronica Rivera;Holiday Stationstore 275

4063210938;6128308891;9528308721;9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator
 Chuck Nyberg, UST Class A Operator
 Jeff Reed, UST Class B Global Operator
 Kegan Krueger, UST Class A Operator
 Lisa Pedersen, UST Class A Operator
 Lisa Pedersen, UST Class B Operator
 Patrick Patnaude, UST Class A Operator
 Valeria Jeffries, UST Class A Operator
 Veronica Rivera, UST Class A Operator
 Veronica Rivera, UST Class B Global Operator
 Veronica Rivera, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	26	07/13/1995	Steel Clad	Flexible Plastic	Positive Shutoff
3043	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/24/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	Yes
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
06	26	07/13/1995	Steel Clad	Flexible Plastic	Positive Shutoff
3044	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/24/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

07	26	07/13/1995	Steel Clad	Flexible Plastic	Positive Shutoff
3045	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/24/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	26	07/13/1995	Steel Clad	Flexible Plastic	Positive Shutoff
3046	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/24/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	26	07/13/1995	Steel Clad	Flexible Plastic	Positive Shutoff
3047	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		05/24/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STATIONSTORE 280
1020 Main St
Billings, MT 59105-2544 Yellowstone

Legacy ID:56-09695

Facility ID: 30314
Last Inspected On: 05/15/2020
Operating Permit Renewal Date: 05/29/2023

Owner Operator Contact:

Operator Contact: Chuck Nyberg; Patrick Patnaude; Stephen Reckinger; Valeria Jeffries; Veronica Rivera

9528308028; 9528308721; 9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator
Chuck Nyberg, UST Class A Operator
Jeff Reed, UST Class B Global Operator
Patrick Patnaude, UST Class A Operator
Stephanie Wilz, UST Class B Global Operator

Stephen Reckinger, UST Class A Operator
 Valeria Jeffries, UST Class A Operator
 Veronica Rivera, UST Class A Operator
 Veronica Rivera, UST Class B Global Operator
 Zachary Simeson, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	34	04/01/1987	Cathodically Protected Steel	Steel	Flapper Valve
3048	No	10/03/2013		None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		05/26/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
12,000		03/12/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	34	04/01/1987	Cathodically Protected Steel	Steel	Flapper Valve
3049	No	10/03/2013		None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		05/26/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
12,000		11/27/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	34	04/01/1987	Cathodically Protected Steel	Steel	Flapper Valve
3050	No	10/03/2013		None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		05/26/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
8,000		06/25/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	34	04/01/1987	Cathodically Protected Steel	Steel	Flapper Valve

3051	No	10/03/2013		None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		05/26/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		03/14/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STATIONSTORE 284
3226 Rosebud Dr
Billings, MT 59102-6017 Yellowstone

Legacy ID:56-09752

Facility ID: 30326
Last Inspected On: 01/28/2020
Operating Permit Renewal Date: 05/30/2023

Owner Operator Contact: Steve Visocan;Visocan Petroleum Co Helena

Operator Contact: Chuck Nyberg;Patrick Patnaude;Valeria Jeffries;Veronica Rivera

9528308721;9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

Brad Lee, UST Class B Global Operator
Chuck Nyberg, UST Class A Operator
Jeff Reed, UST Class B Global Operator
Patrick Patnaude, UST Class A Operator
Valeria Jeffries, UST Class A Operator
Veronica Rivera, UST Class A Operator
Veronica Rivera, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	38	11/05/1983	Cathodically Protected Steel	Steel	Flapper Valve
3052	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		03/20/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	38	11/05/1983	Cathodically Protected Steel	Steel	Flapper Valve

3053	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	03/20/2017		Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	38	11/05/1983	Cathodically Protected Steel	Steel	Flapper Valve
3054	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	03/20/2017		Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	Yes
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STATIONSTORE 285
785 S 20th St W
Billings, MT 59102-6463 Yellowstone

Legacy ID:56-09753

Facility ID: 30327
Last Inspected On: 09/04/2020
Operating Permit Renewal Date: 01/22/2024

Owner Operator Contact: Camie Pederson;Rocky Mountain Oil LLC - Env Director

9528308899

Operator Contact: Chuck Nyberg;Patrick Patnaude;Valeria Jeffries;Veronica Rivera

9528308721;9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Jeff Reed, UST Class B Global Operator
- Patrick Patnaude, UST Class A Operator
- Russell Ericson, UST Class B Operator
- Valeria Jeffries, UST Class A Operator
- Veronica Rivera, UST Class A Operator
- Veronica Rivera, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

05	24	04/01/1997	Steel Clad	Flexible Plastic	Ball Float Valve;High Level Alarm
3055	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		10/25/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000		03/17/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	24	04/01/1997	Steel Clad	Flexible Plastic	Ball Float Valve;High Level Alarm
3056	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		10/25/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000		03/17/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	24	04/01/1997	Steel Clad	Flexible Plastic	Ball Float Valve;High Level Alarm
3057	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		10/25/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000		08/17/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	24	04/01/1997	Steel Clad	Flexible Plastic	Ball Float Valve;High Level Alarm
3058	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		10/25/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000		08/25/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	24	04/01/1997	Steel Clad	Flexible Plastic	Ball Float Valve;High Level Alarm
3059	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	

Diesel	10/25/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
8,000	09/12/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STORE 385
3551 Ember Ln
Billings, MT 59102 Yellowstone

Legacy ID:60-15065

Facility ID: 30837
Last Inspected On: 01/17/2020
Operating Permit Renewal Date: 05/20/2023

Owner Operator Contact:

Operator Contact: Chuck Nyberg;Patrick Patnaude;Valeria Jeffries;Veronica Rivera

9528308721;9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Jeff Luedtke, UST Class B Global Operator
- Jeff Reed, UST Class B Global Operator
- Patrick Patnaude, UST Class A Operator
- Valeria Jeffries, UST Class A Operator
- Veronica Rivera, UST Class A Operator
- Veronica Rivera, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	14	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5139	No		Double-Walled	Double Walled	Yes
Currently in Use		07/12/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
02	14	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5140	No		Double-Walled	Double Walled	Yes

Currently in Use		07/12/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
03	14	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5141	No		Double-Walled	Double Walled	Yes
Currently in Use		07/12/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	Yes
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
04	14	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5142	No		Double-Walled	Double Walled	Yes
Currently in Use		07/12/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
05	14	12/11/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5143	No		Double-Walled	Double Walled	Yes
Currently in Use		07/12/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STATIONSTORE 470
1212 Mallowney Ln
Billings, MT 59102 Yellowstone

Legacy ID:60-15327

Facility ID: 31023
Last Inspected On: 10/18/2019
Operating Permit Renewal Date: 12/17/2022

Owner Operator Contact:

Operator Contact: Chuck Nyberg

9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

Chuck Nyberg, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5880	No		Double-Walled	Double Walled	No
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
20,000			Incon/TS-550 EVO		No
02	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5881	No		Double-Walled	Double Walled	No
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Incon/TS-550 EVO		No
03	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5882	No		Double-Walled	Double Walled	No
Currently in Use		11/15/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Incon/TS-550 EVO		No
04	3	11/15/2018	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5883	No		Double-Walled	Double Walled	No

Currently in Use	11/15/2018	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		Incon/TS-550 EVO		No

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STATIONSTORE 731
1280 Grand Ave
Billings, MT 59102 Yellowstone

Legacy ID:56-14090

Facility ID: 30741
Last Inspected On: 06/18/2021
Operating Permit Renewal Date: 10/01/2024

Owner Operator Contact:

Operator Contact: Chuck Nyberg;Patrick Patnaude;Valeria
Jeffries;Veronica Rivera

9528308721;9528308722

Owner/Operator: Rocky Mountain Oil Co Inc

- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Jeff Reed, UST Class B Global Operator
- Patrick Patnaude, UST Class A Operator
- Valeria Jeffries, UST Class A Operator
- Veronica Rivera, UST Class A Operator
- Veronica Rivera, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	18	06/24/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4844	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000		02/01/2018	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
02	18	06/24/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm

4845	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000		02/02/2018	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
03	18	06/24/2003	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
4846	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
5,000		01/30/2018	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: HOLIDAY STATIONSTORE 87
4041 Grand Ave
Billings, MT 59106-1731 Yellowstone

Legacy ID:56-13723

Facility ID: 30457
Last Inspected On: 05/08/2019
Operating Permit Renewal Date: 05/23/2022

Owner Operator Contact:

Operator Contact: Chuck Nyberg;Kegan Krueger;Patrick Patnaude;Stephen Reckinger;Valeria Jeffries;Veronica Rivera **4063210938;9528308028;9528308721;9528308722**

Owner/Operator: Rocky Mountain Oil Co Inc

- Brad Lee, UST Class B Global Operator
- Chuck Nyberg, UST Class A Operator
- Greg Hoffman, UST Class B Operator
- Jeff Reed, UST Class B Global Operator
- Kegan Krueger, UST Class A Operator
- Patrick Patnaude, UST Class A Operator
- Stephen Reckinger, UST Class A Operator
- Valeria Jeffries, UST Class A Operator
- Veronica Rivera, UST Class A Operator
- Veronica Rivera, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected

Status	Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types	
Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	25	06/01/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3062	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	07/11/2013		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000	06/21/2013		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	25	06/01/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3063	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	07/11/2013		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000	06/21/2013		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	25	06/01/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3064	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	07/11/2013		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000	06/21/2013		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
04	25	06/01/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3065	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	07/11/2013		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	Yes
8,000	06/21/2013		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

05	25	06/01/1996	Steel Clad	Flexible Plastic	Ball Float Valve
3066	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		07/11/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000		06/21/2013	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: JTL GROUP INC UST
1102 Shiloh Rd
Billings, MT 59106-2415 Yellowstone

Legacy ID:56-14001

Facility ID: 30662
Last Inspected On: 04/26/2019
Operating Permit Renewal Date: 05/23/2022

Owner Operator Contact: JTL Group Inc

4066552012

Operator Contact: Brian Nickel; Dan Ottman

4066512476

Owner/Operator: JTL Group Inc

- Brian Nickel, UST Class A Operator
- Brian Nickel, UST Class B Global Operator
- Brian Nickel, UST Class B Operator
- Dan Ottman, UST Class A Operator
- Dan Ottman, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	20	04/01/2001	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4397	No		Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2	Deferred	No
1,958			Veeder Root/TLS-350		No
02	20	04/01/2001	Steel Clad	Flexible Plastic	High Level Alarm

4398	No	Double-Walled	Double Walled	Yes
Currently in Use		Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
13,019		Veeder Root/TLS-350		No

Facility Summary in Yellowstone County in the City of Billings

Location: LYNCH FLYING SERVICE
1691 Aviation PI
Billings, MT 59105 Yellowstone

Legacy ID:56-07797

Facility ID: 30200
Last Inspected On: 10/14/2020
Operating Permit Renewal Date: 10/29/2023

Owner Operator Contact: Lynch Flying Service Inc;N/A ZZZ - TBL_OWN : 4062520508
624;Lynch Flying Service Inc;Robb Bergeson;Edwards
Jet Center

Operator Contact: Aaron VanLuchene;Joel Simmons;Parker Hesper;Robert McCullough;Warren Nemitz 4062478916;4062520508

Owner/Operator: Lynch Flying Service Inc

- Aaron VanLuchene, UST Class A Operator
- Aaron VanLuchene, UST Class B Global Operator
- Joel Simmons, UST Class A Operator
- Joel Simmons, UST Class B Operator
- Parker Hesper, UST Class A Operator
- Parker Hesper, UST Class B Global Operator
- Robert McCullough, UST Class A Operator
- Robert McCullough, UST Class B Operator
- Warren Nemitz, UST Class A Operator
- Warren Nemitz, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	31	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1563	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic

Jet Fuel (Jet-A, Jet-A1, JP5)		07/05/2018	Automatic Tank Gauging 0.2	Deferred	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	31	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1564	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel (Jet-A, Jet-A1, JP5)		07/05/2018	Automatic Tank Gauging 0.2	Deferred	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	31	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1565	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel (Jet-A, Jet-A1, JP5)		07/05/2018	Automatic Tank Gauging 0.2	Deferred	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
11	31	10/25/1990	Cathodically Protected Steel	No Piping	High Level Alarm
1566	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Aviation Gas		07/05/2018	Automatic Tank Gauging 0.2	Deferred	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
12	31	10/25/1990	Cathodically Protected Steel	Steel	High Level Alarm
1567	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline		07/05/2018	Automatic Tank Gauging 0.2	Deferred	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
13	23	06/26/1998	Cathodically Protected Steel	No Piping	High Level Alarm

1568	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel (Jet-A, Jet-A1, JP5)		07/05/2018	Automatic Tank Gauging 0.2	Deferred	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
14	23	06/26/1998	Cathodically Protected Steel	No Piping	High Level Alarm
1569	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Jet Fuel (Jet-A, Jet-A1, JP5)		07/05/2018	Automatic Tank Gauging 0.2	Deferred	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
15	0		Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5909	No		Double-Walled	None	No
Currently in Use			Not Required	Safe Suction	Non-corrodible
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Deferred	No
30,000					Yes
16	0		Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5910	No		Double-Walled	None	No
Currently in Use			Not Required		Non-corrodible
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Deferred	No
30,000					Yes

Facility Summary in Yellowstone County in the City of Billings

Location: LYNCH FLYING SERVICE INC
1482 Aviation Place
Billings, MT 59105 Yellowstone

Legacy ID:60-15100

Facility ID: 30859
Last Inspected On: 07/20/2020
Operating Permit Renewal Date: 10/15/2023

Owner Operator Contact:

Owner/Operator: Edwards Jet Center

Owner/Operator: Paul Gatzemeier

- Aaron VanLuchene, UST Class A Operator
- Aaron VanLuchene, UST Class B Global Operator
- Joel Simmons, UST Class A Operator
- Joel Simmons, UST Class B Operator
- Parker Hesper, UST Class A Operator
- Parker Hesper, UST Class B Global Operator
- Warren Nemitz, UST Class A Operator
- Warren Nemitz, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	13	02/25/2008	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5172	No	07/28/2014	Double-Walled	None	Yes
Currently in Use		02/22/2008	Continuous Interstitial Monitoring	Not Listed	Non-corrodible
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
02	13	02/25/2008	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5173	No	07/28/2014	Double-Walled	None	Yes
Currently in Use		02/22/2008	Continuous Interstitial Monitoring	Not Listed	Non-corrodible
Jet Fuel (Jet-A, Jet-A1, JP5)			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
20,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

03	13	02/25/2008	Fiberglass Reinforced Plastic	No Piping	High Level Alarm
5174	No	07/28/2014	Double-Walled	None	Yes
Currently in Use		02/22/2008	Continuous Interstitial Monitoring	Not Listed	Non-corrodible
Aviation Gas			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: MARKET BASKET STORE
8014 S Frontage Rd
Billings, MT 59101 Yellowstone

Legacy ID:56-08286

Facility ID: 30228
Last Inspected On: 02/08/2019
Operating Permit Renewal Date: 07/28/2022

Owner Operator Contact: Arnold Or Lynn Strand;Town and Country Supply Association

4066286314

Operator Contact: Teresa Bidleman

Owner/Operator: Town and Country Supply Association

Jeff Bidleman, UST Class B Operator
Teresa Bidleman, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	26	10/06/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve;High Level Alarm
3314	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		02/19/2016	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000		04/01/2016	Veeder Root/TLS-300		No
04	26	10/06/1995	Cathodically Protected Steel	Flexible Plastic	Flapper Valve;High Level Alarm
3315	No			Double Walled	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline	02/19/2016		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
4,000	04/01/2016		Veeder Root/TLS-300		No
05	18	11/28/2003	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4945	No			Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel	02/19/2016		Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000	04/01/2016		Veeder Root/TLS-300		No

Facility Summary in Yellowstone County in the City of Billings

Location: MCFINYS #2
3306 Rimrock Rd
Billings, MT 59102-0325 Yellowstone

Legacy ID:56-05090

Facility ID: 30008
Last Inspected On: 01/13/2020
Operating Permit Renewal Date: 02/24/2023

Owner Operator Contact:

Operator Contact: Joe McCullough;Ken McCullough

4062590466

Owner/Operator: Vesta Ventures LLP

Beverly Mundschenk, UST Class B Operator
Joe McCullough, UST Class A Operator
Joe McCullough, UST Class B Operator
Ken McCullough, UST Class A Operator
Ken McCullough, UST Class B Global Operator
Ken McCullough, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	34	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3681	No			None	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		02/16/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		02/16/2017	Gilbarco/EMC Basic		No
02	34	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3682	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		02/16/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
10,000		02/16/2017	Gilbarco/EMC Basic		No
03	34	11/30/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3683	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		02/16/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
8,000		02/16/2017	Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: MDOT BILLINGS
424 Morey St
Billings, MT 59101-4732 Yellowstone

Legacy ID:56-09501

Facility ID: 30307
Last Inspected On: 12/11/2019
Operating Permit Renewal Date: 04/25/2023

Owner Operator Contact: MDOT Helena

4064446163

Operator Contact: Jeff Gleason;Joe Radonich;Mike Murolo;Walt Kerttula

Owner/Operator: MDOT Helena

Bradley Becker, UST Class B Global Operator
Charlie Eddlemon, UST Class B Operator
Dennis Grimm, UST Class B Global Operator
Jeff Gleason, UST Class A Operator
Joe Radonich, UST Class A Operator
Joe Radonich, UST Class B Global Operator
John McCloskey, UST Class B Operator
Mike Murolo, UST Class A Operator
Walt Kerttula, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
06	28	09/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2948	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		01/06/2017	Automatic Tank Gauging 0.2	Deferred	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	28	09/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
2949	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		01/06/2017	Automatic Tank Gauging 0.2	Deferred	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: MERIDIAN AUTOMOTIVE SERVICE INC
1240 Ave C
Billings, MT 59102-3238 Yellowstone

Legacy ID:56-05077

Facility ID: 30000
Last Inspected On: 12/04/2020
Operating Permit Renewal Date:

Owner Operator Contact: Candy Woolford;Exxon Company USA Dallas;Meridian Automotive Service LLC **2143484566;4062596922**

Operator Contact: Richard Skewis

4062561020

Owner/Operator: Meridian Automotive Service LLC

Richard Skewis, UST Class A Operator

Richard Skewis, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
05	27	01/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3182	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline	07/02/2015		Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Not Listed	No
2,000			Gilbarco/EMC Basic		No
06	27	01/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3183	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Gasoline	07/02/2015		Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	Not Listed	No
4,000			Gilbarco/EMC Basic		No
07	27	01/11/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3184	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline	07/02/2015		Automatic Tank Gauging 0.1;Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000			Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: MIDWEST MOTOR EXPRESS INC
214 Orchard Ln
Billings, MT 59101-4952 Yellowstone

Legacy ID:56-14075

Facility ID: 30727
Last Inspected On: 01/29/2021
Operating Permit Renewal Date: 02/03/2024

Owner Operator Contact:

Operator Contact: Christopher Booth

4062455938

Owner/Operator: Midwest Motor Express

Christopher Booth, UST Class A Operator
Christopher Booth, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	18	01/09/2003	Steel Clad	Flexible Plastic	Flapper Valve
4782	No	10/15/2015	Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
20,000			Veeder Root/TLS-300		No

Facility Summary in Yellowstone County in the City of Billings

Location: MSU FACILITY SERVICES BLDG
1500 University Dr
Billings, MT 59101-0245 Yellowstone

Legacy ID:56-00904

Facility ID: 29741
Last Inspected On: 03/12/2021
Operating Permit Renewal Date: 08/21/2024

Owner Operator Contact: Montana State University Billings

4066572309

Operator Contact: Brian Mackey;Jason McGimpsey

4066725594

Owner/Operator: Montana State University Billings

Brian Mackey, UST Class A Operator
Brian Mackey, UST Class B Global Operator
Brian Mackey, UST Class B Operator
Jason McGimpsey, UST Class A Operator
John Grimstad, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve

846	No	Double-Walled	Double Walled	Yes
Currently in Use		Not Required	Safe Suction	Non-corrodible
Gasoline		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;Deferred	Yes
1,000		Veeder Root/TLS-300		No

Facility Summary in Yellowstone County in the City of Billings

Location: MT STATE WOMENS PRISON
701 S 27th St
Billings, MT 59101-4511 Yellowstone

Legacy ID:56-01757

Facility ID: 29788
Last Inspected On: 03/19/2021
Operating Permit Renewal Date: 04/04/2024

Owner Operator Contact: Montana State Womens Prison

Operator Contact: Joel Carlson;Michael Bangert

Owner/Operator: Montana State Womens Prison

Joel Carlson, UST Class A Operator
Joel Carlson, UST Class B Operator
Michael Bangert, UST Class A Operator
Michael Bangert, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	16	10/01/2005	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
5053	No	03/13/2018	Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Diesel		03/13/2018	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
2,000			Veeder Root/TLS-300		No

Facility Summary in Yellowstone County in the City of Billings

Location: NORTHWESTERN ENERGY FACILITY
405 S 20th St W
Billings, MT 59102-6343 Yellowstone

Legacy ID:56-01188

Facility ID: 29758
Last Inspected On: 10/09/2020
Operating Permit Renewal Date: 12/09/2023

Operator Contact: John Habeger

Owner/Operator: Northwestern Energy Butte

Darren Brockel, UST Class B Global Operator

John Habeger, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3-1	41	04/30/1980	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
1683	No			None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		10/05/2017	Automatic Tank Gauging 0.2	Deferred	No
4,000		10/05/2017	EMCO Electronics/EECO 1500		No
3-2	41	04/30/1980	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
1684	No			None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Diesel		10/05/2017	Automatic Tank Gauging 0.2	Deferred	No
2,000			EMCO Electronics/EECO 1500		No
3-3	41	04/30/1980	Cathodically Protected Steel	Steel	Flapper Valve;High Level Alarm
1685	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/05/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000			EMCO Electronics/EECO 1500		No

Facility Summary in Yellowstone County in the City of Billings

Location: OLD DOMINION FREIGHT LINES
1030 Intermountain St
Billings, MT 59101 Yellowstone

Legacy ID:60-15216

Facility ID: 30935
Last Inspected On: 09/01/2020
Operating Permit Renewal Date: 09/19/2023

Owner Operator Contact:

Operator Contact: James Ascheman;Lorrin Wallace;Richard McGuire **4062567082**

Owner/Operator: Old Dominion Freight Line

Ben Figg, UST Class B Global Operator
James Ascheman, UST Class A Operator
James Ascheman, UST Class B Operator
Lorrin Wallace, UST Class A Operator
Lorrin Wallace, UST Class B Global Operator
Richard McGuire, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	9	10/01/2012	Unknown	Fiberglass Reinforced Plastic	
5393	Yes		Double-Walled	Double Walled	No
Currently in Use		10/05/2012	Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;ELLD 0.1	No
15,000		09/01/2017			Yes

Facility Summary in Yellowstone County in the City of Billings

Location: PACIFIC SUPPLY
600 Daniel St
Billings, MT 59101-3221 Yellowstone

Legacy ID:56-04965

Facility ID: 29960
Last Inspected On: 04/24/2020
Operating Permit Renewal Date: 05/14/2020

Owner Operator Contact:

Operator Contact: Dennis Yonts;Kate Renner;Ryan Eklund **4062458876**

Owner/Operator: Pacific Coast Building Products Rancho Cordova

Dennis Yonts, UST Class A Operator

Kate Renner, UST Class A Operator
 Kayla Wittman, UST Class B Operator
 Ryan Eklund, UST Class A Operator
 Ryan Eklund, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	28	11/01/1993	Fiberglass Reinforced Plastic	Steel	Flapper Valve
4350	No		Double-Walled	Double Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	
Diesel			Continuous Interstitial Monitoring	Deferred	No
10,000			Other/Other		No

Facility Summary in Yellowstone County in the City of Billings

Location: PEPSI COLA BOTTLING CO BILLINGS
 344 Howard Ave
 Billings, MT 59101-3039 Yellowstone

Legacy ID:56-08323

Facility ID: 30261
Last Inspected On: 03/12/2021
Operating Permit Renewal Date: 06/13/2024

Owner Operator Contact: Pepsi Cola Bottling Co;Tom Dimich;Pepsi Cola Bottling Co **4062529355**

Operator Contact:

Owner/Operator: Pepsi Cola Bottling Co

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	31	08/01/1990	Cathodically Protected Steel	Steel	Flapper Valve

1798	No		None	Yes
Currently in Use		Not Required	Safe Suction	Galvanic
Gasoline	06/06/2018	Automatic Tank Gauging 0.2	Deferred	No
3,000		OPW/EECO 1500		No

Facility Summary in Yellowstone County in the City of Billings

Location: POLY CONOCO
1704 Poly Dr
Billings, MT 59102-1729 Yellowstone

Legacy ID:56-04414

Facility ID: 29908
Last Inspected On: 01/10/2019
Operating Permit Renewal Date: 02/13/2022

Owner Operator Contact:

Operator Contact: Lawrence Sperry

4062456944

Owner/Operator: Morledge - Hampton Family LLC

Lawrence Sperry, UST Class A Operator
Lawrence Sperry, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	23	02/11/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4718	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		04/05/2016	Gilbarco/EMC Basic		No
06	23	02/11/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4719	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No

7,000		04/05/2016	Gilbarco/EMC Basic		No
07	23	02/11/1998	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
4720	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		04/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
3,000		04/05/2016	Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: PUBLIC UTILITIES DEPT
2251 Belknap Ave
Billings, MT 59101-5706 Yellowstone

Legacy ID:56-09746

Facility ID: 30324
Last Inspected On: 03/11/2021
Operating Permit Renewal Date: 03/16/2024

Owner Operator Contact: Boris Krizek;City of Billings Public Works;City of Billings Public Works **4066578335**

Operator Contact: Margaret Pegues **4062478633**

Owner/Operator: City of Billings Public Works

Jason Harper, UST Class B Operator
Margaret Pegues, UST Class A Operator
Margaret Pegues, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	31	01/01/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
631	No			None	Yes
Currently in Use			Not Required	Safe Suction	
Gasoline		05/14/2018	Automatic Tank Gauging 0.2	Deferred	No
10,000			Gilbarco/EMC Basic		No
05	31	01/01/1990	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
632	No			None	Yes
Currently in Use			Not Required	Safe Suction	
Diesel		05/14/2018	Automatic Tank Gauging 0.2	Deferred	No
10,000			Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: QWEST BILLINGS WEST CENTRAL OFFICE
3190 Central Ave
Billings, MT 59102-6606 Yellowstone

Legacy ID:56-08762

Facility ID: 30285
Last Inspected On: 04/16/2021
Operating Permit Renewal Date: 05/17/2024

Owner Operator Contact: Qwest Corporation/Century Link

Operator Contact: Kevin Robison;Stephanie Miller;Thomas Pitts

2063467532;5016808141;8015983020

Owner/Operator: Qwest Corporation/Century Link

Kevin Robison, UST Class A Operator
Kevin Robison, UST Class B Global Operator
Stephanie Miller, UST Class A Operator
Stephanie Miller, UST Class B Global Operator
Thomas Pitts, UST Class A Operator
Thomas Pitts, UST Class B Global Operator
Thomas Pitts, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	27	11/01/1994	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
1733	No		Double-Walled	Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Non-corrodible
Diesel		08/20/2012	Automatic Tank Gauging 0.2	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
1,000		05/14/2018	Veeder Root/TLS-300		No

Facility Summary in Yellowstone County in the City of Billings

Location: RED LION HOTEL BILLINGS
5500 Midland Rd
Billings, MT 59101-6321 Yellowstone

Legacy ID:56-14103

Facility ID: 30746
Last Inspected On: 04/19/2019
Operating Permit Renewal Date: 06/22/2022

Owner Operator Contact:

Operator Contact: Douglas Schmidt;Gary Giangreco;Jonathan Harpole

4066968636;4068505861;4086919074

Owner/Operator: 5500 Midland Holdings LLC

Douglas Schmidt, UST Class A Operator
Douglas Schmidt, UST Class B Operator
Gary Giangreco, UST Class A Operator
Gary Giangreco, UST Class B Global Operator

Jonathan Harpole, UST Class A Operator
Jonathan Harpole, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	17	03/12/2004	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
4887	No	04/20/2016		Secondary Containment Chase	Yes
Currently in Use			Not Required	U.S. Suction	Galvanic
Diesel		04/20/2016	Automatic Tank Gauging 0.2	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
500		09/20/2004	EMCO Electronics/EECO 1500		No

Facility Summary in Yellowstone County in the City of Billings

Location: REDDAWAY
833 Mullowney Ln
Billings, MT 59101-4654 Yellowstone

Legacy ID:56-01340

Facility ID: 29768
Last Inspected On: 01/30/2019
Operating Permit Renewal Date: 05/30/2022

Owner Operator Contact: David Robson;USF Reddaway;Reddaway

Operator Contact: Gary Fort

Owner/Operator: Reddaway

Gary Fort, UST Class A Operator
Gary Fort, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	28	08/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3154	No			None	Yes

Currently in Use		Not Required	Safe Suction	Galvanic
Diesel	01/25/2019	Automatic Tank Gauging 0.2	Deferred	No
10,000		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: REDDI ELECTRIC INC
1045 1/2 Central Ave
Billings, MT 59102-5821 Yellowstone

Legacy ID:56-06953

Facility ID: 30142
Last Inspected On: 06/15/2021
Operating Permit Renewal Date: 09/16/2024

Owner Operator Contact: Reddi Electric Inc

4062453141

Operator Contact: Jordan Schmidt

Owner/Operator: Reddi Electric Inc

Jordan Schmidt, UST Class A Operator

Jordan Schmidt, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	34	01/10/1987	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
1837	No			None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline	04/09/2018		Automatic Tank Gauging 0.2	Deferred	No
560			Veeder Root/TLS-300		No

Facility Summary in Yellowstone County in the City of Billings

Location: RENTAL CAR WASH
3301 Overlook Dr
Billings, MT 59105 Yellowstone

Legacy ID:60-15179

Facility ID: 30905
Last Inspected On: 12/14/2020
Operating Permit Renewal Date: 03/24/2024

Owner Operator Contact:

Operator Contact: Donald Kim Annin;Shawn Gaalswyk

Owner/Operator: Billings Logan International Airport

Dennis Couch, UST Class B Operator
 Donald Kim Annin, UST Class A Operator
 Shawn Gaalswyk, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	10	04/11/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5288	No		Double-Walled	Double Walled	Yes
Currently in Use		03/29/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
20,000		06/25/2017	Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: SAINT VINCENT HOSPITAL and HEALTH CENTER
 1233 N 30th St
 Billings, MT 59101-0127 Yellowstone

Legacy ID:56-02666

Facility ID: 29838
Last Inspected On: 03/17/2020
Operating Permit Renewal Date: 05/22/2023

Owner Operator Contact: Saint Vincent Hospital and Health Center

4062373065

Operator Contact: Kevin Maddox

4062374717

Owner/Operator: Saint Vincent Hospital and Health Center

Kevin Maddox, UST Class A Operator
 Kevin Maddox, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	5	11/01/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff

5700	No	09/21/2016	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
20,000		11/14/2016	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
08	5	11/01/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5701	No	09/21/2016	Double-Walled	Double Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring	No
20,000		11/14/2016	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: SAMS CLUB
4420 King Ave E
Billings, MT 59101 Yellowstone

Legacy ID:60-15138

Facility ID: 30882
Last Inspected On: 05/16/2019
Operating Permit Renewal Date: 06/17/2022

Owner Operator Contact: Sams West Inc

8778295505

Operator Contact: Donald Elderbaum;Kevin Allen;Sandy Goff;Stacie Greer;Steven Hodge;Tyler Babb

4062567277;4066980157;5132574034;9375439552

Owner/Operator: Sams West Inc

- Donald Elderbaum, UST Class A Operator
- Donald Elderbaum, UST Class B Global Operator
- James Ray, UST Class B Global Operator
- Johney Miller, UST Class B Global Operator
- Joseph Khan, UST Class B Operator
- Kevin Allen, UST Class A Operator
- Kevin Allen, UST Class B Global Operator
- Rick Weaver, UST Class B Global Operator
- Sandy Goff, UST Class A Operator
- Sandy Goff, UST Class B Global Operator
- Stacie Greer, UST Class A Operator
- Stacie Greer, UST Class B Operator
- Steven Hodge, UST Class A Operator

Steven Hodge, UST Class B Global Operator
 Tyler Babb, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	12	09/08/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5210	No		Double-Walled	Double Walled	Yes
Currently in Use		05/20/2009	Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
20,000		04/06/2016	Veeder Root/TLS-450		Yes
02	12	09/08/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5211	No		Double-Walled	Double Walled	Yes
Currently in Use		05/20/2009	Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
20,000		04/06/2016	Veeder Root/TLS-450		Yes
03	12	09/08/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5212	No		Double-Walled	Double Walled	Yes
Currently in Use		05/20/2009	Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000		04/06/2016	Veeder Root/TLS-450		Yes
04	12	09/08/2009	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve

5213	No		Double-Walled	Double Walled	Yes
Currently in Use	05/20/2009		Mechanical Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
8,000	04/06/2016		Veeder Root/TLS-450		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: SHORT STOP
804 Central Ave
Billings, MT 59102-5818 Yellowstone

Legacy ID:56-06609

Facility ID: 30126
Last Inspected On: 10/18/2019
Operating Permit Renewal Date: 10/26/2016

Owner Operator Contact: Dan Stockton;Stockton Oil Co Billings;Stockton Oil Co Billings

Operator Contact: Michael Stockton

4062456376

Owner/Operator: Montana Marketing and Development LLC

Owner/Operator: Stockton Oil Co Billings

Christopher Stockton, UST Class B Global Operator
Joey McConnell , UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Michael Stockton, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	40	03/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
3754	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
8,000					No
02	40	03/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve

3899	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
8,000					No
03	40	03/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4920	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
8,000					No
04	40	03/26/1981	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4921	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		10/10/2016	Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
8,000					No

Facility Summary in Yellowstone County in the City of Billings

Location: SKYVIEW HIGH SCHOOL DIST 2
1775 High Sierra Blvd
Billings, MT 59105 Yellowstone

Legacy ID:56-10585

Facility ID: 30356
Last Inspected On: 10/18/2021
Operating Permit Renewal Date: 12/10/2021

Owner Operator Contact: Billings School District;N/A ZZZ - TBL_OWN : 4062473777
88;Billings Public Schools Dist 2

Operator Contact:

Owner/Operator: Billings School District

Jim Miller, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S1	34	03/16/1987	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
448	No	12/05/2018		Double Walled	Yes
Currently in Use			Auto Dialer	U.S. Suction	Galvanic
Heating Oil		12/05/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring	No
5,000			Veeder Root/TLS-300		No

Facility Summary in Yellowstone County in the City of Billings

Location: STOCKTON OIL CO 4TH AVE N
1607 4th Ave N
Billings, MT 59101-1522 Yellowstone

Legacy ID:56-04839

Facility ID: 29940
Last Inspected On: 11/27/2019
Operating Permit Renewal Date: 12/03/2022

Owner Operator Contact: Dan Stockton;Stockton Oil Co Billings;Stockton Oil Co Billings

Operator Contact: Michael Stockton 4062456376

Owner/Operator: Michael Stockton

Owner/Operator: Stockton Oil Co Billings

Christopher Stockton, UST Class B Global Operator
Joseph Stockton, UST Class B Global Operator
Michael Stockton, UST Class A Operator
Michael Stockton, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	41	03/26/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1988	No		Lined Interior/Impressed Current	None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		12/02/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	29	04/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1989	No			None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
5,000		12/02/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	29	04/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1990	No			None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		12/07/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	29	04/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1991	No			None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No

8,000		12/02/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	29	04/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1992	No			None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
8,000		12/02/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	29	04/01/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1993	No			None	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		12/07/2016	Automatic Tank Gauging 0.2	ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: SYSCO FOOD SERVICES OF MONTANA MONAD RD
1509 Monad Rd
Billings, MT 59101 Yellowstone

Legacy ID:56-03530

Facility ID: 29872
Last Inspected On: 02/13/2020
Operating Permit Renewal Date: 06/11/2023

Owner Operator Contact: Bill Zink;Sysco Food Services of Montana

4062471131

Operator Contact: Christopher Murphy

4062004591

Owner/Operator: Sysco Food Services of Montana

Christopher Murphy, UST Class A Operator
Greg Murray, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	14	12/27/2007	Unknown	Flexible Plastic	
5144	Yes			Double Walled	Yes

Currently in Use		07/10/2007	Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		11/23/2016			Yes
05	14	12/27/2007	Unknown	Flexible Plastic	
5145	Yes			Double Walled	Yes
Currently in Use		07/10/2007	Electronic Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
10,000		11/23/2016			Yes

Facility Summary in Yellowstone County in the City of Billings

Location: THE WAVE CAR WASH
858 S 29th St W
Billings, MT 59102-7449 Yellowstone

Legacy ID:56-13884

Facility ID: 30559
Last Inspected On: 07/01/2019
Operating Permit Renewal Date: 09/13/2022

Owner Operator Contact: The Wave and Rocky Toppers **4066562781**

Operator Contact: Stacy Ott;Steven Ott **4066562781**

Owner/Operator: The Wave and Rocky Toppers

Stacy Ott, UST Class A Operator
Stacy Ott, UST Class B Operator
Steven Ott, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	23	06/01/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3527	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/10/2013	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	23	06/01/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3528	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		06/10/2013	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN AND COUNTRY HILL TOP
523 Hilltop Rd
Billings, MT 59105-2374 Yellowstone

Legacy ID:56-13731

Facility ID: 30458
Last Inspected On: 09/18/2019
Operating Permit Renewal Date: 12/12/2022

Owner Operator Contact: Town and Country Supply Association

4066286314

Operator Contact: Leilani McCarthy;Lucy Green;Mark Heimbichner;Steven Shelton

4062561020;4063200055

Owner/Operator: Town and Country Supply Association

Leilani McCarthy, UST Class A Operator
 Leilani McCarthy, UST Class B Operator
 Lucy Green, UST Class A Operator
 Mark Heimbichner, UST Class A Operator
 Mark Heimbichner, UST Class B Global Operator
 Steven Shelton, UST Class A Operator
 Steven Shelton, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	25	07/01/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3419	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		12/03/2010	Gilbarco/EMC Basic		No
02	25	07/01/1996	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3420	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		12/03/2010	Gilbarco/EMC Basic		No
03	7	06/30/2014	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
5509	No	06/30/2014	Double-Walled	Double Walled	Yes

Currently in Use	06/10/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000	07/14/2014	Gilbarco/EMC Basic;Gilbarco- Veeder Root/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS #12
3415 Grand Ave
Billings, MT 59102 Yellowstone

Legacy ID:60-15328

Facility ID: 31024
Last Inspected On: 05/26/2021
Operating Permit Renewal Date: 06/04/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Billings 12 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	2	03/01/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5884	No		Double-Walled	Double Walled	No
Currently in Use		03/01/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
30,000			Gilbarco-Veeder Root/TLS-450		Yes
02	2	06/27/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5885	No		Double-Walled	Double Walled	No
Currently in Use		06/27/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
7,000			Gilbarco-Veeder Root/TLS-450		Yes
03	2	06/27/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5886	No		Double-Walled	Double Walled	No
Currently in Use		06/27/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000			Gilbarco-Veeder Root/TLS-450		Yes
04	2	06/27/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5887	No		Double-Walled	Double Walled	No
Currently in Use		06/27/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
7,000			Gilbarco-Veeder Root/TLS-450		Yes
05	2	06/27/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5888	No		Double-Walled	Double Walled	No
Currently in Use		06/27/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
7,000			Gilbarco-Veeder Root/TLS-450		Yes
06	2	06/27/2019	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
5889	No		Double-Walled	Double Walled	No
Currently in Use		06/27/2019	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
20,000	Gilbarco-Veeder Root/TLS-450		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS #8
 3969 Grand Ave
 Billings, MT 59102-7512 Yellowstone

Legacy ID:56-13741

Facility ID: 30459
Last Inspected On: 08/17/2020
Operating Permit Renewal Date: 02/07/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Billings 8 Town Pump LLC

Trent Biggers, UST Class A Operator
 Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
01	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
2013	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/22/2011	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
02	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
2014	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline		12/22/2011	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
20,000			Gilbarco-Veeder Root/TLS-350		No
03	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
2015	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/22/2011	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
04	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
2016	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		12/22/2011	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
4,000			Gilbarco-Veeder Root/TLS-350		No
05	25	09/01/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve
2017	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		12/22/2011	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
4,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP BILLINGS 11
450 Main St
Billings, MT 59105 Yellowstone

Legacy ID:60-15297

Facility ID: 31001
Last Inspected On: 12/17/2020
Operating Permit Renewal Date: 04/03/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Billings 11 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	4	09/12/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5709	No	06/19/2017	Double-Walled	Double Walled	Yes
Currently in Use		09/12/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
25,000			Gilbarco-Veeder Root/TLS-450		Yes
02	4	09/12/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5710	No	06/19/2017	Double-Walled	Double Walled	Yes
Currently in Use		09/12/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
15,000			Gilbarco-Veeder Root/TLS-450		Yes
03	4	09/12/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5711	No	06/19/2017	Double-Walled	Double Walled	Yes
Currently in Use		09/12/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-450		Yes
04	4	09/12/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5712	No	06/19/2017	Double-Walled	Double Walled	Yes
Currently in Use		09/12/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
7,000			Gilbarco-Veeder Root/TLS-450		Yes
05	4	09/12/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5713	No	06/19/2017	Double-Walled	Double Walled	Yes
Currently in Use		09/12/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
7,000			Gilbarco-Veeder Root/TLS-450		Yes
06	4	09/12/2017	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5714	No	06/19/2017	Double-Walled	Double Walled	Yes
Currently in Use		09/12/2017	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
7,000			Gilbarco-Veeder Root/TLS-450		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP INC BILLINGS 1
1028 US Hwy 87 E
Billings, MT 59101-6658 Yellowstone

Legacy ID:56-00767

Facility ID: 29729
Last Inspected On: 09/11/2020
Operating Permit Renewal Date: 02/06/2024

Owner Operator Contact: Don Edmisten;Billings Holdings LLC

4064976948

Operator Contact: Trent Biggers

Owner/Operator: Billings 1 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	25	10/02/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
2665	No		Double-Walled	Double Walled	Yes
Currently in Use		07/11/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		Yes
08	25	10/02/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
2666	No		Double-Walled	Double Walled	Yes
Currently in Use		02/15/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		Yes
09	25	10/02/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
2667	No		Double-Walled	Double Walled	Yes
Currently in Use		02/15/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		Yes
10	22	02/01/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
3921	No		Double-Walled	Double Walled	Yes
Currently in Use		04/20/2011	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
6,000			Gilbarco-Veeder Root/TLS-350		Yes
06	25	10/02/1996	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve;Flapper Valve
4583	No		Double-Walled	Double Walled	Yes
Currently in Use		07/11/2013	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP INC BILLINGS 3
3150 King Ave W
Billings, MT 59102-6438 Yellowstone

Legacy ID:60-15023

Facility ID: 30809
Last Inspected On: 07/07/2021
Operating Permit Renewal Date: 07/21/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Billings 3 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
02	15	04/01/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5056	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/01/2006	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
03	15	04/06/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5057	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		05/01/2006	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
04	15	04/14/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5058	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
05	15	04/06/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5059	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel		05/01/2006	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
06	15	04/06/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5060	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		05/01/2006	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
01	15	04/14/2006	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5062	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
20,000		05/01/2006	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Yellowstone County in the City of Billings

Location: TOWN PUMP INC BILLINGS 4
2711 N Frontage Rd
Billings, MT 59101-7327 Yellowstone

Legacy ID:60-15104

Facility ID: 30863
Last Inspected On: 07/06/2021
Operating Permit Renewal Date: 07/21/2024

Owner Operator Contact:

Operator Contact: Trent Biggers

Owner/Operator: Billings 4 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types

Product	Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery	
Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
01	13	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5180	No		Double-Walled	Double Walled	Yes
Currently in Use		05/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-450		No
02	13	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5181	No		Double-Walled	Double Walled	Yes
Currently in Use		05/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-450		No
03	13	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5182	No		Double-Walled	Double Walled	Yes
Currently in Use		05/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
30,000			Gilbarco-Veeder Root/TLS-450		No
04	13	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5183	No		Double-Walled	Double Walled	Yes
Currently in Use		05/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible

Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
22,000			Gilbarco-Veeder Root/TLS-450		No
05	13	12/18/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5184	No		Double-Walled	Double Walled	Yes
Currently in Use		05/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-450		No
06	13	12/18/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5185	No		Double-Walled	Double Walled	Yes
Currently in Use		05/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Yes
22,000			Gilbarco-Veeder Root/TLS-450		No
07	13	12/15/2008	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
5186	No		Double-Walled	Double Walled	Yes
Currently in Use		05/27/2008	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-450		No

Facility Summary in Yellowstone County in the City of Billings

Location: TRADING POST CONOCO
1225 Mallowney Ln
Billings, MT 59101-6301 Yellowstone

Legacy ID:56-06963

Facility ID: 30148
Last Inspected On: 07/22/2019
Operating Permit Renewal Date: 11/30/2022

Owner Operator Contact: Robert Stevenson;S and G Partnership;S and G Partnership

4062524661;4062524661;4062524661

Operator Contact: Jeffrey Sowden

4062568465

Owner/Operator: S and G Partnership

Jeffrey Sowden, UST Class A Operator

Jeffrey Sowden, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	18	05/09/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4836	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		09/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000		06/18/2010	Gilbarco/EMC Basic		No
06	18	05/09/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4837	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		09/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		06/18/2010	Gilbarco/EMC Basic		No
07	18	05/09/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4838	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		09/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		06/18/2010	Gilbarco/EMC Basic		No

08	18	05/09/2003	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
4839	No		Double-Walled	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		09/07/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		06/18/2010	Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: UNITED PARCEL SERVICES BILLINGS
1830 Lampman Dr
Billings, MT 59102-6442 Yellowstone

Legacy ID:56-04542

Facility ID: 29919
Last Inspected On: 12/04/2018
Operating Permit Renewal Date: 03/22/2022

Owner Operator Contact: Paul Harper;United Parcel Service Inc Atlanta

Operator Contact: Kaytee Villafrancaa;Robert Counts;Russell Stott;Treira Smith **2066216286;2066216380;5039787678**

Owner/Operator: United Parcel Service Inc Seattle

- Kaytee Villafrancaa, UST Class A Operator
- Kaytee Villafrancaa, UST Class B Global Operator
- Robert Counts, UST Class A Operator
- Robert Counts, UST Class B Operator
- Russell Stott, UST Class A Operator
- Russell Stott, UST Class B Operator
- Treira Smith, UST Class A Operator
- Treira Smith, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	28	07/20/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2183	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	Yes

12,000		04/11/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	28	07/20/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve
2184	No		Double-Walled	Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	Yes
12,000		04/11/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: WELLS FARGO BANK OPERATIONS CENTER
2324 Overland Ave
Billings, MT 59102-6401 Yellowstone

Legacy ID:56-13992

Facility ID: 30653
Last Inspected On: 12/12/2019
Operating Permit Renewal Date: 12/12/2022

Owner Operator Contact: Wells Fargo Bank Billings Operations Center **4066557390**

Operator Contact: Greg Amos;Richard Brodston;Stan Barr **4066700779;4066902252**

Owner/Operator: Wells Fargo Bank Billings Operations Center

- Greg Amos, UST Class A Operator
- Greg Amos, UST Class B Operator
- Richard Brodston, UST Class A Operator
- Richard Brodston, UST Class B Operator
- Stan Barr, UST Class A Operator
- Stan Barr, UST Class B Global Operator
- Stan Barr, UST Class B Operator
- Trevor Mill, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	21	09/01/2000	Steel Clad	Flexible Plastic	High Level Alarm
4279	No	06/12/2017	Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Pressurized	Non-corrodible

Diesel		05/30/2008	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
8,000		09/18/2017	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
02	21	09/01/2000	Steel Clad	Flexible Plastic	High Level Alarm
4280	No	06/12/2017	Double-Walled	Double Walled	Yes
Currently in Use			Not Required	Pressurized	Non-corrodible
Diesel		05/30/2008	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	3-Year Line Tightness Test;Continuous Interstitial Monitoring	No
8,000		09/18/2017	Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of billings

Location: WELLS FARGO CENTER
175 N 27th St
billings, MT 59101-2048 Yellowstone

Legacy ID:56-13972

Facility ID: 30634
Last Inspected On: 05/14/2020
Operating Permit Renewal Date: 08/20/2023

Owner Operator Contact: Roger Dearth;Mayo Foundation For Medical Education and Research;S F H II LLC **4066510603**

Operator Contact: John Schafnitz

Owner/Operator: S F H II LLC

John Schafnitz, UST Class A Operator
John Schafnitz, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
02	21	11/01/2000	Cathodically Protected Steel	Copper	Flapper Valve
4231	No		Double-Walled	Secondary Containment Chase	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		05/03/2017	Continuous Interstitial Monitoring	Not Listed	No
400			Pneumercator/Other		No

Facility Summary in Yellowstone County in the City of Billings

Location: WILSON DUNHAM SERVICE INC
2511 1st Ave S
Billings, MT 59101-4220 Yellowstone

Legacy ID:56-07756

Facility ID: 30197
Last Inspected On: 05/13/2020
Operating Permit Renewal Date: 06/03/2020

Owner Operator Contact: William Dunham;Wilson Dunham Service Inc

4062520880;4062520880

Operator Contact: Joan Erickson;William Dunham

4062520880;4067247335

Owner/Operator: Wilson Dunham Petroleum Supply

Joan Erickson, UST Class A Operator
Joan Erickson, UST Class B Operator
William Dunham, UST Class A Operator
William Dunham, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	31	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2277	No			Double Walled	Yes
Temporarily Out of Use			Not Required	Safe Suction	Galvanic
Diesel		05/12/2017	Automatic Tank Gauging 0.2	Deferred	No
4,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	31	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2278	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/12/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
4,000		04/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	31	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm

2279	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/12/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
4,000		04/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	31	11/16/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
2280	No			Double Walled	Yes
Temporarily Out of Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/12/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2	No
8,000		04/23/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 51
1544 Broadwater Ave
Billings, MT 59102-5002 Yellowstone

Legacy ID:56-00050

Facility ID: 29683
Last Inspected On: 04/01/2021
Operating Permit Renewal Date: 07/14/2024

Owner Operator Contact: Jim Alford;CHS Inc - Spokane

5095367418

Operator Contact: Ian Johnstone;Jim Alford;Nicholas Merritt

4066330023;5095367418

Owner/Operator: CHS Inc Spokane Valley

- Darcy Ziegler, UST Class B Operator
- Ian Johnstone, UST Class A Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Nicholas Merritt, UST Class A Operator
- Nicholas Merritt, UST Class B Global Operator
- Nicholas Merritt, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

04	24	10/30/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
----	----	------------	-------------------------------	------------------	------------------

3074	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		02/23/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No
05	24	10/30/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3075	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		02/23/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Gilbarco/EMC Basic		No
06	24	10/30/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3076	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		02/23/2015	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
15,000		02/05/2018	Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 52
1201 Central Ave
Billings, MT 59102-5528 Yellowstone

Legacy ID:56-08903

Facility ID: 30290
Last Inspected On: 06/12/2019
Operating Permit Renewal Date: 11/30/2022

Owner Operator Contact: Jim Alford;CHS Inc - Spokane

5095367418

Operator Contact: Jim Alford;Pete Nussbaum;Sean Hurley

5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

Darcy Ziegler, UST Class B Operator
Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Pete Nussbaum, UST Class A Operator
Pete Nussbaum, UST Class B Global Operator
Sean Hurley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	11	11/22/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5270	No		Double-Walled	Double Walled	Yes
Currently in Use		08/06/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
07	11	11/22/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5271	No		Double-Walled	Double Walled	Yes
Currently in Use		08/06/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
7,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes
08	11	11/22/2010	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm;Positive Shutoff
5272	No		Double-Walled	Double Walled	Yes
Currently in Use		08/06/2010	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000			Gilbarco-Veeder Root/TLS- 350;Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 53
2975 Grand Ave
Billings, MT 59102 Yellowstone

Legacy ID:56-13245

Facility ID: 30433
Last Inspected On: 04/02/2021
Operating Permit Renewal Date: 07/14/2024

Owner Operator Contact:

Operator Contact: Jim Alford;Nicholas Merritt

4066330023;5095367418

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator
 Jim Alford, UST Class B Global Operator
 Nicholas Merritt, UST Class A Operator
 Nicholas Merritt, UST Class B Global Operator
 Nicholas Merritt, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	28	09/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
592	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/01/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco/EMC Basic		No
02	28	09/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
593	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		03/01/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000			Gilbarco/EMC Basic		No
03	28	09/01/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve
594	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic

Diesel	03/01/2018	Automatic Tank Gauging 0.2	ELLD 0.2	No
12,000		Gilbarco/EMC Basic		No

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 54
151 Rosebud Ln
Billings, MT 59101-6503 Yellowstone

Legacy ID:56-08208

Facility ID: 30220
Last Inspected On: 04/07/2021
Operating Permit Renewal Date: 06/25/2024

Owner Operator Contact: Jim Alford;CHS Inc - Spokane

5095367418

Operator Contact: Jim Alford;Nicholas Merritt;Pete Nussbaum;Tom Savas **4066330023;5095367418**

Owner/Operator: CHS Inc Spokane Valley

- Chuck Crane, UST Class B Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Karina Serrano, UST Class B Global Operator
- Nicholas Merritt, UST Class A Operator
- Nicholas Merritt, UST Class B Global Operator
- Nicholas Merritt, UST Class B Operator
- Pete Nussbaum, UST Class A Operator
- Tom Savas, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
07	7	09/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
5525	No	11/01/2014	Double-Walled	Double Walled	Yes
Currently in Use		11/03/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
17,000		02/13/2015	Gilbarco-Veeder Root/TLS-450;Veeder Root/TLS-450		Yes
08	7	09/01/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm

5526	No	11/01/2014	Double-Walled	Double Walled	Yes
Currently in Use		11/03/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000		02/13/2015	Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
09	7	09/01/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5527	No	11/01/2014	Double-Walled	Double Walled	Yes
Currently in Use		11/03/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
17,000		02/13/2015	Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
10	7	09/01/2014	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve;High Level Alarm
5528	No	11/01/2014	Double-Walled	Double Walled	Yes
Currently in Use		11/03/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
8,000		02/13/2015	Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes
11	7	09/01/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve;High Level Alarm
5529	No	11/01/2014	Double-Walled	Double Walled	Yes
Currently in Use		11/03/2014	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
25,000		02/13/2015	Gilbarco-Veeder Root/TLS- 450;Veeder Root/TLS-450		Yes

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 55
236 Main St
Billings, MT 59105-3232 Yellowstone

Legacy ID:56-08904

Facility ID: 30291
Last Inspected On: 04/07/2021
Operating Permit Renewal Date: 07/11/2024

Owner Operator Contact: Tim Lakers;Kum and Go L C

Operator Contact: Ian Johnstone;Jim Alford

5095367418

Owner/Operator: CHS Inc Spokane Valley

Chuck Crane, UST Class B Operator
 Darcy Ziegler, UST Class B Operator
 Ian Johnstone, UST Class A Operator
 Jim Alford, UST Class A Operator
 Jim Alford, UST Class B Global Operator
 Karina Serrano, UST Class B Global Operator
 Nicholas Merritt, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	39	10/03/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
589	No	10/08/2014	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		10/13/2014	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/01/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		10/13/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	39	10/03/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
590	No	10/08/2014	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		10/13/2014	Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/01/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000		10/13/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	39	10/03/1982	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
591	No	10/08/2014	Lined Interior/Impressed Current	Double Walled	Yes

Currently in Use	10/13/2014	Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel	08/01/2013	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000	10/13/2014	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 56
16 Shiloh Rd
Billings, MT 59106 Yellowstone

Legacy ID:56-01664

Facility ID: 29782
Last Inspected On: 03/31/2021
Operating Permit Renewal Date: 07/09/2024

Owner Operator Contact: Roger Pelzer;Superpumper Inc

7018520061

Operator Contact: Jim Alford;Sean Hurley

5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Nicholas Merritt, UST Class B Global Operator
Nicholas Merritt, UST Class B Operator
Sean Hurley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	37	12/31/1984	Bare Steel	Flexible Plastic	High Level Alarm
4344	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		03/01/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	37	12/31/1984	Bare Steel	Flexible Plastic	High Level Alarm
4345	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current

Gasoline	03/01/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No	
12,000		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No	
03	32	11/10/1989	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
4346	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline	03/01/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No	
10,000		Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No	

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 57
1046 N 27th St
Billings, MT 59101-0710 Yellowstone

Legacy ID:56-01665

Facility ID: 29783
Last Inspected On: 04/06/2021
Operating Permit Renewal Date: 07/11/2024

Owner Operator Contact: Jim Alford;CHS Inc - Spokane

5095367418

Operator Contact: Ian Johnstone;Jim Alford;Tom Savas

5095367418

Owner/Operator: CHS Inc Spokane Valley

- Chuck Crane, UST Class B Operator
- Don Thoreson, UST Class B Global Operator
- Ian Johnstone, UST Class A Operator
- Ian Johnstone, UST Class B Global Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Katherine Warmus, UST Class B Global Operator
- Nicholas Merritt, UST Class B Global Operator
- Robert Hays, UST Class B Operator
- Tom Savas, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act

03	23	01/28/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
----	----	------------	-------------------------------	------------------	------------------

3080	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		01/08/2009	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No
04	23	01/28/1998	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
3081	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		01/08/2009	Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS- 350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Billings

Location: ZIP TRIP 58
610 Wicks Ln
Billings, MT 59105 Yellowstone

Legacy ID:56-08209

Facility ID: 30221
Last Inspected On: 03/15/2021
Operating Permit Renewal Date: 03/17/2024

Owner Operator Contact: Tim Lakers;Kum and Go L C

Operator Contact: Jim Alford;Nicholas Merritt;Sean Hurley;Tom Savas **4066330023;5095357701;5095367418**

Owner/Operator: CHS Inc Spokane Valley

- Chuck Crane, UST Class B Operator
- Jim Alford, UST Class A Operator
- Jim Alford, UST Class B Global Operator
- Karina Serrano, UST Class B Global Operator
- Nicholas Merritt, UST Class A Operator
- Nicholas Merritt, UST Class B Operator
- Paul Workin, UST Class B Global Operator
- Sean Hurley, UST Class A Operator
- Tom Savas, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
04	22	01/01/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve;High Level Alarm
4256	No			Double Walled	Yes
Currently in Use		11/20/2007	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/19/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	22	01/01/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve;High Level Alarm
4257	No			Double Walled	Yes
Currently in Use		11/20/2007	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		04/19/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
10,000			Gilbarco/TLS-350		No
06	22	01/01/1999	Cathodically Protected Steel	Flexible Plastic	Flapper Valve;High Level Alarm
4258	No			Double Walled	Yes
Currently in Use		11/20/2007	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		04/19/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Broadview

Location: DANNYS LLC
16437 Iowa Ave
Broadview, MT 59015 Yellowstone

Legacy ID:56-02373

Facility ID: 29819
Last Inspected On: 02/24/2021
Operating Permit Renewal Date: 02/24/2024

Owner Operator Contact: Richard Worisek;Richard Worisek and Adel Worisek **4066672375**

Operator Contact: Jody McCloud

Owner/Operator: Dannys LLC

Jody McCloud, UST Class A Operator
Jody McCloud, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
06	25	05/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3410	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		06/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	25	05/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3411	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		12/12/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
6,000		06/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	25	05/01/1996	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3412	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Galvanic
Diesel		12/12/2017	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		06/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Custer

Location: SURE STOP
523 2nd Ave
Custer, MT 59024 Yellowstone

Legacy ID:56-05291

Facility ID: 30014
Last Inspected On: 12/07/2018
Operating Permit Renewal Date: 04/30/2022

Owner Operator Contact: Dennis Whitmore;Petro Services Co Inc;Valley Farmers Supply

4066515101;4069673100

Operator Contact: Scott Black

4069673100

Owner/Operator: Valley Farmers Supply

Lacey Cox, UST Class B Global Operator
 Lenore Rogers, UST Class B Operator
 Marion Perrin, UST Class B Global Operator
 Marion Perrin, UST Class B Operator
 Scott Black, UST Class A Operator
 Scott Black, UST Class B Global Operator
 Sherry Ward, UST Class B Operator
 Trina Wilson, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
S5	22	07/01/1999	Unknown	Flexible Plastic	
4079	Yes	06/10/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
5,000					No
S6	22	07/01/1999	Unknown	Flexible Plastic	
4080	Yes	06/10/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000					No
S7	22	07/01/1999	Unknown	Flexible Plastic	
4081	Yes	06/10/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	

Gasoline			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
12,000					No
S8	22	07/01/1999	Unknown	Flexible Plastic	
4082	Yes	06/10/2016		Double Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Gasoline			Deferred	Continuous Interstitial Monitoring;MLLD Line Tightness Testing	No
10,000					No

Facility Summary in Yellowstone County in the City of Huntley

Location: HUNTLEY EXPRESSWAY
135 Northern Ave
Huntley, MT 59037-9101 Yellowstone

Legacy ID:56-00627

Facility ID: 29722
Last Inspected On: 02/07/2020
Operating Permit Renewal Date: 06/26/2023

Owner Operator Contact: Bernard Greenfield;Set Five LLC Big Sky

4063489209

Operator Contact: Greg Haines

4065902667

Owner/Operator: Set Five LLC Big Sky

Greg Haines, UST Class A Operator

Greg Haines, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
03	23	11/01/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3660	No			Double Walled	Yes
Currently in Use		06/17/2008	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/30/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring;ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

04	23	11/01/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3661	No			Double Walled	Yes
Currently in Use		06/17/2008	Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		05/30/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
5,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	23	11/01/1998	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
3662	No			Double Walled	Yes
Currently in Use		06/17/2008	Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		05/30/2017	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Laurel

Location: CONOMART SUPERSTORE 2
411 E 1st St
Laurel, MT 59044 Yellowstone

Legacy ID:56-06966

Facility ID: 30151
Last Inspected On: 06/03/2021
Operating Permit Renewal Date: 06/03/2024

Owner Operator Contact: Superpumper Inc

Operator Contact: Justin Franjevic;Stephanie Zierke

4062940867;4068551749

Owner/Operator: Superpumper Inc

Justin Franjevic, UST Class A Operator
Linda Degele, UST Class B Operator
Stephanie Zierke, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	44	04/22/1977	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1175	No		Lined Interior/Impressed Current	Single Walled	Yes

Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		06/19/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
4,000		11/17/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	44	04/22/1977	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1176	No		Lined Interior/Impressed Current	Single Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/19/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		11/18/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	44	04/22/1977	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1177	No		Lined Interior/Impressed Current	Single Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/19/2018	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		11/18/2018	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Laurel

Location: CONOMART SUPERSTORE 3
519 W Main St
Laurel, MT 59044-2926 Yellowstone

Legacy ID:56-06965

Facility ID: 30150
Last Inspected On: 06/03/2021
Operating Permit Renewal Date: 06/03/2024

Owner Operator Contact: Dennis Whitmore;Petro Services Co Inc;Superpumper Inc **4066515101**

Operator Contact: Justin Franjevic;Stephanie Zierke **4062940867;4068551749**

Owner/Operator: Superpumper Inc

Jewell Borchartd, UST Class B Operator
Justin Franjevic, UST Class A Operator
Stephanie Zierke, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery

Capacity	Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act	
04	26	10/17/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1172	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline	06/19/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2		No
10,000	06/28/2018	Gilbarco/EMC Basic			No
05	26	10/17/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1173	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline	06/19/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2		No
8,000	07/01/2018	Gilbarco/EMC Basic			No
06	26	10/17/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1174	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel	06/19/2018	Automatic Tank Gauging 0.2	Continuous Interstitial Monitoring; ELLD 0.1; ELLD 0.2		No
8,000	06/23/2018	Gilbarco/EMC Basic			No

Facility Summary in Yellowstone County in the City of Laurel

Location: FASTLANE C STORES
815 E Main St
Laurel, MT 59044-2810 Yellowstone

Legacy ID:56-05083

Facility ID: 30002
Last Inspected On: 05/29/2020
Operating Permit Renewal Date: 09/25/2023

Owner Operator Contact: Dan Foos; East Main Development LLC

4066286204;4066286204

Operator Contact: Dan Foos

4066286204

Owner/Operator: East Main Development LLC

Dan Foos, UST Class A Operator
Dan Foos, UST Class B Operator
Rochelle Foos, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	46	10/01/1975	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
3831	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/28/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
10,000		05/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
02	46	10/01/1975	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
3832	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		06/28/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
5,200		05/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
03	46	10/01/1975	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve
3833	No			None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		06/28/2017	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		05/09/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Laurel

Location: LAUREL GENEX C STORE
315 S 1st Ave
Laurel, MT 59044-3303 Yellowstone

Legacy ID:56-08161

Facility ID: 30215
Last Inspected On: 09/18/2019
Operating Permit Renewal Date: 12/27/2022

Owner Operator Contact: Town and Country Supply Association;Wes Burley;Town and Country Supply Association

4066286314;4066286314;4066286314

Operator Contact: Steven Shelton;Wesley Burley

4062323520;4063200055

Owner/Operator: Town and Country Supply Association

Cathy Culp, UST Class B Global Operator
 Marise Headdress, UST Class B Global Operator
 Steven Shelton, UST Class A Operator
 Steven Shelton, UST Class B Global Operator
 Wesley Burley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
05	26	05/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1523	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasohol/Ethanol		09/08/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	26	05/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1524	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/08/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
07	26	05/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1525	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		09/08/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
12,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
08	26	05/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm

1526	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/08/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	26	05/22/1995	Cathodically Protected Steel	Flexible Plastic	High Level Alarm
1527	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		09/08/2016	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000			Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Laurel

Location: LAUREL SERVICE CENTER INC UST
201 W Main St
Laurel, MT 59044-3108 Yellowstone

Legacy ID:56-01069

Facility ID: 29751
Last Inspected On: 06/29/2017
Operating Permit Renewal Date: 08/20/2020

Owner Operator Contact: John Munro

4066284216

Operator Contact: John Munro

4066284216

Owner/Operator: John D Munro

John D Munro, UST Class A Operator
John D Munro, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	35	04/29/1986	Cathodically Protected Steel	No Piping	Flapper Valve
1808	No			None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		05/03/2017	Automatic Tank Gauging 0.2	Deferred	No

10,000		08/08/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	33	04/28/1988	Cathodically Protected Steel	No Piping	Flapper Valve
1809	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		05/03/2017	Not Listed	Not Listed	No
10,000		08/08/2007			No
10	34	04/29/1987	Cathodically Protected Steel	No Piping	Flapper Valve
1810	No			None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		05/03/2017	Automatic Tank Gauging 0.2	Deferred	No
10,000		08/08/2006	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
11	33	04/28/1988	Cathodically Protected Steel	No Piping	Flapper Valve
1811	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Safe Suction	Impressed Current
Diesel		05/03/2017	Not Listed	Not Listed	No
10,000		08/08/2007			No
12	33	04/28/1988	Cathodically Protected Steel	No Piping	Flapper Valve
1812	No			None	Yes
Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		05/03/2017	Automatic Tank Gauging 0.1; Automatic Tank Gauging 0.2	Not Listed	No
8,000		08/08/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
13	33	04/28/1988	Cathodically Protected Steel	No Piping	Flapper Valve
1813	No			None	Yes

Temporarily Out of Use			Not Required	Safe Suction	Impressed Current
Diesel		05/03/2017	Not Listed	Not Listed	No
4,000		08/08/2007			No
14	33	04/28/1988	Cathodically Protected Steel	No Piping	Flapper Valve
1814	No			None	Yes
Temporarily Out of Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		05/03/2017	Not Listed	Not Listed	No
4,000		08/08/2007			No
15	23	11/15/1988	Cathodically Protected Steel	No Piping	Flapper Valve
1815	No			None	Yes
Currently in Use			Not Required	Safe Suction	Impressed Current
Gasoline		05/03/2017	Automatic Tank Gauging 0.2	Deferred;MLLD Line Tightness Testing	No
10,000		08/08/2007	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Laurel

Location: LAUREL TRAVEL CENTER
11360 S Frontage Rd
Laurel, MT 59044 Yellowstone

Legacy ID:56-00626

Facility ID: 29721
Last Inspected On: 07/18/2019
Operating Permit Renewal Date: 12/31/2022

Owner Operator Contact: Kelly Gelske;TA Operating LLC;TA Operating LLC **4408087406**

Operator Contact: Josh Cantrell;Mike Rathbone;Renee Andrews **4068607139;4069279658**

Owner/Operator: TA Operating LLC

- David Padilla, UST Class B Global Operator
- Josh Cantrell, UST Class A Operator
- Josh Cantrell, UST Class B Operator
- Mike Rathbone, UST Class A Operator
- Mike Rathbone, UST Class B Global Operator
- Renee Andrews, UST Class A Operator
- Renee Andrews, UST Class B Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
-----------	-----	-----------	----------------------------	-----------------	----------------

Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	53	05/02/1968	Cathodically Protected Steel	Steel	High Level Alarm
1791	No	08/18/2016	Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/01/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
6,000		10/27/2016	Gilbarco-Veeder Root/TLS-350		No
02	53	05/02/1968	Cathodically Protected Steel	Steel	High Level Alarm
1792	No	08/18/2016	Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Gasoline		08/01/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000		10/27/2016	Gilbarco-Veeder Root/TLS-350		No
03	53	05/02/1968	Cathodically Protected Steel	Steel	High Level Alarm
1793	No	08/18/2016	Lined Interior/Impressed Current	None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		08/01/2016	Statistical Inventory Reconciliation	MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000		10/27/2016	Gilbarco-Veeder Root/TLS-350		No
04	53	05/02/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1794	No	08/18/2016	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		08/17/2016	Mechanical Line Leak Detector	Pressurized	Impressed Current

Diesel		08/01/2016	Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000		08/17/2016	Gilbarco-Veeder Root/TLS-350		No
05	50	05/03/1971	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1795	No	08/18/2016	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		08/17/2016	Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		08/01/2016	Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000		08/17/2016	Gilbarco-Veeder Root/TLS-350		No
06	53	05/02/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1796	No	08/18/2016	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		08/17/2016	Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		08/01/2016	Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000		08/17/2016	Gilbarco-Veeder Root/TLS-350		No
07	53	05/02/1968	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1797	No	08/18/2016	Lined Interior/Impressed Current	Double Walled	Yes
Currently in Use		08/17/2016	Mechanical Line Leak Detector	Pressurized	Impressed Current
Diesel		08/01/2016	Statistical Inventory Reconciliation	Continuous Interstitial Monitoring;MLLD Line Tightness Testing;Statistical Inventory Reconciliation	No
10,000		08/17/2016	Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Yellowstone County in the City of Laurel

Location: NORTHERN SKIES AVIATION
3900 Fox Rd
Laurel, MT 59044 Yellowstone

Legacy ID:56-13474

Facility ID: 30443
Last Inspected On: 10/02/2018
Operating Permit Renewal Date: 01/27/2022

Owner Operator Contact:

Operator Contact:

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4295	No		Double-Walled	Double Walled	Yes
Currently in Use		07/28/2006	Mechanical Line Leak Detector	Pressurized	Galvanic
Gasoline		10/02/2018	Manual Interstitial Monitoring	MLLD Line Tightness Testing	No
7,000		10/02/2018			No
02	27	06/01/1994	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve
4296	No		Double-Walled	Double Walled	Yes
Currently in Use		07/28/2006	Not Required	Safe Suction	Galvanic
Gasoline		10/02/2018	Manual Interstitial Monitoring	Deferred	No
3,000					No

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN and COUNTRY SUPPLY LAUREL ASSN
800 E Main St
Laurel, MT 59044-2866 Yellowstone

Legacy ID:56-04497

Facility ID: 29916
Last Inspected On: 09/18/2019
Operating Permit Renewal Date: 12/14/2022

Owner Operator Contact: Town and Country Supply Association;Wes Burley;Town and Country Supply Association

4066286314;4066286314;4066286314

Operator Contact: Karissa DeRudder;Ronni Nace;Steven Shelton;Vincent Farr;Wesley Burley 4062323520;4063200055;4066286314;4066983342;9285242841

Owner/Operator: Town and Country Supply Association

Karissa DeRudder, UST Class A Operator
Ronni Nace, UST Class A Operator
Steven Shelton, UST Class A Operator

Steven Shelton, UST Class B Global Operator
 Vincent Farr, UST Class A Operator
 Wesley Burley, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
08	31	02/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1518	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasohol/Ethanol		09/06/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		08/03/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
10	31	02/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
1520	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		09/06/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		08/03/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
12	31	02/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4470	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Non-corrodible
Gasoline		09/06/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000		08/03/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
11	31	02/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4471	No			None	Yes

Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel		09/06/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
2,000		08/03/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
09	31	02/12/1990	Steel Clad	Fiberglass Reinforced Plastic	High Level Alarm
4472	No			None	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	
Diesel		09/06/2016	Automatic Tank Gauging 0.2	MLLD Line Tightness Testing	No
4,000		08/03/2016	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN AND COUNTRY WEST MAIN
801 W Main St
Laurel, MT 59044 Yellowstone

Legacy ID:60-15264

Facility ID: 30978
Last Inspected On: 12/16/2019
Operating Permit Renewal Date: 02/14/2023

Owner Operator Contact:

Operator Contact: Michele Ames;Steven Shelton

4063200055;4066335063

Owner/Operator: Town and Country Supply Association

Michele Ames, UST Class A Operator
Michele Ames, UST Class B Operator
Steven Shelton, UST Class A Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	5	10/19/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5611	No	10/07/2016	Double-Walled	Double Walled	Yes
Currently in Use		10/19/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No

15,000			Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
02	5	10/19/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5612	No	10/07/2016	Double-Walled	Double Walled	Yes
Currently in Use		10/19/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
03	5	10/19/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5613	No	10/07/2016	Double-Walled	Double Walled	Yes
Currently in Use		10/19/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
15,000			Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
04	5	10/19/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5614	No	10/07/2016	Double-Walled	Double Walled	Yes
Currently in Use		10/19/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No
10,000			Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		Yes
05	5	10/19/2016	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Positive Shutoff
5615	No	10/07/2016	Double-Walled	Double Walled	Yes
Currently in Use		10/19/2016	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Automatic Tank Gauging 0.2;Continuous Interstitial Monitoring	Continuous Interstitial Monitoring;ELLD 0.1;ELLD 0.2	No

10,000	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC	Yes
--------	--	-----

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN PUMP INC LAUREL
312 S 1st Ave
Laurel, MT 59044 Yellowstone

Legacy ID:56-08710

Facility ID: 30282
Last Inspected On: 02/24/2019
Operating Permit Renewal Date: 04/29/2022

Owner Operator Contact: Kevin Kenneally;Major Brands Dist Imports Inc **4067829121**

Operator Contact: Trent Biggers

Owner/Operator: Laurel 3 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	47	04/14/1974	Cathodically Protected Steel	Steel	Flapper Valve
2668	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/07/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
02	47	04/14/1974	Cathodically Protected Steel	Steel	Flapper Valve
2669	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No

03	47	04/14/1974	Cathodically Protected Steel	Steel	Flapper Valve
2670	No		Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
8,000			Gilbarco-Veeder Root/TLS-350		No
05	41	04/14/1980	Cathodically Protected Steel	Flexible Plastic	Flapper Valve
2672	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		12/07/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
04	41	04/14/1980	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Ball Float Valve;Flapper Valve
4589	No			Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/07/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No
07	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4590	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		11/18/2014	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No

08	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4591	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		11/18/2014	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
09	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4592	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel		11/18/2014	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
5,000			Gilbarco-Veeder Root/TLS-350		No
10	20	06/01/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4593	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		11/18/2014	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
10,000			Gilbarco-Veeder Root/TLS-350		No
11	20	08/25/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4594	No		Double-Walled	Double Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline		11/18/2014	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	No
15,000			Gilbarco-Veeder Root/TLS-350		No

06	34	04/01/1987	Cathodically Protected Steel	Galvanized Steel	Flapper Valve
4603	No			Single Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		12/07/2018	Approved Remote Monitoring;Statistical Inventory Reconciliation	Approved Remote Monitoring;Statistical Inventory Reconciliation	No
12,000			Gilbarco-Veeder Root/TLS-350		No

Facility Summary in Yellowstone County in the City of Laurel

Location: TOWN PUMP OF LAUREL #3
704 1st Ave
Laurel, MT 59044-2100 Yellowstone

Legacy ID:60-15061

Facility ID: 30833
Last Inspected On: 08/16/2021
Operating Permit Renewal Date: 09/07/2024

Owner Operator Contact:

Operator Contact:

Owner/Operator: Laurel 3 Town Pump LLC

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
01	14	03/28/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5105	No		Double-Walled	Double Walled	Yes
Currently in Use		10/25/2006	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
6,000		05/07/2014			No
02	14	03/28/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5106	No		Double-Walled	Double Walled	Yes
Currently in Use		10/25/2006	Electronic Line Leak Detector	Pressurized	Non-corrodible

Diesel			Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
6,000		05/11/2014			No
03	14	03/28/2007	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
5107	No		Double-Walled	Double Walled	Yes
Currently in Use		10/25/2006	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline			Statistical Inventory Reconciliation	Statistical Inventory Reconciliation	No
12,000		05/13/2014			No

Facility Summary in Yellowstone County in the City of Worden

Location: VALLEY FARMERS SUPPLY
1545 Northern Ave
Worden, MT 59088-2215 Yellowstone

Legacy ID:56-02326

Facility ID: 29815
Last Inspected On: 09/21/2020
Operating Permit Renewal Date: 02/27/2024

Owner Operator Contact: Kirk Marzolf;Farmers Union Oil Co Hysham-Worden;Valley Farmers Supply **4069673100**

Operator Contact: Kirk Marzolf;Scott Black **4069673100**

Owner/Operator: Valley Farmers Supply

Deborah Dvorak, UST Class B Operator
Kirk Marzolf, UST Class A Operator
Scott Black, UST Class A Operator
Scott Black, UST Class B Global Operator

Tank Code	Age	Installed	Tank Material Construction	Piping Material	Overfill Types
Tag #	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Piping Installed Date	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
04	30	11/01/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1006	No			None	Yes
Currently in Use		02/15/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		09/16/2011	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No

6,000		05/21/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
05	30	11/01/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1007	No			None	Yes
Currently in Use		02/15/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Gasoline		09/16/2011	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
6,000		05/21/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No
06	30	11/01/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve
1008	No			None	Yes
Currently in Use		02/15/2007	Electronic Line Leak Detector	Pressurized	Non-corrodible
Diesel		09/16/2011	Automatic Tank Gauging 0.2	ELLD 0.1;ELLD 0.2	No
3,000		05/21/2017	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC		No