

# Farm, Residential, Heating Oil & Emergency Generator Tanks

|                |               |
|----------------|---------------|
| Facility Name: | Facility ID#: |
|----------------|---------------|

**ANNUAL 36-HOUR TANK GAUGING** is used for farm, residential, heating oil, and emergency generator USTs of 1,100 gallons and less capacity installed before April 27, 1995.

|   | <u>UST Information:</u> If a question does not apply, leave it blank.                                                                                                                                                                                   | Tag # | Tag # | Tag # | Tag # | Tag # |
|---|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------|-------|-------|-------|-------|
| 1 | Is the UST 1,100 gallons or less capacity?                                                                                                                                                                                                              |       |       |       |       |       |
| 2 | Was the UST system installed before April 27, 1995? If the tank was installed on or after April 27, 1995, then this method is <b>NOT</b> valid and you must utilize a department approved monthly tank leak detection method (choose from other forms). |       |       |       |       |       |
| 3 | Is the UST located at a farm or residential property and used for storing motor fuel for non-commercial purposes, or used for storing heating oil for consumptive use on the premises, or used as an emergency generator tank?                          |       |       |       |       |       |
| 4 | Are passing monitoring records available for the current year? The minimum requirement is a written record of the results of an annual 36-hour gauge stick test.                                                                                        |       |       |       |       |       |
| 5 | Do records show that liquid level measurements are taken at the beginning and ending of a 36 hour rest period hours (or longer duration) during which no liquid is added to or removed from tank?                                                       |       |       |       |       |       |
| 6 | Are liquid level measurements based on an average of two consecutive stick readings, at both the beginning and the end of the test period?                                                                                                              |       |       |       |       |       |
| 7 | Can the gauge stick measure the level of product over the full range of the tank to the nearest 1/8 <sup>th</sup> of an inch? (Stick must be legible and not worn-down or damaged at the end)                                                           |       |       |       |       |       |

**Comments:**

|                     |        |                          |        |
|---------------------|--------|--------------------------|--------|
|                     |        |                          |        |
| (Inspector Initial) | (Date) | (Owner/Operator Initial) | (Date) |