



## 30-Day Record of Impressed Current Cathodic Protection

<b>Facility Name:</b>	<b>Facility ID No.:</b>
<b>Street Address:</b>	<b>City, State, Zip:</b>

**Instructions**

- This form may be used to document operational checks of the cathodic protection system rectifier at least once every 60 days. We recommend that you check your rectifier monthly.
- If your rectifier is so equipped, you should also record the output voltage and current, and the number of hours indicated on the meter.
- Any significant variance should be reported to your inspector so that any necessary repairs or adjustments can be made.
- Every three years your cathodic protection should be tested by a qualified corrosion tester ([click here for a list](#)).
- Keep this form on file for at least three years.

Month	Date Inspected	Tap Setting		DC Output		Hour Meter	Inspector Initials	Comments
		Coarse	Fine	Volts	Amps			
January								
February								
March								
April								
May								
June								
July								
August								
September								
October								
November								
December								
<b>Rectifier Manufacturer:</b>				<b>Rated DC Output: __Volts _____Amps</b>				
<b>Rectifier Model:</b>				<b>Rectifier Serial Number:</b>				
<b>What is the most recently recommended rectifier output? ____Volts _____Amps</b>								