

**TANK SECONDARY CONTAINMENT INTEGRITY  
TESTING DRY TEST METHOD**

Facility Name:	Owner Name:	
Address:	Address:	
City, State, Zip Code:	City, State, Zip Code:	
Montana Facility I.D. #:	Owner Phone #:	
Testing Company:	Test Co Phone #:	Date:

This data sheet is for testing the integrity of the dry secondary containment of a underground storage tank (UST). See PEI/RP1200 Section 4.2 for the test procedure.

Tank Tag ID Number						
Tank Material						
Product Stored						
Tank Capacity,* gallons						
Test Start Time						
Initial Vacuum Reading, inches Hg (See Table 4-1 below.)						
Specified Test Duration (See Table 4-1 below.)	<input type="checkbox"/> 1 hour <input type="checkbox"/> 2 hours	<input type="checkbox"/> 1 hour <input type="checkbox"/> 2 hours	<input type="checkbox"/> 1 hour <input type="checkbox"/> 2 hours	<input type="checkbox"/> 1 hour <input type="checkbox"/> 2 hours	<input type="checkbox"/> 1 hour <input type="checkbox"/> 2 hours	<input type="checkbox"/> 1 hour <input type="checkbox"/> 2 hours
Test End Time						
Final Vacuum Reading, inches Hg						
Is the Annular Space Dry After the Test?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Test Results	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail

TABLE 4-1		
Vacuum, inches Hg	Capacity, gallons	Duration, hours
10	<20,000	1
	20,000+	2

**Comments:**

  
  
  
  
  
  
  
  
  
  

\*Total tank capacity, including all compartments in a multi-compartment tank.

Tester's Name (print) \_\_\_\_\_ Tester's Signature \_\_\_\_\_