

ANNUAL AUTOMATIC TANK GAUGE OPERATION INSPECTION				
Facility Name:		Owner Name:		
Address:		Address:		
City, State, Zip Code:		City, State, Zip Code:		
Montana Facility I.D. #:		Owner Phone:		
Testing Company:		Testing Co Phone:	Date:	
This procedure is to determine whether the automatic tank gauge (ATG) is operating properly. See PEI/RP1200 Section 8.2 for the inspection procedure. This procedure is applicable to tank level monitor probes that touch the bottom of the tank when in place.				
Tank Tag ID Number				
Product Stored				
ATG Make and Model				
1. Tank Volume, gallons				
2. Tank Diameter, inches				
3. After removing the probe from the tank, it has been inspected and any damaged or missing parts replaced?	Yes No	Yes No	Yes No	Yes No
4. Float moves freely on the shaft without binding?	Yes No	Yes No	Yes No	Yes No
5. Fuel and water float level agrees with the value programmed into the console?	Yes No	Yes No	Yes No	Yes No
6. ATG has no alarms, battery tested, lights working and the audible alarm is functional.	Yes No	Yes No	Yes No	Yes No
7. Inch level from bottom of stem when 90% alarm is triggered.				
8. Inch level at which the overfill alarm activates corresponds with or is less than the value programmed in the console?	Yes No	Yes No	Yes No	Yes No
9. Inch level from the bottom when the water float first triggers an alarm.				
10. Inch level at which the water float alarm activates corresponds with or is less than the value programmed in the console?	Yes No	Yes No	Yes No	Yes No
11. Verified system setup configuration, parameters, and applicability. ATG / Leak Detection system is functioning properly as intended for this system.	Yes No	Yes No	Yes No	Yes No
If any answers in Lines 3, 4, 5, 6, 8, 10, or 11 are "No," the system has failed the test. If not applicable, explain below.				
<b>Test Results</b>	Pass Fail	Pass Fail	Pass Fail	Pass Fail
<b>Comments:</b>				

Tester's Name (print) \_\_\_\_\_ Tester's Signature \_\_\_\_\_