

John S. Anderson M.D.

S

January 23, 1976

MONTANA HELENA, MONTANA 59601

RECEIVED JAN 28 1976

meni

١Į

00

]\//I(

Mr. Joe Sabol, Chairman Board of Natural Resources & Conservation 32 South Ewing Helena, Montana 59601

MONT. DEPT. OF NATURAL RESOURCES & CONSERVATION

Dear Mr. Sabol:

Enclosed is a copy of the Board of Health and Environmental Science's conditional certification of Colstrip units 3 and 4. This certification is made pursuant to Section 70-810 (L), R.M.C. 1947, of the Major Facility Siting Act which requires the duly authorized air and water quality agencies to certify that a proposed facility will not violate state and federal standards and implementation plans. Please consider this letter and the enclosed transcript, Findings of Fact and Conclusions of Law as the official notice of certification to the Board of Natural Resources and Conservation.

Best Regards.

Sincerely,

John Bartlett, Chairman Board of Health & Environmental Sciences

JB/SB/slo

Enclosure

cc: Carl Davis Jack Peterson Bill Bellingham Leo Graybull Arden Shenker Don McIntyre

Steve Brown Jim Goetz Benjamin W. Hilley George Pring Mike Meloy

EXHIBIT "A"

n 💽 Seo I

ON D-1/XH

Coll. No.

EXHIBIT "A"

.

` **†** 

.

·/apon čr

BEFORE THE BOARD OF NATURAL RESOURCES AND CONSERVATION AND BOARD OF HEALTH AND ENVIRONMENTAL SCIENCES *** In the Matter of the Application of The Montana Power Company, Puget Sound Power and Light Company, Portland General Electric Company, Washington Water Power Company, and Pacific Power and Light Company, for a Certificate of Environmental Compatability and Public Need relative to Colstrip #3 and #4.
AND BOARD OF HEALTH AND ENVIRONMENTAL SCIENCES *** In the Matter of the Application of The Montana Power Company, Puget Sound Power and Light Company, Portland General Electric Company, Washington Water Power Company, and Pacific Power and Light Company, for a Certificate of Environmental Compatability and Public Need relative to Colstrip #3 and #4. FINDINGS OF FACT AND
3 *** 4 In the Matter of the Application of The Montana Power Company, Puget Sound Power and Light Company, Portland General Electric Company, Washington-Water Power Company, and Pacific Power and Light Company, for a Certificate of Environmental Compatability and Public Need relative to Colstrip #3 and #4. 7 8 FINDINGS OF FACT AND
4 In the Matter of the Application of The Montana Power Company, Puget Sound Power and Light Company, Portland General Electric Company, Washington Water Power Company, and Pacific Power and Light Company, for a Certificate of Environmental Compatability and Public Need relative to Colstrip #3 and #4. 7 8 FINDINGS OF FACT AND
8 FINDINGS OF FACT AND
9 CONCLUSIONS OF LAW
10 The above-entitled matter came on regularly for
11 hearing on June 5, 1975, before the Hearings Examiner,
12 Carl M. Davis, duly appointed by and acting on behalf
13 of the Board of Health and Environmental Sciences
14 of the State of Montana, on the matter of the certifica-
15 tion that the proposed facility will not violate State
16 and Federally established standards and implementation
17 plans, as provided in §70-810(h), R.C.M. 1947. The
$1\delta$ applicants and the opponents to the application appeared
19 by and through their counsel of record, and public
20 witnesses appeared in person; witnesses were sworn
21 and evidence come up, both oral and documentary was
22 introduced, and thereafter the Board of Health and
23 Environmental Sciences heard arguments of counsel on
November 7 and 8, 1975; and having fully considered
25 the evidence and arguments of counsel, makes the following
26 Findings of Facts and Conclusions of Law:
27 FINDINGS OF FACT
The air quality standards applicable to Colstrip
30 Units #3 and #4 are:
31 A. Emissions:
32
TATE HING CO, IA: MONT; JA: DONT;

Ş.

1	New Source Performance Standards (Title 40,
2	Chapter 1, Part 60, Code of Federal Regulations, Section
. 3	60.40, et seq.):
4	Particulate Matter:
5	(1) No discharge to exceed 0.18 g per million cal
6	(2) Exhibit greater than 20% opacity except that a maximum of 40% opacity shall be permissible for
7	not more than two (2) minutes in any hour. Where the pressure of uncombined water is the only reason
9	for failure to meet the requirements of this paragraph, such failure will not be a violation of this section.
10	Sulfur Dioxide:
11	No discharge to exceed (2) 2.2 g per million Cal heat imput being 1.2 lb per million BTU.
12	Nitrogen Oxides:
13	No discharge to exceed (3) 1.26 g per million Cal
14	heat imput being 0.70 lb. per million BTU.
15	B. Ambient Air Quality Standards: (Montana)
16	Sulfur Dioxide:       0.02 ppm       (52 ug/m3) Annual         0.10 ppm       (262 ug/m3) 24 hr.
17	(Not to be exceeded for more than one per cent (1%) of the time)
18	0.25 ppm (654 ug/m3) 1 hr. (not to be exceeded for more than one
20	hour in any four consecutive days at same receptor point)
21	Total Suspended Particulates:
22	75 ug/m3 Annual 200 ug/m3 24 hour
- 23	(Not to be exceeded for more than
24	one per cent of days per year)
25	Suspended Sulfate:
26	4 ug/m3 Annual
27	12 ug/m3
28	(Not to be exceeded over one per cent of the time)
29	Sulfuric Acid Mist:
21	4 ug/m3 Annual
27	12 ug/m3
	-2-
ATATE ISHING CO. INA. MONT.	
	· · · · · · · · · · · · · · · · · · ·

ON PETXE

A STON NOD

•

HEL

ż

<u>.</u>..

1 (Not to be exceeded over one per cent 2 of the time) 3 30 ug/m3 1 hour 4 (Not to be exceeded over one per cent of the time) 5 Lead: 5.0 ug/m3 30 day 6 Average Beryllium 0.01 ug/m3 30 day 7 Average Fluorides, Total in Air as HF - 1 ppb 24 hour 8 Average National: (ug/m3)9 Primary Secondar Sulfur Dioxide Annual 80 10 24 hour' 365 (Not to be exceeded more 11 than once a year) 12 1300 3 hour 13 Particulates: Annual 75 60 14 24 hour 260 150 (Not to be exceeded more 15 than once a year) 16 Photochemical Oxidants (Ozone): 160 (.08 ppm) --17 (Not to be exceeded more than once per year) 18 100 Nitrogen Oxides: Annual 19 For Class II significant deterioration standards С. 20 allowable increase applicable to Units 3 and 4 only: (ug/m3) 21 Sulphur Dioxide 15 Annual 22 100 24 hour 23 700 3 hour maximum 24 Particulates: Annual 10 25 24 hour maximum 30 26 (A-20) 27 II. 28 The water quality standards applicable to 29 Colstrip Units #3 and #4 are Section 69-4801 through 30 Section 69-4827, Revised Codes of Montana, 1947 (Water 31 -3-32

:

Coll. No:

14

•Bx/Ed No Instantical Sucrety Archites. 14149 De subject to Copyright Law

I Pollution), and Section 69-4901 through Section 69-4908, Revised Codes of Montana, 1947 (Public Water 2 3 Supply). The applicable water quality regulations of the State of Montana pertaining to this portion of 4 the hearing are found in Section 16-2.14(10)-S14480, entitled 5 "Water Quality Standards", pp. 16-375.2 through 16-393.8, 6 7 Vol. 2, Title 16, Health and Environmental Sciences of 8 the Montana Administrative Code. The foregoing water quality standards found in the Montana Administrative 9 10 Code pertain only to surface water; ground water standards 11 have not yet been adopted by the Board of Health and Envir 12 onmental Sciences. There are no federal water quality 13 statutes, rules, regulations, standards or laws which 14 are applicable to this hearing. (A-43)

III.

16 Under the foregoing Montana Administrative Code, the
17 Yellowstone River drainage from the Billings water supply
18 intake to the North Dakota state line, with the exception
19 of various tributaries listed in the code, has a water
20 use classification of B-D3 (Department of Health's Exhibit
21 27; Section 16-2.14(10)-S14480(4), p. 16-387, Vol. 2,
22 Title 16 of the Montana Administrative Code. (A44)

15

23

24

25

26

27

28

29

30

31

32

IV.

The system to be constructed for the control of emissions from Colstrip Units #3 and #4, consists of venturi wet scrubber modules (Applicant's Exhibit 63), (Grimm, 12-1712). There will be eight scrubber modules constructed for Unit #3 and eight scrubber modules for Unit #4, (Grimm, 12-1717), with one module in each unit to be used as a spare, (Grimm, 13-1841). (A1)

The components that make up each individual module

v.

COIL NO

-4-

include: dampers, so the modules can be isolated for maintenance, (Grimm, 12-1718), the Venturi plumb bob section, (Grimm, 12-1719), the absorption vessel with counter current absorption sprays and agitated integral recycle tank, (Grimm, 12-1721, 1722, 14-1936), (Appli-c cants' Exhibit 109); the Koch or wash tray to remove entrained scrubber sludge from the flue gas, (Grimm, 12-1723, 1726), Applicants' Exhibit 110); demisters that separate entrained moisture from the flue gas, (Grimm, 12-1727, 1729), Applicants' Exhibit 111), a stainless steel fleximesh, (Abrams 15-2138); flue gas reheater to reheat the scrubbed gases to 175° Fahrenheit, (Grimm, 12-1729, 1730), equipped with a soot blower to remove fly ash deposits, (Grimm, 14-1950), and the dry induced draft fan which pulls the flue gas through the scrubber system by a suction or vacuum process. (Grimm, 12-1730). For operation purposes, access ports for observation into the scrubber will be provided to allow the operator to observe any build-up of solid deposits, (Grimm, 14-1935). (A2)

VI.

The Venturi scrubber system captures the fly ash present in the flue gas, (Grimm, 12-1745). The fly ash results from the burning of the coal, (Grimm, 12-1720), and contains alkali material of calcium and magnesium which absorbs the sulfur dioxide, (Grimm, 12-1720, 1745). The fly ash is recovered in the Venturi section and drops to the recycle tank, which holds 12% per centum quantity of suspended solids so as to eliminate scaling of the system, (Grimm, 12-1746). The resulting water/

-5-

ON TIOS

TATE PUBLIBHING CO HELENA, MONT I

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

fly ash alkaline slurry is recycled through the Venturi and the counter current absorption spray section to effect sulfur dioxide removal. (Grimm, 12-1717, 1720). (A3)

### VII.

6 The flue gas enters the Venturi at the preheaters 7 outlet, (Grimm, 12-1717). The pressure drop in the 8 throat of the Venturi is governed by the plumb bob and 9 it restricts the flue gas stream so that the velocity 10 of the flue gas, when increased, mixes with the liquor 11 (water or recycled slurry) which is thus atomized. 12 The atomized liquor drops contact the particulate in 13 the flue gas and enlarges the fine particulate because 14 of the deposition of the atomized particles of liquor. 15 Thus the higher the velocity of the gas through the 16 throat of the Venturi, the higher atomization and more 17 removal of fine particulate takes place. (Abrams, 15-18 2026). The flue gas passes into the absorber sections 19 where the wash tray and demister remove entrained scrubber sludge and water droplets. (Grimm, 12-1726, 1727, 13-1828). Then, upon leaving the absorber section, it passes through the reheater section which heats the gases above their dew point to a termperature of 175° Fahrenheit, (Grimm, 12-1730). This reheating protects the induced draft fan from contract with a wet gas, thus keeping it dry and the heated gas gives the plume more buoyancy (Grimm, 12-1730, 13-1842; Raben, 23-3013). Waste scrubber sludge is continually bled from the system at a rate proportionate to the boiler load and removed fly ash. (A4)

20

21

22

23

24

25

26

27

28

1

2

3

-6-

DN D'4/XA

Chemical control of the scrubber system should be maintained at a ph of 5.0 to 5.6 (Grimm, 13-1867), to prevent scale, i.e., crystals of calcium sulfate and calcium sulfite, (Applicants' Exhibit 74, p. 3-2). A liquid to gas ratio of 33, i.e., 33 gallons of liquid per thousand actual cubic feet of incoming flue gas, (Grimm, 12-1719, 14-1913; Raben, 23-3010), in the entire system is used to remove the sulfur oxides, particulate matter, fluorides, (Grimm, 13-1787, 1788), oxides of nitrogen, (Abrams, 16-2272), lead, beryllium and other trace elements, (Grimm, 12-1720), (DNR Exhibit, 123), (Applicants' Exhibit, 74). A constant velocity of flue gas flow into the throat of the Venturi regardless of the boiler load is maintained by the use of the plumb bob to insure constant outlet grain loading of particulate matter, (Grimm, 12-1719; Abrams, 15-2071). The velocity of the flue gas going through the mist eliminator should be maintained at 8.7 feet per second at full load and 7.5 feet per second at average load of 80% to prevent plugging of the demister, (Abrams, 15-2075, 2076; Grimm, 14-1896), (Applicants' Exhibit, 74). (A-5)

## IX.

The system is designed without any by-pass, (Grimm, 13-1853), so that all flue gas from the boiler will be treated in the scrubber modules when the plant is in operation and thus meet emission standards, (Grimm, 14-1965). A by-pass is a means of ducting the flue gas around the scrubber modules in the event the modules become inoperable and by its use the flue gas passes

-7-

DN DJ/XH

Coli. No

TTATE PUBLISHING CO. HEI CHA, MONT.

2

3

4

5

6

7

8

9

10

i1

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

VIII.

2

3

6)

1

untreated to the stack, (Grimm, 14-1933, 1947). (A-

Χ.

4 Scaling in the scrubber is deterred by: (1) proper 5 control of ph through injection of lime as additional 6 alkali substance to absorb sulfur dioxide and (2) recycle 7 of the liquor which provides seed crystals of calcium 8 sulphate with the fly ash as precipitation sites for 9 calcium sulphate so as to prevent the super-saturation 10 of calcium sulphate in the recycled liquor, (Grimm, 11 14-1836, 1912; Raben, 23-2996, 2999). The recycle tank 12 of the system is a holding tank which catches the slurry 13 from the downcomer. It holds the volume of slurry for 14 eight minutes, which is equivalent to providing contact 15 with the liquor of each individual particle of fly ash 16 for ten hours, (Abrams, 14-2001). Thus the slurry is 17 desupersaturated, i.e., the solids of calcium sulfate 18 resulting from absorption of  $SO^2$  will deposit on the 19 nucleus of the calcium sulfate and fly ash existing 20 in the slurry. The effluent or waste, which is insoluble, 21 is placed in a separate holding tank for ten minutes 22 to complete the reaction and then is pumped to a retention . 23 pond where the solids settle. The remaining clear liquor 24 from the pond is returned to the system. The percentage 25 of suspended solids in the slurry liquor at 12%, will 26 help avoid scaling of the unit, (Abrams, 15-2073, 2075). 27 (A-7)

XI.

The operation of the scrubber will be controlled by operators in a control room where instruments record

-8-

BTÀTE PURLISHING CO. NELENA, MONT. CLI TAND 3

28

29

-30

31

32

(and co 't t ant

the inlet and outlet concentrations of  $SO^2$  and also record the ph of the scrubber system. In the event the outlet concentration incrases (above 260 ppm with an inlet concentration of 965 ppm) while the ph drops (below 5.6), the operator can add additional time to bring the ph to proper level and thus reduce the  $SO^2$ outlet concentration, (Grimm, 13-1875). (A-8)

XII.

The emission control system for Colstrip Units #3 and #4 is the best suited for the Colstrip plants because it makes use of the alkalinity nature of the fly ash found in the Rosebud coal and thus reduces dependence upon additional lime injection, (Grimm, 14-1964).

XIII.

The flue gas desulphurization system to be installed 16 at Colstrip Units #3 and #4 and which are presently 17 under construction at Units #1 and #2 may prove to be 18 reliable systems to remove pollutants from the flue gas because Venturi scrubbers have been in operation at other power generating plants and are not a new equipment system (Abrams, 14-1990). The Colstrip modules have improved the design and operating efficiencies over previous modules. (Labrie, 21-2770; Abrams, 14-1944, 1990; Raben, 23-3062). The alkali nature of the fly ash of Rosebud coal contributes to that improvement, (Abrams, 14-2000). In addition, the pilot plant study conducted at Corette generating station, Billings, Montana, confirmed the chemistry of the system, (Abrams, 15-2014; Raben, 33-2931). (Applicants' exhibits, 73 and 74). The particulate removal based upon pilot plant studies

-9-

oN ba/xa

Coll. No.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

19

20

21

22

-23

24

25

26

27

28

29

30

31

is projected within the range of 99.465% to 99.76% and will be enhanced by the utilization of the wash tray and stainless steel pleximesh in the scrubber units. (Abrams, 15-2042, 2045, 15-2034, 2035). Utilization of the wash tray reduced the solid buildup in the demister and improved the particulate removal, as well as  $SO^2$ removal. (Abrams, 15-2124, 2125).

XIV.

9 Pilot plant tests project that SO<sup>2</sup> emissions from 10 Units 1, 2, 3 and 4, will have an outlet concentration 14 under "worst" coal conditions of 1% fulfur (965 PPM) 12 of 260 PPM, at 100% load, with a ph of 5.6 and liquid 13 to gas ratio of 33. (Abrams, 15-2144, 2145). With outlet 14 concentration for sulfur dioxide under "worst" coal 15 conditions of 1% sulfur at 260 PPM, and based upon the 16 units running at 100% loan, the emissions for sulfur 17 dioxide would then be:

18 Units 3 or 4: 4633 pounds per hour or 585 grams per second;
19 Units 1 or 2: 2071 pounds per hour or 260 grans per second.
20 (Applicants' Ex. 64 and 65; Grim 13-1794, 1795,
21 1801;

Applicants' Ex. 61 and 62; Berube 8-1117, 1120, 1121, 1124)

Emissions for particulate matter for Units 1 or 2 is 184 pounds per hour, or 46 grams per second combined and for Units 3 or 4 is 408 pounds per hour each, or 103 grams per second combined. (Berube 9-1130, 1134).

The pilot plant tests also substantiate that fluoride emissions from the use of Rosebud coal, which contains 27 PPM, will emit 1.8 pounds per hour, or .227 grams per second, for Units 3 or 4, and .1 gram per second

-10-

Coll. No.

STATE PUBLISHING CO. HELENA, MONT,

22

23

24

25

26

27

28

29

30

31

32

1

2

3

4

5

6

7

1 from Units 1 or 2. (Grimm, 12-1788, 13-1789, 1790. Appli-2 cants' Ex. 74, p. 15.2.1). Beryllium in the coal will 3 be emitted at the rate of .0021 grams per second at 4 100% load for Units 3 or 4 (DNR Ex. 123), which is equiv-5 alent to .0061 grams per second for all four units. 6 (Faith, 43-6240). Lead emissions in the Rosebud coal 7 for Units 3 or 4 will be .0423 grams per second (DNR 8 Ex. 123), which is equivalent to 1.22 grams per second 9 for all 4 units. (Faith 43-6241). For oxides of nitrogen 10 calculated as N  $0^2$  , the emission rate for Units 1 and 11 2 combined at .7 pounds per million BTU is 4.740 pounds 12 per hour, or 598 grams per second; for Units 3 and 4 13 combined at .7 pounds per million BTU is 10602 pounds 14 per hour, or 1336 grams per second, and thus for all 15 four units emisssions at .7 pounds per million BTU is 16 15,342 pounds per hour, or 1934 grams per second. (Faith, 17 26-346, 3463). The scrubber will reduce 15 to 20 per 18 cent of the oxides of nitrogen emissions. (Abrams, 19 16-2272). (A-11) 20 XV. 21 The fuel to be used in Units #3 and #4 will be 22 Rosebud seam coal from the Colstrip area. (Berube 7-23 902). It will be mined from areas designated C, D and 24 E, shown on Exhibits 52, 53, 140 and 141. (Berube 8-25 1027-1029; Rice 28-3635-3636, 3640-3641). 26

XVI.

Con

The results of analyses of all the core hole samples, made by commercial testing laboratories, and which provide information necessary to properly specify equipment for Units #3 and #4 are included in Applicants' Ex. 53A and 53B, (Berube 7-908, 912, 913). The composition

27

28

29

30

31

32

-11-

of the coal was considered to estimate the quantities of ash and sulfur dioxide that would enter the boiler, leave the boiler, and enter any pollution control equipment. (Berube, 8-1041, 1042).

1

2

3

4

5

19

20

21

22

23

24

25

26

27

28

29

30

31

32

XVII.

6 The values of the basic composition of the coal 7 that should be considered for the emissions control 8 system, including averages, maximums and minimums proper 9 for design of the equipment are included in Applicants' 10 Exh. 54. (Berube 8-1042, 1043). 'This information is 11 an instruction for the equipment supplier and not a 12 description of the coal in the coal field. The value 13 of 1% sulfur is a maximum for design purposes because 14 it represents the maximum value of sulfur that the pollu-15 tion control equipment will have to contend with in 16 operation. (Berube 8-1044-1046). It is the maximum 17 value of sulfur authorized by this Board for certification 18 purposes.

## XVIII.

Tentative specifications have been prepared advising this Board of the proposed construction and operation of Units #3 and #4 (Applicants' Ex. 100).

## XIX.

The estimated capital cost of the system is \$151,614,000.00, which is equivalent to \$108.30 per kilowatt (Applicants' Ex. 108A), and this represents the least expensive and most economical system for Units #3 and #4. (Leffman 20-2410). The operation costs of Units 3 and 4 are also the most economical of all other systems and will operate at an estimated cost of \$1,030,000.00 per year. (Applicants' Ex. 108B).

-12-

oN b3/xa

Coll. No

2	A dispersion model is used to predict maximum ground
3	level concentrations. A dispersion model is a mathematical
4	equation which indicates the change in concentrations
5	of various pollutants in different positions downwind.
6	Tall stacks affect the ground level concentrations of
7	pollutants which come from the plant. In most models,
8	the basic characteristics include: (1) the stack and
9	emission parameters; (2) the plume rise equations; (3)
10	the dispersion (spread of the plume) equations; and
11	(4) the diffusion equation which calculate the ground
12	level concentrations. (Gelhaus 38-5068). Meterology
13	in the Colstrip area must be considered to determine
14	whether the peak or maximum concentrations as computed
15	by any model will in fact occur since air pollution
16	is very closely related to the atmosphere and the changes
17	of the atmosphere. (Crow, 25-3318, 3320, 3333, 3334,
18	43-6149).
19	XXI.
20	For predicting maximum ground level concentrations
21	for Units #3 and #4, one model used Briggs plume rise
22	equation (Applicants' Ex. 66), Hillsmeyer-Gifford plume
23	spread classified by the Pasquill method and the Gaussian
24	dispersion equations. Maximum concentrations were deter-
25	mined by multiplying the highest relative concentrations
26	by projected emission rates. (Applicants' Ex. 67 and

Inversion heights published by Holzworth apply.

# XXII.

Meterological data for the Colstrip area was gathered by the Earth Science Department of Montana State University

• •

-13-

UNLISHING C

27

28

29

30

31

32

121).

XX.

1 over a two-year period under a research grant funded 2 by Montana Power Company and in conjunction with the 3 Department of Health and Environmental Sciences. (Heimbach 4 24-3062; Applicants' Ex. 76, Part I and Part II; Ex. 5 76-B). Another dispersion model was developed by the 6 Montana State University personnel who conducted the 7 meterological study. (Heimback 24-3090, 3092) (Applicants' 8 Ex. 76 D, E, F and G).

## XXIII.

10 In applying the MSU model, predictions for 11 downwind distances of less than, or equal to, 2.3 kilometers 12 applicants divided by a factor of two. (Heimbach 24-13 3093, 45-6452, 6470) (Applicants' Ex. 183, p. 166). 14 All calculations using the MSU model were made assuming 15 an inversion at the top of the plume height for one 16 hour concentrations, this being a worst case condition 17 for an emission situation.

#### XXIV.

Based on the meterology data, the modeling calculations, and applicants' assumptions, the expected maximum (peak) ground level concentrations for the following pollutants are:

(1) Sulfur Dioxide.

(a) For Pasquill Methodology:

Maximum one hour ground-level concentrations for all four Units are 405 micrograms per cubic meter. The maximum three hour ground-level concentrations for Units 3 and 4 are 120 micrograms per cubic meter and for all tour Units are 194 micrograms per cubic meter. The maximum annual ground-level concentration for Units 3 and 4 are 0.9 micrograms per cubic meter and for all

-14-

Coll. No.

oN bA/xa

HATE CO.

9

18

19

20

21

22

23

24

25

26

27

. 28

29

30

31

four units are 1.4 micrograms per cubic meter.

(b) MSU Methodology:

Maximum one-hour ground-level concentrations for all four Units are 256 micrograms per cubic meter. Maximum three-hour ground-level concentrations for Units 3 and 4 are 100 micrograms per cubic meter, and for all four Units are 156 micrograms per cubic meter. Maximum 24-hour ground-level concentrations for Units 3 and 4 are 40 micrograms per cubic meter and for all four Units are 63 micrograms per cubic meter.

I

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

(2) Particulate matter.

(a) Using Pasquill Methodology.

The maximum annual ground-level concentrations of particulate for Units 1 and 2 are .05 micrograms per cubic meter. For Units 3 and 4 are 0.07 micrograms per cubic meter, and for all four Units are 0.11 micrograms per cubic meter. The maximum 24-hour ground-level concentrations of particulate for Units 1 and 2 are 0.9 micrograms per cubic meter, for Units 3 and 4 are 1.3 micrograms per cubic meter, and for all four Units are 2.1 micrograms

(b) Using MSU Methodology.

The maximum 24-hour ground-level concentrations of particulate for Units 3 and 4 are 3.7 micograms per cubic meter, and for all four Units are 5.9 micrograms per cubic meter.

(3) Oxides of Nitrogen (Calculated as  $NO^2$ ).

Pasquill Methodology - Annual.

For Units 1 and 2 are 0.6 micrograms per cubic meter, for Units 3 and 4 are 1.1 micrograms per cubic -15-

oki iton

PUBLISHING CO. HELENA, MONT.

meter, and for all four Units are 1.7 micrograms per 1 2 cubic meter. Sulfates: (4) 3 Pasquill Methodology: (a) 4 5 Maximum one-hour ground-level concentrations for all four Units are 0.1 micrograms per cubic meter. 6 7 Maximum 24-hour ground-level concentrations for all four Units are 0.4 micrograms per cubic meter. Maximum 8 annual ground-level concentrations for all four Units 9 10 are 0.2 micrograms per cubic meter. 11 (b) MSU Methodology: 12 Maximum one-hour ground-level concentrations 13 for all four Units are 7.8 micrograms per cubic meter. 14 Maximum 24-hour ground-level concentrations for all four Units are 1.1 micrograms per cubic meter. 15 16 (5) Fluorides: 17 Pasquill Metnod: (a) 18 Maximum 24-hour ground-level concentrations 19 for all four Units are 0.01 parts per billion. 20 (b) MSU Method: 21 Maximum 24-hour ground-level concentrations 22 for all four Units are 0.03 parts per billion. 23 (6) Beryllium: 24 (a) Pasquill Methodology: 25 For all four Units the 24-hour concentration 26 would be .000084 micrograms per cubic meter. The 30-27 day value could not be greater. 28 The corresponding calculation for MSU (b) 29 methodology is .00026 micrograms per cubic meter. 30 (7) Lead: 31 For Pasquill methodology, all four Units, (a) 32 -16-

1 the 24-hour concentration would be .00168 micrograms
2 per cubic meter. The 30-day value would be less.

3 (b) The corresponding calculation for MSU
4 methodology would be .0045 micrograms per cubic meter.
5

XXV.

Colstrip Units 3 and 4 will project two 525-foot
7 stacks and will project compliance with all applicable
8 standards.

### XXVI.

10 Generally there are four steps in the development 11 of a power plant pollution control system. The first 12 step is bench scale, which is what the applicants did 13 at the Corette Station. The next step is a pilot plant, 14 which will provide for the testing of the Units, coming 15 to 25 times the size of the unit tested at the Corette 16 Station. The next step would be a prototype of a demonstration 17 unit. The last step would be a commercial unit in operation. 18 (Raben 23-2967). (0-119)

### XXVII.

The criteria established by the National Academy of Engineers are generally accepted. They require 90% or greater sulfur oxide recovery, 90% availability of a reliable system, one year of commercial demonstation on a 100 megawatt unit or larger, and economic feasibility for operation based upon sufficient data.

### XXVIII.

Colstrip Unit #1 would produce useful information
to be incorporated into Units 3 and 4 for consideration
of the proper pollution control there to be installed.
(Crow, 26-3427; Grimm 14-1921).. (0-125). Colstrip
#1 is presently available for observation and evaluation.

-17-

BTATE PUBLIBHING CO HALENA, MONT.

9

19

(Leffman, 19-2484).

1

2

9

20

21

22

23

24

25

26

27

28

29

30

31

32

## XXIX.

A closed loop water system (a system which does not discharge effluents from the plants downstream or into other waters) was adopted for Colstrip Units 1-4 so that there would be no discharge from the plants into the Yellowstone River or other state waters. (Labrie 20-2627, 45-6444-6446).

#### XXX.

10 The surge pond is located approximately one mile  $\mathbf{H}$ northwest of the plants and comprises approximately 12 160 acres. When filled it will hold approximately one 13. billion gallons of water or 2800 acre feet. It contains 14 19 days' storage of water at summer withdrawal rates 15 for Units 1-4 and 26 days' storage of water for winter 16 withdrawal rates for the four units. (Grimm, 12-1701, 17 13-1834; Labrie, 20-2630; Berube, 22-2831-2832; McMillan, 18 43-6177-6184, 6227; Applicants' Exhibits 51, 175.) (A-19 31)

### XXXI.

Much of the waste matter from the four units, such as ash from the scrubber and boiler systems, suspended solids, sediment, and other matter, will be disposed of by using water to convey them to their eventual destinations, the disposal ponds. In some instances the wastes will be further processed and clean water will be returned into the system in order to reduce the amount of water used. Waste ash from various systems and some other waste will be first sluiced to temporary retention ponds located in a 40-acre area just south of the plants. These wastes will eventually be moved to the ultimate

-18-

Coll. No.

Bx/Fd No

ETATE PUBLIBHING CO. HELENA, MONT.

I disposal ponds by slurry pipeline. The first two perman-2 ent disposal areas developed will be located approximately 3 10,000 feet northwest from the plants in Sections 20, 4 21, 28 and 29, Township 2 North, Range 41 East. During the life of Units 3 and 4, it will be necessary to develop 6 further disposal ponds to be located in Sections 5, 6, 7 7 and 8, Township 1 North, Range 42 East. After these 8 ponds are filled with waste, they will be dried up, 9 covered with dirt and reclaimed. The first permanent 10 retention pond will contain a surface acreage of approxi-11 mately 112 acres and it, like all the other retention 12 ponds, will be sealed, using normal construction methods. 13 The first permanent retention pond will have a useful 14 life of approximately six years if the pond is utilized 15 for all four units. Its useful life will be approximately 16 12 years in the event that it is utilized for the wastes 17 from Units 1 and 2 only. (Labrie, 20-2625-2628, 21-2731-2733; Grimm 12-1701-1712; Berube, 22-2831-2838, 2800-2861, 45-6474-6475, 6527-6530; (Applicants' Ex. 50A, 51.) (A-32)

### XXXII.

Maximum water consumption for Colstrip Units 1, 2, 3 and 4, running at full or 100% load will be reached during the summer months of July and August of each year at the rate of approximately 56.12 cubic feet per second (approximately 25,187 gallons per minute or 40,631 acre feet annually). (Labrie, 20-2629-2630; Berue, 22-2839-2842; Applicants' Exhibit 50B). (A-33) XXXIII.

The lowest historical daily flow of water in the Yellowstone River at the location of Nichols is approxi-

-19-

:oN'b'i\x8

Coll. No.

18

19

20

21

· 22

23

24

25

26

27

28

29

30

31

ately 1,000 cubic feet per second (approximately 448,800 gallons per minute or 724,000 acre feet annually). Lowest flows of water in the Yellowstone River at the point of diversion near Nichols occur during the winter months of December, January and February with the highest flows during the spring month of June. (Labrie, 20-2630; Dunkle, 30A-3903) (Applicants' Ex. 137, 138). (A-36)

## XXXIV.

10 Because of the storage capacity of the surge pond and the historical flows of water on record in the Yellow-12 stone River, it will not be necessary for the Applicants 13 to withdraw water from the Yellowstone River for use 14 in their Colstrip Units when the river is flowing water at Nichols less than 1,500 cubic feet per second (673,000 gallons per minute or 1,086,000 acre feet per year). (Labrie, 20-2630). (A-38)

### XXXV.

Dissolved solid concentrations in the Yellowstone River increase downstream and decrease with increased flow. Suspended sediment in the Yellowstone River also varies with flow, but in a manner opposite to the dissolved solid concentations; that is, suspended sediment increases with increasing flow. In general, water quality is best in the Yellowstone River at high flow periods in the more upstream locations, but sediment detracts from this quality at high flow periods, particularly at downstream locations. (Dunkle, 29-3822-3823; Botz, 39-5222-5223). (A - 42)

# XXXVI.

The effects of the withdrawal of water from the

-20-

Coll. No.

Bx/Fd No.

1

2

3

4

5

6

7

8

9

11

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

Yellowstone River for utilization at Colstrip Units 1-4 as proposed by the applicants does not appear to be significant. (Dunkle, 29-3824-3826; Willems, 38-5157; Botz, 39-5229-5231).

### XXXVII.

The impact of the withdrawal of water from the Yellowstone River for utilization at Colstril Units 1-4 as proposed by the Applicants upon the water quality of the Yellowstone River will be insignificant and will not cause a violation of any of the standards applicable to the Yellowstone River. (Willems, 38-5157). (A-46) XXXVIII.

The impact of Colstrip Units 1-4 upon surface water quality outside of the Yellowstone River will be insignificant and will not violate any applicable standards. (Botz, 39-5223-5227; Willems, 38-5157-5158). (A-47)

## XXXIX.

The various ponds which will be used for storage of water in the evaporation and disposal of water and waste materials emanating from Colstrip Units 1-4 will have seepage not anticipated to impair the quality of the ground water in the area. (Northern Plains Ex. 2, 3A; Berube, 22-2831-2839; Grimm, 44-6370-6376).

#### ·XXXX.

The applicants were aware of the generalized statement of the non-degradation standards both in the Montana State Implementation Plan and the statutes and regulations of the Department of Health and Environmental Sciences and the Board of Health and Environmental Sciences in the State of Montana. The applicants knew that it would be necessary to resolve the highest state of the art in their pollution control system. (Berube, 10-1392,

-21-

oV b7\xa

Coll. No

HALENA, MONT,

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

------

1393) (0-144).

#### CONCLUSIONS OF LAW

The Board concludes, based upon the testimony, and the exhibits in the record before it, that the proper procedure for it is to grant <u>conditional</u> certification for Colstrip Units 3 and 4 subject to possible suspension thereof.

7 1. The applicants' will utilize only coal from
8 the Rosebud seam. It will at no time exceed 1% inlet
9 sulfur content. Daily testing of the coal and sulfur
10 content will be required to effect that control.

11. 2. The operation of the air quality system in 12 Colstrip #1 will be closely monitored by the Department 13 of Health and Environmental Sciences and the applicants. 14 The data therefrom is to be interpreted by the Department 15 as to the effectiveness of such system of control of 16 air quality. This monitoring will be continuous during 17 the construction of Units #3 and #4. In the event Colstrip 18 #1 violates the compliance standards during its operation 19 and performance, certification of Colstrip Units #3 20 and #4 will be suspended pending the implementation 21 of modifications in Colstrip Units 1, 2, 3 and 4 to 22 bring the units into compliance.

3. The certification with conditions herein set forth does not constitute a waiver of any of the requirements of the Clean Air Act, the Water Pollution Control Act, or the implementation plan, including the necessity of obtaining a permit in accordance with the rules and regulations implemented under Section 69-3911, R.C.M. 1947.

4. Any compliance modifications required during the operations of Colstrip Units 1 or 2 will be installed in

-22-

32

100 3

30

31

1

1	Colstrip Units 3 and 4.
2	5. No water will be withdrawn from the Yellowstone
3	River when the Yellowstone River is flowing at Nichols
4	less than 1,500 cubic feet per second. Daily testing
5	will be required during periods of low water.
	6. All ponds, surge ponds, settling ponds, and
- 7	impoundments shall be properly sealed. They shall be
8	monitored for seepage, including the installation of test
9	wells to determine the extent of ground water pollution,
10	and the necessities of correction therefor.
Ħ	Dated this 21st day of November, 1975.
12	E
13	MONTANA BOARD OF HEALTH AND ENVIRONMENTAL SCIENCES
14	$\Lambda (1) \rightarrow i \rho / h h h$
15	By tity U. Bartleft
10	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
. 30	
31	
32	_23_
BTATR PUBLISHING CO.	-23-
HELENA, MONT.	
	•

Bx/Fd Yo.

r

Coll. No.